

A large version of the BIPV boost logo, centered on the page.

## **D8.2 Report on the design and simulation of PV and energy performance of each demonstration installation**

Report Name: BIPVBOOST-WP8-T82-D82\_M33-COMSA-20211103-v03.pdf  
Version Number: 03

Document Number: D8.2  
Due Date for submission: 30/06/2021  
Actual Submission date: 03/11/2021  
Lead Beneficiary: COMSA  
Document Dissemination Level: Public

### ***BIPVBOOST***

**“Bringing down costs of BIPV multifunctional solutions and processes along the value chain, enabling widespread nZEBs implementation”**

**Start date: October 2018. Duration: 4 Years**

## Summary

### Document Information

<b>Title</b>	D8.2: Report on the design and simulation of PV and energy performance of each demo case
<b>Lead Beneficiary</b>	COMSA
<b>Contributors</b>	COMSA, ISFOC, MASS, OPTIMAL, PIZ, ONYX, TULIPPS, FLISOM, SCHWEIZER, VIRIDEN, EnerBIM, TECNALIA
<b>Distribution</b>	Public
<b>Report Name</b>	BIPVBOOST-WP8-T82-D82_M33-COMSA-20211103-v03

### Document History

Date	Version	Prepared by	Organisation	Approved by	Notes
2/12/2019	1	Sergio Valentino Costa, Merche Polo	COMSA	Merche Polo, José M. Vega, Francesco Frontini	Pre-design of demo-sites. Submitted to the EC. Milestone 1
09/07/2021	2	Enric Ortega, Marcela Rubio, Merche Polo	COMSA	Merche Polo	Design of demo-sites
03/11/2021	3	Marcela Rubio, Enric Ortega, Merche Polo	COMSA	Merche Polo, José M. Vega	Design of demo-sites. Submitted to the EC

## Acknowledgements

The work described in this publication has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement N° 817991.

## Disclaimer

This document reflects only the authors' view and not those of the European Community. This work may rely on data from sources external to the members of the BIPVBOOST project Consortium. Members of the Consortium do not accept liability for loss or damage suffered by any third party as a result of errors or inaccuracies in such data. The information in this document is provided "as is" and no guarantee or warranty is given that the information is fit for any particular purpose. The user thereof uses the information at its sole risk and neither the European Community nor any member of the BIPVBOOST Consortium is liable for any use that may be made of the information.



## Contents

Summary1	
Document Information.....	2
Document History .....	2
Acknowledgements .....	2
Disclaimer .....	2
<b>1 EXECUTIVE SUMMARY.....</b>	<b>13</b>
1.1 Description of the deliverable content and purpose .....	13
1.2 Relation with other activities in the project.....	14
<b>2 DEMO SITE 1: ISFOC.....</b>	<b>15</b>
2.1 DEMO-SITE BUILDING DESCRIPTION .....	15
2.2 ARCHITECTURAL BIPV DESIGN.....	16
2.2.1 Existing demo-site building .....	17
2.2.2 Architectural BIPVBOOST design .....	17
2.3 BIPV STRUCTURE DESIGN .....	19
2.3.1 Existing building structure .....	19
2.3.2 BIPVBOOST structure.....	22
2.4 BIPV MODULE DESIGN.....	26
2.4.1 Balustrades based on glass-glass bifacial modules .....	26
2.4.2 Walkable floor based on back-contact solar cells .....	29
2.4.3 BIPVBOOST modules electrical design .....	34
2.5 BIPV ELECTRICAL SYSTEM DESIGN.....	35
2.5.1 BIPVBOOST system components.....	37
2.5.2 BIPVBOOST electrical diagram .....	39
2.6 BIPV MONITORING DESIGN .....	41
2.6.1 Definition of monitoring objectives: BIPV performance validation, economic viability and progress towards NZEB requirements.....	41
2.6.2 Definition of variables to be monitored .....	42
2.6.3 Existing monitoring system .....	45
2.6.4 BIPVBOOST monitoring system .....	46
2.7 BIPV Modelling and performance simulation .....	49
2.7.1 Element level to building level methodology using 3D modelling and simulation tools .....	49
2.7.2 Modelling strategy retained for transparent and opaque BIPV .....	50
2.7.3 DEMO#1 – ISFOC building, 3D design from 2D plans, simulation with BIMsolar.....	51
2.7.4 Summary of the results .....	75
2.7.5 Conclusions.....	76
2.8 Planning Timeline .....	77
<b>3 DEMO SITE 2: MASS .....</b>	<b>78</b>
3.1 DEMO-SITE BUILDING DESCRIPTION .....	78



3.1.1	General topology .....	78
3.2	ARCHITECTURAL BIPV DESIGN.....	79
3.2.1	Demo 2 selected design .....	81
3.3	BIPV STRUCTURE DESIGN .....	83
3.3.1	Building to module structure.....	83
3.3.2	Module fixing structure .....	88
3.4	BIPV MODULE DESIGN.....	89
3.4.1	BIPVBOOST module/s.....	90
3.5	BIPV ELECTRICAL SYSTEM DESIGN.....	106
3.5.1	BIPVBOOST electrical diagram .....	106
3.6	BIPV MONITORING DESIGN.....	107
3.6.1	Definition of monitoring objectives: BIPV performance validation, economic viability and progress towards NZEB requirements.....	107
3.6.2	Definition of variables to be monitored.....	107
3.6.3	Existing monitoring system .....	109
3.6.4	BIPVBOOST monitoring system .....	109
3.7	BIPV Modelling and performance simulation .....	111
3.7.1	Element level to building level methodology using 3D modelling and simulation tools .....	111
3.7.2	Modelling strategy retained for transparent and opaque BIPV .....	111
3.7.3	DEMO#2 – MASS building, 3D design from 2D plans, simulation with BIMsolar....	112
3.7.4	Summary of the results .....	127
3.7.5	Conclusions.....	127
3.8	Planning Timeline .....	129
<b>4</b>	<b>DEMO SITE 3: OPTIMAL .....</b>	<b>130</b>
4.1	DEMO-SITE BUILDING DESCRIPTION .....	130
4.1.1	Building description .....	130
4.1.2	General topology .....	130
4.1.3	Grid connection & Equipment.....	131
4.1.4	Energy consumption.....	132
4.1.5	BIPV system to be installed .....	132
4.1.6	Monitoring system .....	133
4.2	ARCHITECTURAL BIPV DESIGN.....	134
4.2.1	Existing demo-site building .....	134
4.2.2	Architectural BIPVBOOST Design Options.....	134
4.2.3	Detailed selected architectural design .....	141
4.3	BIPV STRUCTURE DESIGN .....	148
4.3.1	Existing building structure (roof).....	148
4.3.2	BIPVBOOST roof/tile structure .....	149
4.4	BIPV MODULE DESIGN.....	150
4.4.1	BIPVBOOST module/s.....	150
4.4.2	BIPVBOOST module/s electrical Design.....	151
4.5	BIPV ELECTRICAL SYSTEM DESIGN.....	152
4.5.1	PV Inverter.....	152

4.6	BIPV MONITORING DESIGN.....	158
4.6.1	Definition of monitoring objectives: BIPV performance validation, economic viability and progress towards NZEB requirements.....	158
4.6.2	Definition of variables to be monitored.....	158
4.6.3	BIPVBOOST monitoring system.....	161
4.7	BIPV MODELLING AND PERFORMANCE SIMULATION.....	165
4.7.1	Element level to building level methodology using 3D modelling and simulation tools.....	165
4.7.2	Modelling strategy retained for CIGS films mounted on roof tiles (integrated system by SCHWEIZER) – Opaque BIPV.....	165
4.7.3	DEMO#3 – OPTIMAL building, 3D design from 2D plans, simulation with BIMsolar.....	165
4.7.4	Summary of the results.....	185
4.7.5	Conclusions.....	185
4.8	Planning Timeline.....	185
<b>5</b>	<b>DEMO SITE 4: PIZ.....</b>	<b>187</b>
5.1	DEMO-SITE BUILDING DESCRIPTION.....	187
5.2	ARCHITECTURAL BIPV DESIGN.....	188
5.2.1	Existing demo-site building.....	188
5.2.2	Architectural BIPVBOOST Design.....	189
5.3	BIPV STRUCTURE DESIGN.....	195
5.3.1	Existing building structure.....	195
5.3.2	BIPVBOOST structure.....	196
5.4	BIPV MODULE DESIGN.....	196
5.4.1	ePIZ glass-glass module description.....	196
5.4.2	Demo-site module/s design.....	198
5.4.3	BIPVBOOST module/s electrical Design.....	200
5.5	BIPV ELECTRICAL SYSTEM DESIGN.....	207
5.5.1	BIPVBOOST system components.....	207
5.5.2	BIPVBOOST electrical diagram.....	208
5.6	BIPV MONITORING DESIGN.....	210
5.6.1	Definition of monitoring objectives: BIPV performance validation, economic viability and progress towards NZEB requirements.....	210
5.6.2	Definition of variables to be monitored.....	210
5.6.3	BIPVBOOST monitoring system.....	212
5.7	BIPV MODELLING AND PERFORMANCE SIMULATION.....	216
5.7.1	Element level to building level methodology using 3D modeling and simulation tools.....	216
5.7.2	Modeling strategy retained for transparent and opaque BIPV.....	216
5.7.3	DEMO#4 – PIZ building, 3D design from 2D plans, simulation with BIMsolar.....	217
5.7.4	–Summary of the results.....	249
5.7.5	Conclusions.....	249
5.9	Planning Timeline.....	251
<b>6</b>	<b>NEXT STEPS.....</b>	<b>252</b>

## Tables

Table 2.1: South balustrade - PV glass module data-sheet.....	19
Table 2.2: South balustrade - PV glass module data-sheet.....	27
Table 2.3: East and West balustrades - PV glass module data-sheet.....	28
Table 2.4: 750 x 750 (25 cells) walkable floor tile data-sheet.....	31
Table 2.5: 750 x 750 (16 cells) walkable floor tile data-sheet.....	32
Table 2.6: 600 x 600 (16 cells) walkable floor tile data-sheet.....	33
Table 2.7: ISFOC demo installation characteristics .....	34
Table 2.8: Main characteristics - HUAWEI Luna 2000-10-S0 storage.....	38
Table 2.9: Main characteristics - HUAWEI SmartLogger 3000A.....	39
Table 2.10: BIPVBOOST – ISFOC installation. Wiring calculations.....	40
Table 2.11: Description of the variables shown in Figure 2.32 and the instruments used to for the measurements .....	43
Table 2.12: List of the pre-existing monitoring equipment at ISFOC .....	45
Table 2.13 Configuration of ONYX Solar Walkable floor modules .....	52
Table 2.14 Configuration of ONYX Solar Balustrade modules .....	54
Table 3.1: Data sheet of glass-glass module with 48 poly-crystalline cells and tempered rear glass RAL 3020 .....	92
Table 3.2: Data sheet of glass-glass module with 44 poly-crystalline cells and tempered rear glass RAL 3020 .....	94
Table 3.3: Data sheet of glass-glass module with 40 poly-crystalline cells and tempered rear glass RAL 3020 .....	96
Table 3.4: Data sheet of glass-glass module with 36 poly-crystalline cells and tempered rear glass RAL 3020 .....	98
Table 3.5: Data sheet of glass-glass module with 32 poly-crystalline cells and tempered rear glass RAL 3020 .....	100
Table 3.6: Data sheet of glass-glass module with 28 poly-crystalline cells and tempered rear glass RAL 3020 .....	102
Table 3.7: Data sheet of glass-glass module with 24 poly-crystalline cells and tempered rear glass RAL 3020 .....	104
Table 3.8: Aretxabaleta demo site variables measurement information: required instruments, range, units, Time resolution and accuracy .....	108
Table 4.1: Available roof area .....	134
Table 4.2: Summary of panel placement options and their power .....	135
Table 4.3: Optimal demo site variables measurement information: required instruments, range, units, Time resolution and accuracy .....	159
Table 5.1 Total number of BIPV modules required for demo-site 4 installation .....	200
Table 5.2 Demo-site 4, technical data sheet of ONYX PV module type A1 and A2.....	201
Table 5.3 Demo-site 4, technical data sheet of ONYX PV module type B1 and B2.....	203
Table 5.4 Demo-site 4, technical data sheet of ONYX PV module type C1 and C2.....	205
Table 5.5 Demo-site 4, list of electrical components.....	207
Table 5.6. Description of the variables shown in Figure 5.38 and the instruments used for the measurements.....	211
Table 5.7 Configuration of ONYX Solar Cladding modules.....	217

## Figures

Figure 1.1 Demo-Site design Scenario Chart.....	13
Figure 2.1: ISFOC Headquarter satellite view (Google maps) .....	15
Figure 2.2: ISFOC 800kW CPV power plant .....	15
Figure 2.3: Drawing of ISFOC building .....	16
Figure 2.4: ISFOC building – South façade.....	16
Figure 2.5: ISFOC building – Rooftop floor .....	17
Figure 2.6: ISFOC building, areas to cover with the BIPVBOOST solutions .....	18
Figure 2.7: ISFOC rooftop balustrade .....	20
Figure 2.8: Balustrade element .....	20
Figure 2.9: Attachment of the balustrade to ISFOC building .....	21
Figure 2.10: ISFOC walkable floor, concrete tiles.....	21
Figure 2.11: Detail of the supporting elements (plots) .....	21
Figure 2.12: Reinforcement of the south balustrade.....	22
Figure 2.13: Reinforcement of the east/west balustrade .....	23
Figure 2.14: Detail of the assembly elements to use for the installation of the PV modules in the balustrade .....	24
Figure 2.15: Walkable floor. Metallic frame over the plots to mount the PV tiles .....	25
Figure 2.16: Walkable floor. Forces calculation .....	25
Figure 2.17: PV glass module design for South (left) and West/East (right) balustrades respectively....	26
Figure 2.18: Glass configuration of the PV glass module design for the balustrades .....	29
Figure 2.19: Small module design. Front and back side of the manufactured bifacial module.....	29
Figure 2.20: Front side of the PV tile manufactured: 8mm anti-slip / back-contact / 8mm glass .....	30
Figure 2.21: PV designs for the walkable floor .....	30
Figure 2.22: Glass configuration of the PV glass tile design for the walkable floor .....	34
Figure 2.23: Walkable floor based on back-contact solar cells. ISFOC rooftop design .....	35
Figure 2.24: BIPVBOOST ISFOC demonstration – Electrical installation .....	36
Figure 2.25: Photovoltaic inverter HUAWEI SUN2000-2KTL-L1 .....	37
Figure 2.26: Efficiency curve and circuit diagram - HUAWEI SUN2000-2KTL inverter .....	37
Figure 2.27: Photovoltaic inverter HUAWEI SUN2000-10KTL-M1 .....	37
Figure 2.28: Efficiency curve and circuit diagram - HUAWEI SUN2000-10KTL-M0 inverter .....	38
Figure 2.29: Li-ion batteries pack HUAWEI Luna 2000-10-S0 .....	38
Figure 2.30: Smart zero export control - HUAWEI SmartLogger 3000A.....	39
Figure 2.31: BIPVBOOST – ISFOC installation single-line diagram .....	41
Figure 2.32: Main measuring variables of Puertollano demo site. Blue variables will be monitored since the pre-intervention year and the red variables will be monitored from the postintervention onwards .....	42
Figure 2.33: Pre-existing monitoring equipment at ISFOC.....	46
Figure 2.34: Main measuring variables of Puertollano demo site. ....	47
Figure 2.36: Layout of pre intervention monitoring system at Puertollano demo site .....	48
Figure 2.37: Detailed schema of the installed monitoring system connections .....	48
Figure 2.38: Screenshot of the web-datalogger .....	49
Figure 2.39 Walkable floor – ONYX Solar .....	51
Figure 2.40 Data sheets of the front face of the prototype of 1180 mm x 810 mm.....	54
Figure 2.41 Data sheets of the front face of the prototype of 11580 mm x 810 mm.....	54

Figure 2.42 Modelling has been made as much realistic as it could be from the existing 2D plans to address BIPV issues (Trimble SketchUp model from EnerBIM) .....	58
Figure 2.43 Close and far shadowing calculation are made through 3D modelling of realistic buildings - Sun course for full year is displayed at hourly step time .....	59
Figure 2.44 Albedo effects (reflected irradiance) are generated selecting groups and types of surfaces 50% as a setup for surroundings and for the building envelop as a general approach .....	59
Figure 2.45 c-Si walkable floor=192 modules – Total 9.2kWp / 69.1sqm .....	62
Figure 2.46 Global results at array level – Year#1 - Walkable floor layout .....	63
Figure 2.47 Bifacial c-Si south balustrade= 108 modules; bifacial c-Si east + west balustrade= 24 modules – Total 12.8kWp / 125.6sqm .....	63
Figure 2.48 Global results at array level – Year#1 - Balustrades layouts .....	64
Figure 2.49 Shading computation: walkable floor – Highest losses=13.5% (module 26-6) .....	64
Figure 2.50 Electrical layout .....	65
Figure 2.51 INVERTERS and strings configuration in BIMsolar – Walkable floor .....	65
Figure 2.52 INVERTERS and strings configuration in BIMsolar – South balustrade .....	66
Figure 2.53 INVERTERS and strings configuration in BIMsolar – East & West balustrades .....	66
Figure 2.54 PV generation + shading: walkable floor (module 26-6) .....	67
Figure 2.55 PV generation + shading: East balustrade (module 3-1) .....	67
Figure 3.1: Google maps top view of the factory .....	78
Figure 3.2: CAD rendering of the pavilion .....	78
Figure 3.3: East façade of MASS building .....	79
Figure 1.4 Different configurations for Demo2 .....	79
Figure 1.5 Economic table for different options of Demo2 .....	80
Figure 3.6: Demo 2 final design .....	81
Figure 3.7: detail of the variable module design .....	82
Figure 3.8: MASS substructure for Tulipps framing assembly .....	87
Figure 3.9: Framing provided by Tulipps .....	88
Figure 3.10: Composition of the panels .....	89
Figure 3.11: 2000m x 667 mm with 48 cells module manufactured by Onyx .....	89
Figure 3.12: Glass-glass laminate composition for demo prototypes .....	90
Figure 3.13: Façade glass-glass with 48 poly-crystalline cells and tempered rear glass RAL 3020 .....	91
Figure 3.14: Façade glass-glass with 44 poly-crystalline cells and tempered rear glass RAL 3020 .....	93
Figure 3.15: Façade glass-glass with 40 poly-crystalline cells and tempered rear glass RAL 3020 .....	95
Figure 3.16: Façade glass-glass with 36 poly-crystalline cells and tempered rear glass RAL 3020 .....	97
Figure 3.17: Façade glass-glass with 32 poly-crystalline cells and tempered rear glass RAL 3020 .....	99
Figure 3.18: Façade glass-glass with 28 poly-crystalline cells and tempered rear glass RAL 3020 .....	101
Figure 3.19: Data sheet of glass-glass module with 24 poly-crystalline cells and tempered rear glass RAL 3020 .....	103
Figure 3.20: Electrical diagram provided by Ekilor .....	106
Figure 3.21: Main measuring variables of Aretxabaleta demo site .....	107
Figure 3.22: Pre-intervention monitoring system connection schema .....	110
Figure 3.23: Roof installation of the instruments devoted to meteorological data .....	110
Figure 3.24: Screenshot of the web datalogger .....	111
Figure 3.25: Viriden+Partner – Project East Façade – Variant 38 design (vertical configuration) .....	113
Figure 3.26: Onyx Solar – Detailing modules – Double sized (final choice) .....	113
Figure 3.27: Configuration of ONYX Solar V38 modules .....	115
Figure 3.28: Modelling has been made as much realistic as it could be from the existing 2D plans to address BIPV issues (Trimble SketchUp model from Viridén+Partner) .....	117
Figure 3.29: Close and far shadowing calculation are made through 3D modelling of realistic buildings - Sun course for full year is displayed at hourly step time .....	118

Figure 3.30: Albedo effects (reflected irradiance) are generated selecting groups and types of surfaces 20% for surroundings; 50% for the building envelop; 80% for cladding as a general approach .....	119
Figure 3.31: Global results – All layouts – V38 version – non tilted BAPV modules .....	122
Figure 3.32: Mapping of shading losses – No issue – No significant shading .....	122
Figure 3.33: Inverter selection and optimized wiring – 1 string inverter / 2 MPPTs .....	123
Figure 3.34: Monthly AC generation + ohmic losses: inverter output .....	123
Figure 3.35: MASS <i>Demo-site Gantt Chart</i> .....	129
Figure 4.1: Google and CAD view of the whole building .....	130
Figure 4.2: Picture of the house with the front view (left) and the back view (right) .....	131
Figure 4.3: Picture of the office next to the house (left) and top view of the whole building (right)....	131
Figure 4.4: Yearly electrical consumption of the house .....	132
Figure 4.5: Measure of daily electrical and gas consumption of the current building .....	132
Figure 4.6: Cross section of the house showing the roof slope and dimensions .....	133
Figure 4.7: Demo-site 3 building, east and west side.....	134
Figure 4.8: Scenario 1.1 (Max power). East (top), West (bottom) .....	136
Figure 4.9: Scenario 1.11 (Max power).: East (top), West (bottom) .....	137
Figure 4.10: Scenario 1.12 (Max power). Alternative option for the East roof.....	138
Figure 4.11: Scenario 1.2 (Max power). East (top), West (bottom) .....	139
Figure 4.12: Scenario 2 (Architectural Design). East (top), West (bottom).....	140
Figure 4.13: Cost evaluation.....	142
Figure 4.14: Final design.....	143
Figure 4.15: Junction details at the top of the Velux .....	144
Figure 4.16: Junction details at the bottom of the Velux.....	144
Figure 4.17: Junction details on the side of the Velux .....	145
Figure 4.18: Ridge details .....	145
Figure 4.19: Details at the bottom junction with the gutter.....	146
Figure 4.20: Details at the side edge of the roof.....	146
Figure 4.21: East roof details.....	147
Figure 4.22: West roof details .....	147
Figure 4.23: Building permit .....	148
Figure 4.24: Existing roof structure of Demo-site 3 .....	148
Figure 4.25: Details at the eaves of Demo-site 3 roof.....	149
Figure 4.26: Vertical section detail eaves and gutter.....	149
Figure 4.27: Structural design of the CIGS on metal roof module families (vertical and horizontal oriented CIGS subcells) .....	150
Figure 4.28: Preliminary datasheet of the CIGS on metal modules, part 1.....	151
Figure 4.29: Preliminary datasheet of the CIGS on metal modules, part 2.....	151
Figure 4.30: Comparison PV Field South and East-West oriented (from Fronius: "Efficient East-West Oriented PC Systems with one MPP tracker") .....	153
Figure 4.31: SMA simulation provided by a third-party SMA reseller. ....	155
Figure 4.32: Options to connect the panels and design the strings.....	156
Figure 4.33: SMA Sunny Tri-power.....	157
Figure 4.34. Measured variables on optimal demo site. In Blue the variables measured during the preintervention period and in red the variables that will be also measured during the postintervention period.....	159
Figure 4.35. Monitoring system elements located in the Cellar. ....	161
Figure 4.36 Monitoring system elements located in the ground level. ....	162
Figure 4.37. Monitoring system elements located in the south and north facades. ....	162
Figure 4.38. Calorimeter installation schema .....	163



Figure 4.39. Main board components, lay-out and connections.....	163
Figure 4.40. Secondary board components, lay-out and connections.....	164
Figure 4.41. Monitoring system installed components; meteorological instruments and main board. .....	164
Figure 4.42: Modelling has been made as much realistic as it could be from the existing 2D plans to address BIPV issues (Trimble SketchUp model from FD2 Architecture).....	170
Figure 4.43: Close and far shadowing calculation are made possible through 3D modelling of realistic buildings - Sun course for full year is displayed at hourly step time .....	170
Figure 4.44: Albedo effects (reflected irradiance) are generated selecting groups and types of surfaces 20% as a setup for surroundings and 50% for the building itself and other buildings.....	171
Figure 4.45: Layout generation within 3D interface using BIPV BIM objects (from BIMsolar®).....	174
Figure 4.46: East roof for Solrif® modules combination following architect + demo owner requirements. Total 5.2kWp / 62.8 sqm.....	174
Figure 4.47: East roof – Shading losses at module level .....	175
Figure 4.48: East roof – Global results – Array level .....	175
Figure 4.49: West roof for Solrif® modules combination following architect + demo owner requirements. Total 4.8kWp / 62.8 sqm.....	176
Figure 4.50: West roof – Shading losses at module level.....	176
Figure 4.51: East roof – Global results – Array level .....	177
Figure 4.52: SMA SUNNY TRIPOWER 4.0 INVERTER and strings configuration in BIMsolar .....	178
Figure 4.53: disconnection of modules following the demo site manager’s strategy .....	178
Figure 5.1: Satellite view of demosite 4, Latitude 46°7’54’’ Longitude 9°33’64’’ (Source: google earth) .....	187
Figure 5.2: Demo-site 4, Images of the building .....	187
Figure 5.3: Demo-site 4, Building’s image from 1 <sup>st</sup> underground level.....	188
Figure 5.4: Demo-site 4, 3d drawing of the existing building .....	189
Figure 5.5: Demo-site 4, 3d drawing of the existing building .....	189
Figure 5.6: Design option A (best architectural integration).....	190
Figure 5.7: Design option B (maximum power).....	191
Figure 5.8: Cost estimation analysis of Design option A1, A2 and B.....	192
Figure 5.9: Demo-site 4, North-west and north-east facade .....	193
Figure 5.10: Demo-site 4, south-west and south-east facade design.....	193
Figure 5.11: Demo-site 4, 3D design of demo-site building design with and without ePIZ BIPV modules .....	194
Figure 5.12: Cost estimation analysis of Design option A1, A2, B and final design E.....	194
Figure 5.13: Demo site 4, PIZ H 89 cladding system.....	195
Figure 5.14: Demo-site 4, typical wall section before BIPV installation.....	196
Figure 5.15: Demo-site 4, typical wall section after BIPV installation .....	196
Figure 5.16: Demo-site 4, ePIZ prototype with glass-glass PV module (color of the cells is different from the one that will be installed) .....	197
Figure 5.17: Demo-site 4, Aluminum H-profile placed inside the upper horizontal grooves .....	197
Figure 5.18: Demo-site 4, Groove created on the top horizontal edge to provide cable passage .....	198
Figure 5.19: Demo-site 4, Middle safety clamp .....	198
Figure 5.20: Demo-site 4, ePIZ prototypes with glass-glass PV laminate mounted on wall .....	198
Figure 5.23: Demo-site 4, front view of standard ePIZ module A1.....	199
Figure 5.24: Demo-site 4, front view of standard ePIZ module A2.....	199
Figure 5.25: Demo-site4, front view of special ePIZ module B1 .....	199
Figure 5.26: Demo-site 4. front view of standard ePIZ module B2 .....	199
Figure 5.27: Demo-site 4, front view of special ePIZ module C1 .....	199
Figure 5.28: Demo-site 4, front view of special ePIZ module C2 .....	199

Figure 5.29: Demo-site 4, Lateral view of standard ePIZ module .....	200
Figure 5.30: Demo-site 4, design of ONYX PV module, type A1.....	202
Figure 5.31: Demo-site 4, design of ONYX PV module, type A2.....	202
Figure 5.32 Demo-site 4, design of ONYX PV module, type B1.....	204
Figure 5.33 Demo-site 4, design of ONYX PV module, type B2.....	204
Figure 5.34 Demo-site 4, design of ONYX PV module, type C1.....	206
Figure 5.35: Demo-site 4, design of ONYX PV module, type C2.....	206
Figure 5.36: Technical data sheet of inverter Azzurro 1100TL.....	208
Figure 5.37: Electrical diagram for the demo-site installation.....	209
Figure 5.38: Main measuring variables of PIZ demo site. Blue variables are being monitored since the start of preintervention year and the red variables will be monitored afterwards postintervention period.....	211
Figure 5.39: pre-intervention monitoring system meteorological station installed on the roof.....	213
Figure 5.40: Pre-intervention monitoring system meteorological station connections diagram.....	214
Figure 5.41: Monitoring system main board installed in the counter room.....	215
Figure 5.42: Monitoring system main board connections diagrams. ....	215
Figure 5.43: Screen shot of the web datalogger. ....	216
Figure 5.44: Modelling has been made as much realistic as it could be from the existing 2D plans to address BIPV issues (Trimble SketchUp model from PIZ) .....	221
Figure 5.45: Close and far shadowing calculation are made through 3D modelling of realistic buildings - Sun course for full year is displayed at hourly step time – 4 seasons illustration .....	222
Figure 5.46: Close and far shadowing calculation – Specific illustration – DEC 21 <sup>st</sup> – 12:00 .....	223
Figure 5.47: Albedo effects (reflected irradiance) are generated selecting groups and types of surfaces .....	224
Figure 5.48: Building A – 2 rows of 1110x451mm (=102 modules) on South, East, West and North facades + 2 rows 668x451mm (=2 modules) on South-West + 2 rows of 1064x451mm (=2 modules) on North-East facades – Total 4.9kWp / 52.6sqm .....	230
Figure 5.49: Global results building A – All layouts.....	230
Figure 5.50: Shading mapping at module level – Main issue is shading from external beam (south, 70% on 2 modules) .....	231
Figure 5.51: Building B – 2 rows of 1110x451mm (=102 modules) on South, East, West and North facades + 2 rows of 668x451mm (=2 modules) on South-West + 2 rows of 1064x451mm (=2 modules) on North East facades – Total 4.9kWp / 52.6sqm .....	232
Figure 5.52: Global results building B – All layouts.....	232
Figure 5.53: Shading mapping at module level.....	233
Figure 5.54: Building A - 1 inverter on each façade for all the panels (=4 inverters Azzuro-1100-TL), there is 102 module types A1&A2, 2 module types B1&B2 and then 2 C1&C2 .....	234
Figure 5.55: Building B – 1 inverter on each façade for all the panels (=4 inverters Azzuro-1100-TL), there is 102 module types A1&A2, 2 module types B1&B2 and then 2 C1&C2 .....	235
Figure 5.56: Production + shading losses: building A – Monthly analysis.....	236
Figure 5.57: Highlight of mismatching of irradiation between extreme modules.....	250

# 1 EXECUTIVE SUMMARY

## 1.1 DESCRIPTION OF THE DELIVERABLE CONTENT AND PURPOSE

This deliverable is the result of 30 months of work dedicated to the design and simulation of BIPVBOOST solutions to be implemented in four demo-sites in Spain, Belgium and Italy. In October 2019, it was submitted a preliminary version of this deliverable including the Pre-design of all the demo-sites, as a mean of verification of Milestone 1 (MS1) *Pre-design of all demo-sites completed*.

The design of the demo-sites has evolved according to the work performed in the project (development of BIPVBOOST technologies and demo-sites characteristics) to a state of maturity. The design detailed in this deliverable is the executive design for each BIPVBOOST demo-site.

This deliverable highlights the main information for the complete design and implementation of the work to be performed at the demo-sites, with the aim of achieving the optimal conditions for demonstration of viability, performance, reliability and cost-effectiveness of project results.

The current status of demo-site implementations, the different scenarios considered, and the relevant partners that will supply the product, can be found in the following table. Each demo-site currently considers at least two scenarios, one of which has been selected based on the preliminary assessment of the projected impact on the KPIs of the project.

	Demo 1		Demo 2		Demo 3					Demo 4			
Demo manager	ISFOC		MASS		OPTIMAL					PIZ			
Scenario	PRODUCT 1	PRODUCT 2	SCEN. 1 2m panels (var. 38)	SCEN. 2 1m panels	SCEN. 1.1 2 sizes	SCEN. 1.11 2 sizes	SCEN. 1.12 2 sizes	SCEN. 1.2 3 sizes	SCEN. 2 1 size	SCEN. A1 3-phase inverters	SCEN. A2 1-phase inverters	SCEN. B 3 façades	SCEN. E 4 façades, 1-phase inverters
Product	Glass-glass bifacial modules (ONYX)	Glass-glass back contact modules from automated tabber (ONYX)	Glass-glass c-Si modules with different configurations (ONYX). Façade structure (TULIPPS)		CIGS modules (FLISOM). Roof structure (SCHWEIZER)					Multifunctional BIPV element with integrated insulation (ONYX+PIZ)			
Implementation	Balustrades	Walkable floor	Ventilade façade		Roof retrofitting					Opaque cladding			
Orientation	S + E + W	S	SE		E + W					SW+ SE + NW + NE		SW + SE + NW	SW + SE + NW + NE
Surface	126 m <sup>2</sup>	69m <sup>2</sup>	152 m <sup>2</sup>	155 m <sup>2</sup>	150 m <sup>2</sup>					120 m <sup>2</sup>		131 m <sup>2</sup>	110 m <sup>2</sup>
Power	12,8 kWp	9,22 kWp	21,6 kWp	22,2 kWp	10,2 kWp	9,99 kWp (10,38 kWp)	10,26 kWp	9,81 kWp	9,42 kWp	10,2 kWp		10,9 kWp	9,83 kWp
O&M	FDD tool and BEMS for BIPV, HVAC and storage									FDD and BEMS for BIPV and potential flexible demand			

Figure 1.1 Demo-Site design Scenario Chart




Figure 1.2: Location of the four demo-sites: ISFOC, MASS, OPTIMAL and PIZ.

## 1.2 RELATION WITH OTHER ACTIVITIES IN THE PROJECT

This task focuses on the implementation and testing of the KPIs identified within the project within WP 1 and Deliverables D1.1 and D1.2, as well as the monitoring objectives identified within task T8.3. The design of the demo sites is performed on the basis of the pre-audit of the demo-site in T8.1, the BIPV technologies developed in WPs 2 – 4 and using the digital tools developed in WPs 6 and 7. This deliverable will serve as a plan for the implementation phases in Tasks 8.4, 8.5 and 8.6.



## 2 DEMO SITE 1: ISFOC

### 2.1 DEMO-SITE BUILDING DESCRIPTION

This demo-site building corresponds to ISFOC's Headquarter building. ISFOC's Headquarter is located in Puertollano (Ciudad Real) at the centre-south area of Spain.

Location details:

- Address: C/ Francia 7. Polígono Industrial La Nava III. 13500 Puertollano.
- Industrial Area, 5km away from Puertollano city.
- Geographic coordinates (Latitude, Longitude): 38.67, -4.156.



Figure 2.1: ISFOC Headquarter satellite view (Google maps)

ISFOC operates a Concentration Photovoltaic power plant of 800 kW that it is installed at the facilities.



Figure 2.2: ISFOC 800kW CPV power plant

The only energy supply of the building is electrical, reason why ISFOC is interested in PV self-consumption systems.

The building hosts an area of offices and a warehouse including laboratories and mechanical and electrical areas with different purposes. The overall area of the building is of 135m x 14.5m, being the long dimension practically oriented to the south.



Figure 2.3: Drawing of ISFOC building

## 2.2 ARCHITECTURAL BIPV DESIGN

From an architectural point of view and looking for the integration of BIPV solutions, it is important to remark a couple of issues of ISFOC building:

- It has a long façade (135m) oriented to the south with large windows in the office area. But the building includes shadowing eaves for the first and the second floors that allows the entrance of the sunlight through the windows during the winter period to permit the illumination and heating of the interior areas and avoids the entrance during the summer period to prevent the warming and to reduce the air conditioning necessities.
- The rooftop floor is a walkable floor, normally circulated by people, whether employees or visitors.

Taking into account these considerations, it results that the south façade (the windows area) is not appropriate to make a BIPV installation since the area is shaded every day during the central hours and even more during the summer months. But the rooftop seems to be ideal to test **PV balustrades** and **PV walkable floor** in real people circulation conditions.



Figure 2.4: ISFOC building – South façade



### 2.2.1 Existing demo-site building

Currently, the rooftop includes a metal balustrade and a walkable floor based on removable tiles. The approach at this demo site is to replace part of the balustrade and part of the walkable floor with the BIPVBOOST solutions.

- **Balustrades.** The rooftop has a perimeter balustrade for the complete building (floor section: 135m x 14.5m). The current balustrade is only composed of a metallic frame, without glass or similar closure.
- **Walkable floor.** The floor of the rooftop is of removable tiles. The current tiles are of concrete, of 60cm x 40cm.




Figure 2.5: ISFOC building – Rooftop floor

### 2.2.2 Architectural BIPVBOOST design

Initially, in the proposal of the project, the installation of the BIPV solutions at ISFOC building demo site was as follows:


- **Product 1: Glass-glass bifacial modules.**
  - Implementation: Balustrades.
  - Orientation: East, West, South.
  - Surface:  $13.5 + 13.5 + 73 = 100\text{m}^2$ .
  - Installed power:  $\approx 8.7\text{kW}$ .
- **Product 2: Glass-glass back contact modules from automated tabber.**
  - Implementation: Walkable floors.
  - Orientation: South.
  - Surface:  $100\text{m}^2$ .
  - Installed power:  $\approx 14\text{kW}$ .

Once the partners of the project, Viriden, Onyx and Tecnalía, visited the demo site, it was decided, in accordance with all the partners involved that the complete area of the balustrade should be covered by the BIPVBOOST solution, in order to favour the aesthetic of the building and fully integrate the system. Next, the reasoning offered by Viriden is presented.

*The Design of the building and the integration of the BIPV installations has to be handled as a whole. The existing building has a very clear concept and from the point of view of the architects (Viriden) we should*

work towards that concept by integrating BIPV and not just randomly place it somewhere just to achieve the amount of 100m<sup>2</sup>. Due to the presented dimension of the two areas (floor and balustrade) we would recommend focusing on the East, West and South facade to place balustrades. Therefore, we would need to add some of the 100m<sup>2</sup> walkable floor area to the area of the balustrade. To fully add to the architectural quality of the existing building we would highly recommend adding a PV balustrade on all facades. The Demo site installations should present the work and the results of the BIPVBOOST project. It should be seen and it should be obvious. If we just add small parts of PV elements it will not appear as a Demo site for the results of the whole project but rather as a presentation of samples of the producers.

Therefore, the area to be covered by BIPV balustrades (identified in blue in the following picture) is going to be increased and the area of walkable floor (in green) is going to be reduced. The idea is to maintain, as much as possible, the total area and/or power of both BIPVBOOST solutions as a whole in accordance with the original proposal. The following image of Figure 2.6 shows the first proposal of areas to be covered by the solutions.



**Figure 2.6: ISFOC building, areas to cover with the BIPVBOOST solutions**

The first approach is to make the walkable floor based on back-contact solar cells at the center of the rooftop, around the exit to the rooftop from the elevator in order to increase the visibility of the demo installation.

The final design of the BIPVBOOST installation is as follows:

- **Product 1: Glass-glass bifacial modules.**
  - o Implementation: Balustrades.
  - o Orientation: East, West, South.
  - o Surface: 124.58 m<sup>2</sup>.
  - o Installed power: ≈ 12.80 kW.
- **Product 2: Glass-glass back contact modules from automated tabber.**
  - o Implementation: Walkable floor.
  - o Orientation: South.
  - o Surface: 69.12 m<sup>2</sup>.
  - o Installed power: ≈ 9.22 kW.

A first approximation of the estimated costs of implementation of these solutions is detailed below.

Table 2.1: South balustrade - PV glass module data-sheet

		Glass-glass bifacial	Glass-glass back cont
<b>1. Materials</b>		<b>Price [€]</b>	<b>Price [€]</b>
1.1	Fastening and mounting system	4 092.00 €	275.40 €
1.2	BIPV modules	62 269.68 €	48 867.84 €
1.3	Cabling	included in 1.6	
1.4	Inverters	2 708.00 €	2 009.00 €
1.5	Monitoring system	391.33 €	195.67 €
1.6	Electrical installation materials	3 532.67 €	1 766.33 €
1.7	Battery System	to be defined in WP7	
<b>MATERIALS SUBTOTAL</b>		<b>72 993.68 €</b>	<b>53 114.24 €</b>
<b>2. Labor</b>		<b>Price [€]</b>	<b>Price [€]</b>
2.1	Permit obtaining	650.00 €	
2.2	Detailed Executive Project	1 280.00 €	
2.3	Structural and me chanical installation	1 580.00 €	
2.4	Electrical installation	3 816.00 €	
2.5	Certification of the installation	250.00 €	
2.6	Operation and Maintenance (optional)		
<b>LABOR SUBTOTAL</b>		<b>7 576.00 €</b>	<b>0.00 €</b>
<b>TOTAL TURN-KEY INSTALLATION:</b>		<b>80 569.68 €</b>	<b>53 114.24 €</b>

This cost estimation does not include neither the reinforcement of the balustrade nor the manufacture of the custom-made parts for fastening the PV modules since these are specific costs of our installation and are not directly attributable to the integration of PV in buildings. An approximated cost of this actuation could be around 40 000.00€.

## 2.3 BIPV STRUCTURE DESIGN

In this demo site, the existing structure of the building to be analysed for the proper implementation of the BIPVBOOST solutions are the elements of the existing balustrade and its supporting structure and supporting elements of the walkable floor.

### 2.3.1 Existing building structure

The existing elements of the balustrade and the walkable floor have been analysed to define the modifications required in order to make the replacement of the existing elements with the BIPVBOOST solutions.

After the visit of Onyx, ISFOC has contracted a technical consultancy and engineering to analyse the existing elements and their attachment to the structure of the building to ensure a safe and reliable assembly of the BIPVBOOST solutions in the building.

#### 2.3.1.1 ISFOC rooftop balustrades

The existing balustrade of the building, which is surrounding the whole rooftop floor, is shown in Figure 2-7. As it can be observed, the balustrade is built with consecutive elements, being each element an open metallic frame, and the elements are grouped in groups of 6. The total number of elements and their dimensions are different in the south and the west/east balustrades.


- South balustrade.

- 108 elements
- Dimensions: 1230mm x 910mm
- East/West balustrade.
  - 12+12 elements
  - Dimensions: 1200mm x 880mm



**Figure 2.7: ISFOC rooftop balustrade**

The following drawing is a scheme of the measurements of the elements of the balustrade.



**Figure 2.8: Balustrade element**

The frame is made of 50mm wide and 10mm thick metal plate. The frames are crossed by two tensioner threads, as shown in Figure 2.8. The holes (10mm diameter) in the plate for the tensioner threads can be used to mount the modules in the balustrade structure.

The fixing of the balustrade to the building is done through metal plates as shown in Figure 2.9. This mechanical connection has to be analyzed to ensure the safety of the balustrade itself and for the people.



**Figure 2.9: Attachment of the balustrade to ISFOC building**

### 2.3.1.2 ISFOC walkable floor

The floor of the rooftop is a walkable floor of removable concrete tiles Figure 2.10. Each tile is of 600mm x 400mm, of 50mm thickness and weighs around 24kg. The tiles are placed on a system of adjustable plastic plots. Water tightness is guaranteed by the membrane underneath.



**Figure 2.10: ISFOC walkable floor, concrete tiles**

After the visit of the technicians of Onyx it seems that the same support elements used with the current tiles (see the detail in Figure 2.11) can be used to assembly the BIPVBOOST tiles based on back-contact solar cells.



**Figure 2.11: Detail of the supporting elements (plots)**



## 2.3.2 BIPVBOOST structure

ISFOC has subcontracted a third party, a technical consultancy and engineering specialized in building facades, to analyse the integration of the BIPVBOOST solutions in ISFOC building. The analysis is based on the main requirements defined by the Spanish Building regulations (CTE<sup>1</sup>) that should be fulfilled by the BIPVBOOST solutions to be installed, for instance to withstand wind load, to have a proper impact classification, guarantee the fire resistance, service overload...

### 2.3.2.1 ISFOC rooftop balustrades

In the case of the rooftop balustrade, there are two main issues to analyse:

- On the one hand, the effect and forces generated over the balustrade frame and its fixation to the building because of the introduction of the PV modules. The current balustrade is only a metallic frame that does not offer any resistance to the wind, but once the modules are installed, the effect of the wind load over the balustrade itself and its fixation to the building (see Figure 2.9) can be critical. Therefore, it is mandatory to calculate the forces that must be supported by the balustrade because of the wind mainly and also by the type of use according to the CTE.
- On the other hand, the fixing of the PV glass-glass bifacial modules to the frames of the balustrade must be designed according to the CTE requirements also. The holes in the metal plate for the tensioner threads of the balustrade can be used to support the modules.

The conclusion obtained is that the current balustrade and its fixation will not be able to withstand the wind and thrust loads, so it must be reinforced. The reinforcement solution proposed for the South and East/West balustrade is different.

The reinforcement proposed for the South façade is a structure of galvanised steel plate that will be soldered to the existing frame of the balustrade and fixed to the shadowing eaves, as shown in Figure 2.12. This design has been proposed to avoid, as much as possible, intervening in any element of the building that could put at risk the watertightness of the roof, and to avoid problems of dampness in the future.




Figure 2.12: Reinforcement of the south balustrade

<sup>1</sup> CTE – Código técnico de la Edificación (Building technical code)



For the East/West façade, at the end it has been impossible to find a suitable option for the attachment of the reinforcement to the building, so it is going to be anchored to the roof slab of the building, modifying the waterproofing layer of the rooftop inevitably. Currently, the balustrade is fixed with some metal sheets to a brick wall that it is built on top of the roof slab with apparently no mechanical junction between them. The solution proposed is to build some anchoring metallic pieces that will be soldered to some of the balustrade pillars, which will permit the attachment directly to the roof slab, removing an area of brick wall to make this fixation. Then the wall surrounding the new fixations will be rebuilt and the watertightness layer should be laid again. A first drawing of this solution is shown in Figure 2.13.




Figure 2.13: Reinforcement of the east/west balustrade

The installation of the PV modules in the balustrade frame will be done following the scheme of Figure 2.14. They will be installed using 2 longitudinal steel angle profiles that will be attached to the sides of the PV modules and an horizontal plate will be soldered to the larger angle at the lower part to support the weight of the module. To avoid direct contact of metal and glass, all the parts where a contact between the glass of the modules and the steel is foreseen will be protected using plastic spacers or silicone. Then, these steel profiles will be fixed to the frame of the balustrade using the existing holes of the tensioner threads of the current balustrade.




Figure 2.14: Detail of the assembly elements to use for the installation of the PV modules in the balustrade

### 2.3.2.2 ISFOC walkable floor

The walkable floor will be installed using the same support elements that are currently used to support the concrete tiles. Two options have been considered at pre-design stage: the first one considered the use of a metallic sub-frame over the plots where the PV tiles could be attached, as shown in Figure 2.15, in this way the tiles are not supported only in the 4 corners and the forces are distributed. A second option is to install directly the PV tiles on the support elements (plots). by gluing the BIPV modules to the support elements to ensure that the suction of the wind will not be able raise them and generate a contact with another tile, which could lead to the breakage of the modules.

As observed in Figure 2.16, the result of the calculations concludes that the tiles of the walkable floor can withstand the forces generated when they are installed using only the support elements on the 4 corners.




Figure 2.15: Walkable floor. Metallic frame over the plots to mount the PV tiles

The FEM simulation of the walkable floor demonstrates that both stress and deformation levels are within the admissible range when applying a concentrated load of 4 kN. As a consequence, the installation of the BIPV modules will be performed directly over the existing plots. The solution will be in any case validated as per EN 12825, using a 5kN uniform load and 4kN concentrated load over real prototypes.




Figure 2.16: Walkable floor. Forces calculation

Figure 2.16 shows the results of the FEM calculations carried out to the 10T.10T.1, 600mm side, BIPV tiles of the walkable floor when they are supported only on the four corners and applying a concentrated load of 4kN and a uniform load of 5kN/m<sup>2</sup>. The picture of the left shows the result of the stress verification, the stress obtained from the simulation is within the admissible limits of the material, tempered glass. And the picture from the right shows the result of the deformation simulation, where the deformation obtained it is also below the admissible limit of the tempered glass.

## 2.4 BIPV MODULE DESIGN

Two different products of ONYX Solar are going to be tested at ISFOC demo site: a balustrade based on glass-glass bifacial modules and a walkable floor based on back-contact solar cells.

Next, the characteristics of the modules to be installed are described.

### 2.4.1 Balustrades based on glass-glass bifacial modules

As explained in previous sections, the glass-glass bifacial modules will be installed in the balustrades (South, East and West). The modules are going to be assembled into the existing balustrades. It has been also mentioned before that the dimensions of the elements of the balustrade are not the same for the elements of the South and the elements of the East/West.

As a consequence, Onyx Solar has designed two different options taking into account the difference in the dimensions between the elements and the implementation of the PV modules in the inner area of the existing balustrade.




Figure 2.17: PV glass module design for South (left) and West/East (right) balustrades respectively

The design of the PV glass module for the South balustrade is shown in the photo of the left of Figure 2.17 and its characteristics are collected in its data-sheet shown in Table 2.2.

The design of the PV glass module for the East and West balustrades is shown in the photo of the right of Figure 2.17 and its characteristics are collected in its data-sheet shown in Table 2.3.



Table 2.2: South balustrade - PV glass module data-sheet

<b>PHOTOVOLTAIC GLASS</b>		<b>1.180 x 810</b>	
<b>FRONT SIDE</b>		<b>6" Mono</b>	<b>Crystalline Bifacial</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	97,2	$P_{mpp}$ (Wp)	
Open-circuit voltage	15,94	$V_{oc}$ (V)	
Short-circuit current	8,07	$I_{sc}$ (A)	
Voltage at nominal power	12,59	$V_{mpp}$ (V)	
Current at nominal power	7,72	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	1180	mm	
Width	810	mm	
Thickness	21,8	mm	
Surface area	0,96	sqm	
Weight	48	Kgs	
Cell type	6" Mono	Crystalline bifacial	
No PV cells / Transparency degree	24	42%	
Front Glass	10 mm	Tempered Glass Low-Iron	
Rear Glass	10 mm	Tempered Glass Low-Iron	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of P <sub>mp</sub>	-0,451	%/°C	
Temperature Coefficient of V <sub>oc</sub>	-0,361	%/°C	
Temperature Coefficient of I <sub>sc</sub>	+0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	47%
U-value [W/sqm.K]	5,2
Peak Power [Wp/sqm]	97,8

Table 2.3: East and West balustrades - PV glass module data-sheet

<b>PHOTOVOLTAIC GLASS</b>		<b>1.150 x 810</b>	
<b>FRONT SIDE</b>		<b>6" Mono</b>	<b>Crystalline Bifacial</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	95,90	$P_{mpp}$ (Wp)	
Open-circuit voltage	15,93	$V_{oc}$ (V)	
Short-circuit current	7,88	$I_{sc}$ (A)	
Voltage at nominal power	12,47	$V_{mpp}$ (V)	
Current at nominal power	7,68	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	1150	mm	
Width	810	mm	
Thickness	21,8	mm	
Surface area	0,93	sqm	
Weight	47	Kgs	
Cell type	6" Mono	Crystalline bifacial	
No PV cells / Transparency degree	24	41%	
Front Glass	10 mm	Tempered Glass Low-Iron	
Rear Glass	10 mm	Tempered Glass Low-Iron	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of $P_{mpp}$	-0,451	%/°C	
Temperature Coefficient of $V_{oc}$	-0,361	%/°C	
Temperature Coefficient of $I_{sc}$	+0,08	%/°C	


\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	<b>42%</b>
U-value [W/sqm.K]	<b>5,2</b>
Peak Power [Wp/sqm]	<b>107,7</b>




The aim of Onyx with this design is to maintain the same aesthetics, as much as possible, in all the orientations by using the same number of cells and the same disposition of these cells in the glass respect to its centre.

For the two types of PV modules for the balustrades the glass configuration is as shown in Figure 2.18.



**Figure 2.18: Glass configuration of the PV glass module design for the balustrades**

All this work has been developed following the previous steps linked to WP3 (Task 3.3: Low cost, large thickness glass-glass bifacial cell modules for integration in balustrades), with the design and manufacturing of the small modules.




**Figure 2.19: Small module design. Front and back side of the manufactured bifacial module**

## 2.4.2 Walkable floor based on back-contact solar cells


As explained in previous sections, the back-contact solar cells modules are going to be installed as a walkable floor in the rooftop of the building by the replacement of some of the tiles of the floor.

Onyx has designed the PV tiles based on the work developed in WP3, Task 3.4: Back-contact cells modules for walkable floors and curtain walls, as it is shown in Figure 2.20.



**Figure 2.20: Front side of the PV tile manufactured: 8mm anti-slip / back-contact / 8mm glass**

In this case, Onyx Solar has designed different solutions based on the glass size, number of cells and distribution of the cells. The three options proposed are shown in Figure 2.21 and the characteristic parameters of each of them are collected in their data-sheets from Table 2.4 to Table 2.6



**Figure 2.21: PV designs for the walkable floor**

Table 2.4: 750 x 750 (25 cells) walkable floor tile data-sheet

<b>PHOTOVOLTAIC GLASS</b>		<b>750 x 750</b>	
		<b>5" Mono</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power		75	$P_{mpp}$ (Wp)
Open-circuit voltage		17	$V_{oc}$ (V)
Short-circuit current		5,71	$I_{sc}$ (A)
Voltage at nominal power		14	$V_{mpp}$ (V)
Current at nominal power		5,28	$I_{mpp}$ (A)
Power tolerance not to exceed		±10	%
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length		750	mm
Width		750	mm
Thickness		17,8	mm
Surface area		0,56	sqm
Weight		23	Kgs
Cell type		5" Mono	Back Contact Cells
No PV cells / Transparency degree		25	0%
Front Glass		8 mm	Tempered Glass Anti-slip
Rear Glass		8 mm	Tempered Glass
Thickness encapsulation		1,80 mm	EVA Foils
Category / Color code			
<b>Junction Box</b>			
Protection		IP65	
Wiring Section		2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>	
<b>Limits</b>			
Maximum system voltage		1000	$V_{sys}$ (V)
Operating module temperature		-40...+85	°C
<b>Temperature Coefficients</b>			
Temperature Coefficient of $P_{mpp}$		-0,451	%/°C
Temperature Coefficient of $V_{oc}$		-0,361	%/°C
Temperature Coefficient of $I_{sc}$		+0,08	%/°C

\* All technical specifications are subject to change without notice by Onyx Solar

NOTE: Anti-slippery glass induce a 5% of power loss. It has been considered in this data sheet.

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
<b>Light Transmission</b>	<b>0%</b>
<b>U-value [W/sqm.K]</b>	<b>5,3</b>
<b>Peak Power [Wp/sqm]</b>	<b>133,8</b>

Table 2.5: 750 x 750 (16 cells) walkable floor tile data-sheet

<b>PHOTOVOLTAIC GLASS</b>		<b>750 x 750</b>	
		<b>5" Mono</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power		48	$P_{mpp}$ (Wp)
Open-circuit voltage		11	$V_{oc}$ (V)
Short-circuit current		5,71	$I_{sc}$ (A)
Voltage at nominal power		9	$V_{mpp}$ (V)
Current at nominal power		5,28	$I_{mpp}$ (A)
Power tolerance not to exceed		$\pm 10$	%
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length		750	mm
Width		750	mm
Thickness		17,8	mm
Surface area		0,56	sqm
Weight		23	Kgs
Cell type		5" Mono	Back Contact Cells
No PV cells / Transparency degree		16	0%
Front Glass		8 mm	Tempered Glass Anti-slip
Rear Glass		8 mm	Tempered Glass
Thickness encapsulation		1,80 mm	EVA Foils
Category / Color code			
<b>Junction Box</b>			
Protection		IP65	
Wiring Section		2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>	
<b>Limits</b>			
Maximum system voltage		1000	$V_{sys}$ (V)
Operating module temperature		-40...+85	°C
<b>Temperature Coefficients</b>			
Temperature Coefficient of Pmpp		-0,451	%/°C
Temperature Coefficient of Voc		-0,361	%/°C
Temperature Coefficient of Isc		+0,08	%/°C

\* All technical specifications are subject to change without notice by Onyx Solar

NOTE: Anti-slippery glass induce a 5% of power loss. It has been considered in this data sheet.

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
<b>Light Transmission</b>	<b>0%</b>
<b>U-value [W/sqm.K]</b>	<b>5,3</b>
<b>Peak Power [Wp/sqm]</b>	<b>85,7</b>

Table 2.6: 600 x 600 (16 cells) walkable floor tile data-sheet

<b>PHOTOVOLTAIC GLASS</b>		
	<b>600 x 600</b>	
	<b>5" Mono</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>		
Nominal peak power	48	$P_{mpp}$ (Wp)
Open-circuit voltage	11	$V_{oc}$ (V)
Short-circuit current	5,71	$I_{sc}$ (A)
Voltage at nominal power	9	$V_{mpp}$ (V)
Current at nominal power	5,28	$I_{mpp}$ (A)
Power tolerance not to exceed	±10	%
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.		
<b>Mechanical description</b>		
Length	600	mm
Width	600	mm
Thickness	17,8	mm
Surface area	0,36	sqm
Weight	14	Kgs
Cell type	5" Mono	Back Contact Cells
No PV cells / Transparency degree	16	0%
Front Glass	8 mm	Tempered Glass Anti-slip
Rear Glass	8 mm	Tempered Glass
Thickness encapsulation	1,80 mm	EVA Foils
Category / Color code		
<b>Junction Box</b>		
Protection	IP65	
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>	
<b>Limits</b>		
Maximum system voltage	1000	$V_{sys}$ (V)
Operating module temperature	-40...+85	°C
<b>Temperature Coefficients</b>		
Temperature Coefficient of $P_{mpp}$	-0,451	%/°C
Temperature Coefficient of $V_{oc}$	-0,361	%/°C
Temperature Coefficient of $I_{sc}$	+0,08	%/°C

\* All technical specifications are subject to change without notice by Onyx Solar

NOTE: Anti-slippery glass induce a 5% of power loss. It has been considered in this data sheet.

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
<b>Light Transmission</b>	<b>0%</b>
<b>U-value [W/sqm.K]</b>	<b>5,3</b>
<b>Peak Power [Wp/sqm]</b>	<b>133,8</b>



For the three types of PV glass tiles of the walkable floor the glass configuration will be as shown in Figure 2.22.




Figure 2.22: Glass configuration of the PV glass tile design for the walkable floor

### 2.4.3 BIPVBOOST modules electrical design

As it has been indicated in Section 2.2.2, the total area to demonstrate the BIPVBOOST balustrades is going to be increased, so that the entire balustrades of the East, South and West façades are replaced by the glass-glass bifacial module balustrades. With the modules presented by Onyx in Section 2.4.1 and 2.4.2, the premises of maintaining a total power (22.7kW) or a total area (200m<sup>2</sup>) like in the original proposal and taking into account all the technical (electrical) and aesthetical characteristics of the building, the definitive distribution of power between the balustrades and the floor can be calculated as well as the number of modules to install. ISFOC has selected the 600x600mm tiles, as shown in Table 2.7, where the main characteristics of the installation are summarized:

Table 2.7: ISFOC demo installation characteristics

<b>BIPVBOOST INSTALLATION AT ISFOC</b>			
<b>BALUSTRADE</b>			
Power	12.80 kWp		
Area	125.58 m <sup>2</sup>		
<b>Balustrade</b>	<b>South</b>	<b>East</b>	<b>West</b>
Modules Nº	108	12	12
Total	132		
Area	103.23 m <sup>2</sup>	11.18 m <sup>2</sup>	11.18 m <sup>2</sup>
	<b>125.58 m<sup>2</sup></b>		
Power	10.50 kWp	1.15 kWp	1.15 kWp
	<b>12.80 kWp</b>		
<b>WALKABLE FLOOR</b>			
	<b>Option 3</b>		
Dimensions	600x600mm <sup>2</sup>		
Tiles Nº	192		
Power	<b>9.22 kWp</b>		
Area	<b>69.12 m<sup>2</sup></b>		
<b>TOTAL</b>			
Total Power	<b>22.02 kWp</b>		
Total Area	<b>194.70 m<sup>2</sup></b>		

The total numbers of the installation are very similar to the initial ones included in the proposal, 22kWp in 195m<sup>2</sup>.

- The power of the balustrades based on glass-glass bifacial modules to install at ISFOC is increased to 12.80kWp in 126m<sup>2</sup> instead of 8.7kWp in 100m<sup>2</sup>.
- The power of the walkable floor based on back-contact solar cells to install at ISFOC is reduced to 9.22kWp in 69m<sup>2</sup> instead of 14kWp in 100m<sup>2</sup>.

In this way the entire East, West and South facades will be converted into PV balustrades.

The first approach for the installation of the PV floor is as shown in Figure 2.23, a rectangular area, in the South section of the floor, at the exit of the elevator.




Figure 2.23: Walkable floor based on back-contact solar cells. ISFOC rooftop design

## 2.5 BIPV ELECTRICAL SYSTEM DESIGN

Next, the design of the electrical installation of the BIPV installation is presented.

In a first approach, the installation at ISFOC demo site is going to include a battery component in order to manage the energy generation and the building demand, (analysed in WP7). It is going to be an installation without excess energy, which means that it will not inject electricity to the distribution grid.

The PV installation is composed by the different modules provided by ONYX SOLAR divided in three PV generators:

- **PV GENERATOR 1: East and west balustrades.** These two strings of 12 modules will be connected to one PV inverter. Each string will be connected to one MPPT of the HUAWEI SUN2000L-2KTL inverter, it is a one-phase inverter. The modules of each string will be connected all in series.
- **PV GENERATOR 2: South balustrade.** These are all the modules installed in the south façade. They will be connected in two serial strings of 96 modules, each one connected to one MPPT of the HUAWEI SUN2000-10KTL-M1 inverter, it is a three-phases inverter. Additionally, the Li-on battery pack will be connected to this inverter.
- **PV GENERATOR 3 Walkable Floor.** These modules will be connected in four serial strings of 48 modules. This generator will use a HUAWEI SUN2000L-8KTL-M1 inverter with two MPPT, connecting two strings in parallel to each MPPT. It is also a three-phase inverter.

All the components of the electrical installation are shown in Figure 2.24.




Figure 2.24: BIPVBOOST ISFOC demonstration – Electrical installation

The installation includes a net metering, Janitza UMG 604-PRO, to measure the total power consumption of the building and an energy logger, HUAWEI SmartLogger 3000A, to make the smart zero export control to avoid the electricity injection to the grid.

## 2.5.1 BIPVBOOST system components

Next, a brief description of the different components of the installation is presented. Different energy meters will be installed where needed to make the detailed monitoring of the installation (as presented in section 2.6).

### 2.5.1.1 Photovoltaic inverters

Following, the inverters to use in the different PV generators are presented:

- PV GENERATOR 1.** The east and west balustrades will be connected to the inverter **HUAWEI SUN2000-2KTL**. The inverter is shown in Figure 2.25 and its efficiency curve and circuit diagram are shown in Figure 2.26.



Figure 2.25: Photovoltaic inverter HUAWEI SUN2000-2KTL-L1




Figure 2.26: Efficiency curve and circuit diagram - HUAWEI SUN2000-2KTL inverter

- PV GENERATOR 2.** The south balustrade South will be connected to the inverter **HUAWEI SUN2000-10KTL-M1**. The inverter is shown in Figure 2.27 and its efficiency curve and circuit diagram are shown in Figure 2.28.



Figure 2.27: Photovoltaic inverter HUAWEI SUN2000-10KTL-M1




Figure 2.28: Efficiency curve and circuit diagram - HUAWEI SUN2000-10KTL-M0 inverter

- PV GENERATOR 3.** The walkable floor is composed of 192 modules. In this case, the modules will be grouped in four strings of 48 modules connected in series and the strings will be connected in parallel two by two. The two resulting strings will be connected then to each MPPT of the **HUAWEI SUN2000L-8KTL-M1**. The inverter is shown in Figure 2.27 and its efficiency curve and circuit diagram are shown in Figure 2.28.

### 2.5.1.2 Li-ion batteries.

For the storage of the generator there are two possibilities, there are two different Li-ion batteries compatible with the HUAWEI inverters; LG CHEM and HUAWEI. But, trying to avoid any issues related with the compatibility of the components, the batteries to be installed will be **HUAWEI LUNA2000-10-S0** of 10kWh. The battery pack will be managed by the inverter of the PV GENERATOR 2. The battery pack is shown in Figure 2.29 and its main characteristics are collected in Table 2.8.



Figure 2.29: Li-ion batteries pack HUAWEI Luna 2000-10-S0

Table 2.8: Main characteristics - HUAWEI Luna 2000-10-S0 storage

		Performance		
Power module		LUNA2000-5KW-C0		
Number of power modules		1		
Battery module		LUNA2000-5-E0		
Battery module energy		5 kWh		
Number of battery Modules	1	2	3	
Battery usable energy <sup>1</sup>	5 kWh	10 kWh	15 kWh	
Max. output power	2.5 kW	5 kW	5 kW	
Peak output power	3.5 kW, 10 s	7 kW, 10 s	7 kW, 10 s	
Nominal voltage (single phase system)		450 V		
Operating voltage range (single phase system)		350 – 560 V		
Nominal voltage (three phase system)		600 V		
Operating voltage range (three phase system)		600 – 980 V		



### 2.5.1.3 Smart zero export control unit.

As it has been said before, the demonstrator at ISFOC is going to be a PV generation installation without surplus, which means that it will not inject electricity to the distribution grid. The smart zero export control is carried out by the **HUAWEI SmartLogger 3000A**, equipment that must be verified by the distribution company. The total power consumption of the building is measured by a **Janitza UMG 604-PRO** (see section 2.6) equipment, which sends data to the SmartLogger. The SmartLogger unit is shown in Figure 2.30 and its main characteristics are collected in Figure 2.28



Figure 2.30: Smart zero export control - HUAWEI SmartLogger 3000A

Table 2.9: Main characteristics - HUAWEI SmartLogger 3000A

Technical Specification	SmartLogger3000A03EU	SmartLogger3000A01EU
<b>Device Management</b>		
Max. Number of Connected Devices	80	
<b>Communication Interface</b>		
WAN	WAN x 1, 10 / 100 / 1000 Mbps	
LAN	LAN x 1, 10 / 100 / 1000 Mbps	
RS485	COM x 3, 1200 / 2400 / 4800 / 9600 / 19200 / 115200 bps, 1000 m	
MBUS	MBUS x 1, 115.2 kbps, Compatible with PLC	No MBUS Communication Interface
2G / 3G / 4G <sup>1</sup>	LTE(FDD) : B1,B2,B3,B4,B5,B7,B8,B20 DC-HSPA+/HSPA+/HSPA/UMTS : 850/900/1900/2100 MHz GSM/GPRS/EDGE: 850/900/1800/1900 MHz <sup>2</sup>	
Digital / Analog Input / Output	DI x 4, DO x 2, AI x 4	
Active DO	12V, 100mA (connection with relay, sensor)	
<b>Communication Protocol</b>		
Ethernet	Modbus-TCP, IEC 60870-5-104	
RS485	Modbus-RTU, IEC 60870-5-103 (standard), DL / T645	

## 2.5.2 BIPVBOOST electrical diagram

The basic electrical diagram of the installation is shown in Figure 2.24. The PV installation is organized in smaller PV generators, so that each different orientation is connected independently to one MPPT.

- One inverter HUAWEI SUN2000-2KTL for West and East balustrade:
  - 1 MPPT for East Balustrade.
  - 1 MPPT for West Balustrade.
- One inverter HUAWEI SUN2000-10KTL-M1 for South Balustrade
  - 1 MPPT for a half of the south balustrade
  - 1 MPPT for a half of the south balustrade
- One inverter HUAWEI SUN2000-8KTL-M1 for Walkable Floor
  - 1 MPPT for a parallel association of 2 strings of PV tiles connected in series. Half of the walkable floor.

- 1 MPPT for a parallel association of 2 strings of PV tiles connected in series. Half of the walkable floor.

The installation will be connected to the grid but without surpluses and up to now it is going to include some batteries for storage purposes. The first approach is to have a storage capacity of 10kWh using the Li-ion HUAWEI LUNA2000-10-S0 connected to the SUN2000-10KTL inverter of the south balustrade.

The controllable loads at ISFOC, which are also included in the BIPVBOOST project, are the air conditioning system and the lightning.

Next, the wiring of the electrical installation is presented. Figure 2.31 shows the single-line diagram of the installation, where the type, length and sections of the cables can be observed. All the calculations are presented in Table 2.10.

- The DC wires will have a section of 25mm<sup>2</sup> for the west string of generator 1 and of 10mm<sup>2</sup> for the east string of generator 1, for the rest of generators it will be of 4mm<sup>2</sup>.
- The AC wires from the inverters to the interconnection point will have a section of 4mm<sup>2</sup> and of 70mm<sup>2</sup> from the interconnection point to the connection to the grid point.

The length of each cable is indicated in the diagram, being the longest for the east/west balustrade since the inverters will be located in one of the rooftop cabinets of the centre.

**Table 2.10: BIPVBOOST – ISFOC installation. Wiring calculations**

Cálculo Cableados CC									
Dimensionamiento por caída de tensión									
	Longitud [m]	Potencia [W]	Intensidad Isc [A]	Tensión [V]	Caída tensión [V] 1%	Coficiente [Cu]	Sección [mm <sup>2</sup> ]	Sección mínima [mm <sup>2</sup> ]	Sección [mm <sup>2</sup> ]
Rama 1 Serie 1 - Oeste	129	1.224	8,67	180	1,80	56	22,19	25	25
Rama 2 Serie 2 - Este	53	1.224	8,67	180	1,80	56	9,03	10	10
Rama 3 Serie 3 - Sur 1	86	5.832	8,67	810	8,10	56	3,27	1,5	4
Rama 4 Serie 4 - Sur 2	49	5.832	8,67	810	8,10	56	1,87	2,5	4
Rama 5 Serie 5 - Suelo 1	45	2.304	8,67	720	7,20	56	1,94	2,5	4
Rama 6 Serie 6 - Suelo 2	57	2.304	8,67	720	7,20	56	2,46	2,5	4
Rama 7 Serie 7 - Suelo 3	48	2.304	8,67	720	7,20	56	2,04	2,5	4
Rama 8 Serie 8 - Suelo 4	60	2.304	8,67	720	7,20	56	2,56	4	4
Dimensionamiento por intensidad máxima admisible									
	Tipo instalación	Potencia [W]	Intensidad Isc [A]	Tensión [V]	Tipo conductores	Factor reducción	Sección [mm <sup>2</sup> ]	Imáx sección [A]	Sección [mm <sup>2</sup> ]
Rama 1 Serie 1 - Oeste	B2	1.224	8,67	180	2PVC -Cu	1	25	84	25
Rama 2 Serie 2 - Este	B2	1.224	8,67	180	2PVC -Cu	1	10	50	10
Rama 3 Serie 3 - Sur 1	B2	5.832	8,67	810	2PVC -Cu	1	4	27	4
Rama 4 Serie 4 - Sur 2	B2	5.832	8,67	810	2PVC -Cu	1	4	27	4
Rama 5 Serie 5 - Suelo 1	B2	2.304	8,67	720	2PVC -Cu	1	4	27	4
Rama 6 Serie 6 - Suelo 2	B2	2.304	8,67	720	2PVC -Cu	1	4	27	4
Rama 7 Serie 7 - Suelo 3	B2	2.304	8,67	720	2PVC -Cu	1	4	27	4
Rama 8 Serie 8 - Suelo 4	B2	2.304	8,67	720	2PVC -Cu	1	4	27	4
Cálculo Cableados CA									
Dimensionamiento por caída de tensión									
	Longitud [m]	Potencia [W]	Intensidad Isc [A]	Tensión [V]	Caída tensión [V] 0,5%	Coficiente [Cu]	Sección [mm <sup>2</sup> ]	Sección mínima [mm <sup>2</sup> ]	Sección [mm <sup>2</sup> ]
Inv1 Inv1-CAG	5	2.000	8,70	230,00	1,15	56	1,35	1,5	4
Inv2 Inv2-CAG	5	10.000	14,43	400,00	2,00	56	1,12	1,5	4
Inv3 Inv3-CAG	5	8.000	11,55	400,00	2,00	56	0,89	1,5	4
CAG CAG-PCC	130	20.000	28,87	400,00	2,00	56	58,04	70	70
Dimensionamiento por intensidad máxima admisible									
	Tipo instalación	Potencia [W]	Tensión [V]	Intensidad [A]	Tipo conductores	Factor reducción	Sección [mm <sup>2</sup> ]	Imáx sección [A]	Sección [mm <sup>2</sup> ]
Inv1 Inv1-CAG	B2	2.000	230	8,70	2XLPE - Cu	1	4	27	4
Inv2 Inv2-CAG	B2	10.000	400	14,43	3XLPE - Cu	1	4	27	4
Inv3 Inv3-CAG	B2	8.000	400	11,55	3XLPE - Cu	1	4	27	4
CAG CAG-PCC	A2	20.000	400	28,87	3XLPE - Cu	1	70	149	70




Figure 2.31: BIPVBOOST – ISFOC installation single-line diagram

## 2.6 BIPV MONITORING DESIGN

### 2.6.1 Definition of monitoring objectives: BIPV performance validation, economic viability and progress towards NZEB requirements

The main objective of the monitoring system is to verify and validate the Energy performance of the BIPVBOOST project developments implementations through the measurement of key variables. The measurement methodology and key variables to be measured were defined in deliverable 8.3. The monitoring methodology described in deliverable 8.3 is base in the inter-comparison of two monitoring periods, defined as the pre-intervention period (base line) and the post intervention period.

The implementation of pre-intervention period monitoring system has been finished in June 2020 and measurements are being gathered since august 2020. The post-intervention monitoring system will be implemented after the intervention described in this document in September 2021.

Next the pre-intervention period monitoring system is presented and later this document will be updated which the implementation of e post-intervention monitoring system.

### 2.6.2 Definition of variables to be monitored

The monitoring objectives will be reached through the measurement of the energy variables shown in Figure 2.32. Table 2.11 shows a short definition of the variables shown in Figure 2.32 and additional information about instruments used for the measurements. The variables monitored during pre-intervention period are written in blue and, during the post-intervention period, variables written in red will be also measured.

As it can be seen, during the pre-intervention period, the monitored variables are related with meteorology and building consumption and during the post intervention period the energy production of BIPV modules will be also measured.




Figure 2.32: Main measuring variables of Puertollano demo site. Blue variables will be monitored since the pre-intervention year and the red variables will be monitored from the postintervention onwards

Table 2.11: Description of the variables shown in Figure 2.32 and the instruments used for the measurements

<u>Variable</u>	<u>Description</u>	<u>instrument</u>	<u>Range</u>	<u>Units</u>	<u>Time Resolution</u>	<u>Accuracy</u>
<b>BIPV components</b>						
<b>Balustrades east</b>						
<b>Meteo</b>	-					
$G_{i_{east\_1}}$	<i>Irradiance East plane</i>	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
$G_{i_{west\_1}}$	<i>Irradiance West plane</i>	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
$T_{m_{b\_east}}$	<i>Module temperature</i>	Thermocouple type T	0-100	°C	<1min	1K
<b>DC</b>	-					
$I_{b\_east}$	DC Intensity	Amperimeter		A	<1min	1% of the reading
$V_{b\_east}$	DC Voltage	Voltimeter		V	<1min	1% of the reading
$P_{b\_east}$	DC Power	Power meter	1,2	Kw	<1min	2% of the reading
$ET_{b\_east}$	DC Energy	Energy meter		Kw/h	<1min	
<b>AC</b>	-					
$P_{b\_east\_l}$	AC Power	Power meter	1,2	Kw	<1min	2% of the reading
$ET_{b\_east\_l}$	AC Energy	Energy meter		Kw/h	<1min	
<b>Balustrades West</b>						
<b>Meteo</b>	-					
$G_{i_{east\_2}}$	<i>Irradiance East plane</i>	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
$G_{i_{west\_2}}$	<i>Irradiance West plane</i>	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
$T_{m_{b\_west}}$	<i>Module temperature</i>	Thermocouple type T		°C	<1min	1K
<b>DC</b>	-					
$I_{b\_west}$	DC Intensity	Amperimeter		A	<1min	1% of the reading
$V_{b\_west}$	DC Voltage	Voltimeter		V	<1min	1% of the reading
$P_{b\_west}$	DC Power	Power meter	1,2	Kw	<1min	2% of the reading
$ET_{b\_west}$	DC Energy	Energy meter		Kw/h	<1min	
<b>AC</b>	-					
$P_{b\_west\_l}$	AC Power	Power meter	1,2	Kw	<1min	2% of the reading
$ET_{b\_west\_l}$	AC Energy	Energy meter		Kw/h	<1min	
<b>Balustrades South</b>						
<b>Meteo</b>	-					
$G_{i_{south}}$	<i>Irradiance south plane</i>	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
$G_{i_{north}}$	<i>Irradiance North plane</i>	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
$T_{m_{b\_south}}$	<i>Module temperature</i>	Thermocouple type T		°C	<1min	1K
<b>DC</b>	-					
$I_{b\_south}$	DC Intensity	Amperimeter		A	<1min	1% of the reading
$V_{b\_south}$	DC Voltage	Voltimeter		V	<1min	1% of the reading
$P_{b\_south}$	DC Power	Power meter	6,4	Kw	<1min	2% of the reading
$ET_{b\_south}$	DC Energy	Energy meter		Kw/h	<1min	
<b>AC</b>	-					
$P_{b\_south\_l}$	AC Power	Power meter	6,4	Kw	<1min	2% of the reading
$ET_{b\_south\_l}$	AC Energy	Energy meter		Kw/h	<1min	
<b>Walkable Flor</b>						
<b>Meteo</b>	-					




<b>Variable</b>	<b>Description</b>	<b>instrument</b>	<b>Range</b>	<b>Units</b>	<b>Time Resolution</b>	<b>Accuracy</b>
$G_{i_w}$	<i>Irradiance azimuth</i>	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
$T_{m_w}$	<i>Module temperature</i>	Thermocouple type T	0-100	°C	<1min	1K
<b>DC</b>						
$I_w$	DC Intensity	Amperimeter		A	<1min	1% of the reading
$V_w$	DC Voltage	Voltimeter		V	<1min	1% of the reading
$P_w$	DC Power	Power meter	14	Kw	<1min	2% of the reading
$ET_w$	DC Energy	Energy meter		Kw/h	<1min	
<b>AC</b>						
$P_{w\_l}$	AC Power	Power meter	14	Kw	<1min	2% of the reading
$ET_{w\_l}$	AC Energy	Energy meter		Kw/h	<1min	
<b>Storage</b>						
<b>Input</b>	-					
$I_{st\_in}$	Intensity	Amperimeter		A	<1min	
$V_{st\_in}$	Voltage	Voltimeter		V	<1min	1% of the reading
$P_{st\_in}$	Power	Power meter	89	Kw	<1min	2% of the reading
$ET_{st\_in}$	Energy	Energy meter		Kw/h	<1min	
<b>Output</b>	-					
$I_{st\_out}$	Intensity	Amperimeter		A	<1min	1% of the reading
$V_{st\_out}$	Voltage	Voltimeter		V	<1min	1% of the reading
$P_{st\_out}$	Power	Power meter		Kw	<1min	2% of the reading
$ET_{st\_out}$	Energy	Energy meter		Kw/h	<1min	
<b>Building</b>						
<b>HVAC</b>						
$I_{hvac}$	Intensity	Amperimeter		A	<1min	1% of the reading
$V_{hvac}$	Voltage	Voltimeter		V	<1min	1% of the reading
$P_{hvac}$	Power	Power meter		Kw	<1min	2% of the reading
<b>Existing PV field</b>						
<b>DC</b>	-					
$I_{pv}$	DC Intensity	Amperimeter		A	<1min	1% of the reading
$V_{pv}$	DC Voltage	Voltimeter		V	<1min	1% of the reading
$P_{pv}$	DC Power	Power meter	89	Kw	<1min	2% of the reading
$ET_{pv}$	DC Energy	Energy meter		kW/h	<1min	
<b>AC</b>	-					
$P_{pv\_l}$	AC Power	Power meter	89	kW	<1min	
$Et_{pv\_l}$	AC Energy	Energy meter		kW/h	<1min	
<b>Grid</b>						
$P_{gr}$	Power	Power meter		kW	<1min	
$ET_{pv\_l}$	Energy	Energy meter		kW/h	<1min	

### 2.6.3 Existing monitoring system

ISFOC has already a monitoring system in its building in charge of measuring the energy consumption of the building, complete, and also some circuits independently. The purpose of this monitoring was different so only some of the measurements will be taken into account and it will be completed with additional components.

The different energy circuits monitored are shown in Table 2.12.

**Table 2.12: List of the pre-existing monitoring equipment at ISFOC**



ELECTRIC METER	Short explanation about the loads being measured by the specified electric meter or similar device	ACCES TO THIS DATA? Y/N
1	Total energy consumption of ISFOC headquarter	YES
2	"Red IRIS" server and ISFOC servers consumption.	YES
3	Urbanization (exterior lights, irrigation, door...)	YES
4	Climatic chambers laboratory consumption	YES
5	Power consumptions to be protected by a UPS (not installed) for workers computers	YES
6	Office lights	YES
7	General Power consumptions	YES
8	HVAC system unit 2	YES
9	Kitchen	YES
10	HVAC system unit 1	YES
11	Solar Simulator laboratory	YES
12	Third company (offices and workshops) consumption. Offices	YES
13	Third company (offices and workshops) consumption. Workshops power	YES
14	Third company (offices and workshops) consumption. Workshops lights	YES

**OBSERVATIONS**

The numbers of the meters are also marked as comments in the document "Esquema\_Unifilar\_ISFOC\_Num.pdf"  
 the electric meter 1 is the utility grid energy meter. We access to the data and we store it. You can have access to this data stored but not to the instantaneous value  
 the electric meters from 2 to 14 are grid analyzers. The data of all of them are stored in a DB where you can access or we can generate the file you need. I think it is not possible to have access to instantaneous value neither.



Figure 2.33: Pre-existing monitoring equipment at ISFOC

#### 2.6.4 BIPVBOOST monitoring system

As mentioned, the installation of the pre-intervention monitoring system was finished in June (2020) and data are being gathered since August (2020). This monitoring system will be updated after the BIPVBOOST intervention in the demo site and the results will be reported later.

##### Pre-intervention monitoring system.

In order to measure all the key variables, it has been used the already installed instruments of the ISFOC pre-existing monitoring system and additional variables have been measured with a complementary monitoring system installed within the frame of BIPVBOOST project.

Figure 2.34 shows the variables measured by the pre-existing monitoring system (Highlighted in yellow) and the variable measured with the monitoring system installed during the BIPVBOOST project framework (Highlighted in GREEN).

As it can be seen, the BIPVBOOST monitoring system is measuring the meteorological (irradiance in the module plane, Ambient temperature and wind direction) data and the pre-existing monitoring system in ISFOC is measuring the energy consumption of the building and its temperature.




Figure 2.34: Main measuring variables of Puertollano demo site.

Blue variables will be monitored since the pre intervention year and the red variables will be monitored from the post intervention onwards. Green variables are already being monitored

The meteorological instruments have been installed on the roof. The Figure 2.35: shows the layout and some detailed photo of the finished installation. The ambient temperature ( $T_{atm}$ ) is being measured by the PT100; the East ( $Gi_{b\_east}$ ), West ( $Gi_{b\_west}$ ), North ( $Gi_{b\_north}$ ), South ( $Gi_{b\_south}$ ) and azimuthal plane ( $Gi_w$ ) Irradiance is being measured at certain height to avoid the albedo effect and additionally at low height (near the ground) to evaluate the albedo effect with a cube formed by reference cells;  $Gi$  with a pyranometer and wind direction with an anemometer.




Figure 2.36: Layout of pre intervention monitoring system at Puertollano demo site

The data measured by the instruments are sent to the data logger via Modbus communication. Figure 2.37 shows all the connections between the instruments and the datalogger.




Figure 2.37: Detailed schema of the installed monitoring system connections

### Data collection



On the one hand the gathered data are sent to TECNALIA via internet by a modem integrated in the monitoring system. On the other hand, the data gathered by the pre-existing monitoring system in ISFOC are sent to TECNALIA through FTC. The data can be check online in the website prepared for this purpose (see Figure 2.38).




Figure 2.38: Screenshot of the web-datalogger

## 2.7 BIPV MODELLING AND PERFORMANCE SIMULATION

EnerBIM, as WP6 leader and BIMSolar tool developer, has completed BIPV systems digital modelling and simulation works as a pre-study.

### 2.7.1 Element level to building level methodology using 3D modelling and simulation tools

#### 2.7.1.1 Overall methodology

- a. EnerBIM develops BIMSolar as a BIPV dedicated software, first for integrated simulation performance at building level with BIPV and BAPV systems, second for BIPVBOOST products virtualization with significant level of information.

- b. **Inputs**

BIMSolar software (version BIPVBOOST) is designed to import 3D geometry through various formats:

- Trimble SketchUp native (.SKP)
- AutoDesk REVIT native (projects and families) through dedicated plugins
- Generic ISO/open BIM (.IFC)
- Green Building open format (gbXML)
- EnergyPlus open format (.IDF)

Weather data come from various reliable sources such as METEONORM®, PVGIS®. Each BIPVBOOST demo site is geo-localized with the highest level of accuracy (WGS84 coordinates) to generate the most reliable TMY as an epw file from PVGIS®.

### c. BIPV Modelling-Simulation

BIMsolar software runs contextual simulation in real time to bridge the gap between 3D modelling and performance calculation:

- Primary modelling comes from an architectural design (architect, designer): 3D CAD 3D file; SKP preferred as BIM is not necessary for preliminary studies,
- **Step#1** – Environment: 3D model generation, weather data, albedo selection, sun course, shadowing, sun exposure,
- **Step#2** – Irradiation: global yearly to hourly direct and diffuse irradiation simulation (kWh/m<sup>2</sup>) using our own raytracing technologies. Shading effects on energy ratio are highlighted in 3D,
- **Step#3** – BIPV layouts: configuration of pre-series of BIPVBOOST products (cell editor to glazing editor) using SCHWEIZER and ONYX Solar datasheets. Virtual objects handling from user (mouse+click) enables integration of modules, tiles, on selected surfaces; global performance is computed and displayed: installed power (kWp), modules area (m<sup>2</sup>), array yield (kWh/kWp), module yield, yearly PV generation (kWh), shading losses, heat losses. The software enables KPIs calculation at element level (module),
- **Step#4** – Inverter selection and wiring: the user can set-up any inverter or select inverter(s) from the PHOTON database or project database. Sizing of the inverter and strings strategies are performed with a dedicated algorithm (design support); cable / wiring specifications enable users to interact with the balance of system. Mismatching of modules and ohmic losses in strings are computed and displayed.
- **Step#5** – Results: array production is displayed at PV layout level at various time steps (yearly to hourly). Several outcomes are computed and displayed in a contextual mode: shading losses, heat losses, ohmic losses, leading to DC & AC production and final yield. Sets of data can be extracted as outputs (production, hourly figures) through CSV files at any moment, to feed the downstream processing (Energy Management, specific studies with external tools).

Locations and configurations of the BIPV systems are considered as inputs for EnerBIM 3D modelling; they are detailed upstream in this report.


## 2.7.2 Modelling strategy retained for transparent and opaque BIPV

The software is being developed to fit with ONYX Solar strategies regarding glazing systems and transparent BIPV products. The BIPV module configurator is based on 4 editors:

- Cell editor
- Pattern editor
- Transparent Glass editor
- Glazing editor

To design a transparent BIPV system, we have fixed the following steps:

### BIPV Layout



### Balance of System (downstream studies)



## 2.7.3 DEMO#1 – ISFOC building, 3D design from 2D plans, simulation with BIMsolar

### 2.7.3.1 Hypothesis

BIPV modules have been set up from ONYX Solar datasets (up to date version).

BIFACIAL technologies: the full development of these specific innovations for BIPV is not completed for BIMsolar software at this stage (WP6 T6.3 – M48).

On the other hand, the bifacial modules have not been tested in laboratory to set-up their bifaciality. In this sense, the simulation of bifacial features is not possible yet.

To perform design simulations, we have selected mono crystalline cells and glass modules from ONYX datasheets (modules front side as specified). We have created “digital twin modules” to capture front side irradiation (mainly direct + diffuse irradiance). This is a first approach before going into deeper investigations.

### 2.7.3.2 Walkable floor modules

#### Specifications from ONYX Solar:




Figure 2.39 Walkable floor – ONYX Solar

Table 2.13 Configuration of ONYX Solar Walkable floor modules

<p>GLASS</p> <p>Front: 10mm tempered Low-Iron</p> <p>Back: 10mm tempered Black Frit</p>	<div style="text-align: center;"> <p>Front</p> </div> <div style="text-align: center; margin-top: 20px;"> <p>Back</p> </div>
---	--

<p>GLAZING system</p>	
<p>FLOOR MODULES – 600x600mm 48Wp</p>	

### 2.7.3.3 Balustrade modules

Specifications from ONYX Solar:

PHOTOVOLTAIC GLASS		1.180 x 810	
FRONT SIDE		6" Mono	Crystalline Bifacial
Electrical data test conditions (STC)			
Nominal peak power	97.2	$P_{mpp}$ (Wp)	
Open-circuit voltage	15.94	$V_{oc}$ (V)	
Short-circuit current	8.07	$I_{sc}$ (A)	
Voltage at nominal power	12.59	$V_{mpp}$ (V)	
Current at nominal power	7.72	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
Mechanical description			
Length	1180	mm	
Width	810	mm	
Thickness	21,8	mm	
Surface area	0,96	sqm	
Weight	48	Kgs	
Cell type	6" Mono	Crystalline bifacial	
No PV cells / Transparency degree	24	42%	
Front Glass	10 mm	Tempered Glass Low-Iron	
Rear Glass	10 mm	Tempered Glass Low-Iron	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
Junction Box			
Protection	IP65		
Wiring Section	2.5 mm <sup>2</sup> or 4.0 mm <sup>2</sup>		
Limits			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
Temperature Coefficients			
Temperature Coefficient of Pmpp	-0,451	%/°C	
Temperature Coefficient of Voc	-0,361	%/°C	
Temperature Coefficient of Isc	+0,08	%/°C	

\*All technical specifications are subject to change without notice by Onyx Solar

Figure 2.40 Data sheets of the front face of the prototype of 1180 mm x 810 mm

PHOTOVOLTAIC GLASS		1.150 x 810	
FRONT SIDE		6" Mono	Crystalline Bifacial
Electrical data test conditions (STC)			
Nominal peak power	95,90	$P_{mpp}$ (Wp)	
Open-circuit voltage	15,93	$V_{oc}$ (V)	
Short-circuit current	7,88	$I_{sc}$ (A)	
Voltage at nominal power	12,47	$V_{mpp}$ (V)	
Current at nominal power	7,68	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
Mechanical description			
Length	1150	mm	
Width	810	mm	
Thickness	21,8	mm	
Surface area	0,93	sqm	
Weight	47	Kgs	
Cell type	6" Mono	Crystalline bifacial	
No PV cells / Transparency degree	24	41%	
Front Glass	10 mm	Tempered Glass Low-Iron	
Rear Glass	10 mm	Tempered Glass Low-Iron	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
Junction Box			
Protection	IP65		
Wiring Section	2.5 mm <sup>2</sup> or 4.0 mm <sup>2</sup>		
Limits			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
Temperature Coefficients			
Temperature Coefficient of Pmpp	-0,451	%/°C	
Temperature Coefficient of Voc	-0,361	%/°C	
Temperature Coefficient of Isc	+0,08	%/°C	

\*All technical specifications are subject to change without notice by Onyx Solar

Figure 2.41 Data sheets of the front face of the prototype of 11580 mm x 810 mm

Table 2.14 Configuration of ONYX Solar Balustrade modules

<p><b>GLASS</b></p> <p>Front: 10mm tempered Low-Iron</p> <p>Back: 10mm tempered Low-Iron</p>	<div style="border: 1px solid gray; padding: 5px;"> <p><b>Glass editor</b> ? X</p> <p>Supplier: <input type="text" value="ONYX Solar"/> <input type="button" value="Load from..."/></p> <p>Model: <input type="text" value="10mm tempered glass low iron"/> <input type="button" value="Save to My Database"/></p> <p style="text-align: right;"><input type="button" value="Save to Server Database"/></p> <p>Epaisseur : <input type="text" value="10,0 mm"/></p> <p>Conductivité : <input type="text" value="1,000 W/m.K"/></p> <p>Transmittance solaire : <input type="text" value="80,0 %"/></p> <p>Réflectance solaire avant : <input type="text" value="10,0 %"/></p> <p>Réflectance solaire arrière : <input type="text" value="10,0 %"/></p> <p>Transmittance visible : <input type="text" value="90,0 %"/></p> <p>Réflectance visible avant : <input type="text" value="5,0 %"/></p> <p>Réflectance visible arrière : <input type="text" value="5,0 %"/></p> <p>Emission thermique avant : <input type="text" value="0,837"/></p> <p>Emission thermique arrière : <input type="text" value="0,837"/></p> <p>Couleur : <input type="text"/></p> </div>
--	---



<p>GLAZING system</p>	<p><b>Glazing editor</b></p> <p>Supplier: ONYX Solar          Model: ISFOC_Balustrade_LV0</p> <p>Type de vitrage : Simple</p> <p>Epaisseur : 21.81 mm          U : 4.828 W/m².K          Facteur solaire (*) : 46 %          Transmission lumineuse (*) : 66 %          (*) Hors couche PV</p> <p>Couches (de l'extérieur vers l'intérieur) :</p> <table border="1"> <thead> <tr> <th>Couche</th> <th>Nom</th> <th>e (mm)</th> <th>Suppt.</th> </tr> </thead> <tbody> <tr> <td>Vitrage</td> <td>ONYX Solar - 10mm tempered glass low iron</td> <td>10.000</td> <td>X</td> </tr> <tr> <td>Intermédiaire</td> <td>ONYX Solar - EVAfilm 900µm</td> <td>0.900</td> <td>X</td> </tr> <tr> <td>PV</td> <td>PV layer</td> <td>0,010</td> <td></td> </tr> <tr> <td>Intermédiaire</td> <td>ONYX Solar - EVAfilm 900µm</td> <td>0.900</td> <td>X</td> </tr> <tr> <td>Vitrage</td> <td>ONYX Solar - 10mm tempered glass low iron</td> <td>10.000</td> <td>X</td> </tr> </tbody> </table> <p>+ Vitrage              + Intermédiaire</p> <p>Diagram labels: Extérieur, Intérieur</p>	Couche	Nom	e (mm)	Suppt.	Vitrage	ONYX Solar - 10mm tempered glass low iron	10.000	X	Intermédiaire	ONYX Solar - EVAfilm 900µm	0.900	X	PV	PV layer	0,010		Intermédiaire	ONYX Solar - EVAfilm 900µm	0.900	X	Vitrage	ONYX Solar - 10mm tempered glass low iron	10.000	X
Couche	Nom	e (mm)	Suppt.																						
Vitrage	ONYX Solar - 10mm tempered glass low iron	10.000	X																						
Intermédiaire	ONYX Solar - EVAfilm 900µm	0.900	X																						
PV	PV layer	0,010																							
Intermédiaire	ONYX Solar - EVAfilm 900µm	0.900	X																						
Vitrage	ONYX Solar - 10mm tempered glass low iron	10.000	X																						
<p>SOUTH BALLUSTRADE                  MODULES                  FRONT side</p>	<p><b>BIPV Module editor</b></p> <p>Supplier: ONYX Solar          Model: ISFOC_Balustrade_Front_1180x810</p> <p>Configuration   Technical   Glazing</p> <p>Physical:</p> <p>Peak power: 97.200 Wp          Power coef.: -0.451 %/°C          NOCT: 45.0 °C</p> <p>Electrical:</p> <p>Strings: 3          Voc: 15.936 V          Vmpp: 12.592 V          Isc: 8.070 A</p> <p>Visual representation of a 6x4 grid of solar cells.</p>																								
<p>EAST/WEST BALLUSTRADES                  MODULES                  FRONT side</p>	<p><b>BIPV Module editor</b></p> <p>Supplier: ONYX Solar          Model: ISFOC_Balustrade_Front_1150x810</p> <p>Configuration   Technical   Glazing</p> <p>Physical:</p> <p>Peak power: 95.904 Wp          Power coef.: -0.451 %/°C          NOCT: 45.0 °C</p> <p>Electrical:</p> <p>Strings: 3          Voc: 15.928 V          Vmpp: 12.472 V          Isc: 7.881 A</p> <p>Visual representation of a 6x4 grid of solar cells.</p>																								


### 2.7.3.4 Weather data and Irradiation modelling

We chose to use the European open access reference tool PVGIS to generate meteorological and site data at the exact location of the demo site. Visualization from satellite enable considering terrain modelling, albedo evaluation and masking effects.

<p><b>GEO LOCATION</b></p>	
<ul style="list-style-type: none"> <li>➔ Google Maps</li> <li>➔ PVGIS</li> </ul>	
<p><b>ALBEDO</b></p>	
<ul style="list-style-type: none"> <li>➔ 50% for surroundings</li> </ul>	
<p><b>ORIENTATION</b></p>	
<ul style="list-style-type: none"> <li>➔ -15° (EAST)</li> </ul>	

<p><b>HORIZON</b></p> <p>IN PLANE IRRADIATION for typical 35° PV angle</p> <p>➔ No masking for PV production</p>	<p><b>Monthly in-plane irradiation for fixed angle</b></p> <p>Y-axis: In-plane irradiation [kWh/m<sup>2</sup>]</p> <p>X-axis: Month (Jan to Dec)</p> <p><b>Outline of horizon</b></p> <p>Legend: Horizon height (solid line), Sun height, June (dashed line), Sun height, December (dotted line)</p>
<p><b>IRRADIANCE</b></p> <p>TMY data from PVGIS® to generate weather file as input for BIMsolar (epw import format)</p> <p>TMY Period: 2007-2016</p> <p>Time step: hourly</p>	<p><b>Typical Meteorological Year: Global horizontal irradiance</b></p> <p>Y-axis: Global horizontal irradiance [W/m<sup>2</sup>]</p> <p>X-axis: January to January</p> <p><b>Typical Meteorological Year: Direct (beam) normal irradiance</b></p> <p>Y-axis: Direct (beam) normal irradiance [W/m<sup>2</sup>]</p> <p>X-axis: January to January</p> <p><b>Typical Meteorological Year: Diffuse horizontal irradiance</b></p> <p>Y-axis: Diffuse horizontal irradiance [W/m<sup>2</sup>]</p> <p>X-axis: January to January</p> <p>Legend for all diagrams: Horizon height (solid line), Sun height, June (dashed line), Sun height, December (dotted line)</p>

BIMSolar epw importation



### 2.7.3.5 3D modelling – setup – existing building



Figure 2.42 Modelling has been made as much realistic as it could be from the existing 2D plans to address BIPV issues (Trimble SketchUp model from EnerBIM)



## STEP#1- BIMsolar IMPORTATION – Building settings




Figure 2.43 Close and far shadowing calculation are made through 3D modelling of realistic buildings - Sun course for full year is displayed at hourly step time



Figure 2.44 Albedo effects (reflected irradiance) are generated selecting groups and types of surfaces 50% as a setup for surroundings and for the building envelop as a general approach

### 2.7.3.6 Simulation – Results

#### STEP#2-IRRADIATION

We perform simulation of irradiance with BIMsolar raytracing algorithms to deliver irradiation 3D mapping.


We use markers to record and visualize values.

Sets of data can be exported in CSV files.

<p>Global survey on horizontal surfaces + vertical south</p> <p>Yearly kWh/sqm</p>	
<p>South balustrade</p> <p>Yearly</p> <p>→1515 kWh/sqm recorded</p>	
<p>East balustrade</p> <p>Yearly</p> <p>→1070 kWh/sqm recorded</p>	
<p>East balustrade</p> <p>Average day</p> <p>→240kWh/sqm recorded</p>	



<p>East balustrade Direct ratio →44% recorded</p>	
<p>West balustrade Yearly →880 kWh/sqm recorded</p>	
<p>West balustrade Average day →200kWh/sqm recorded</p>	
<p>West balustrade Direct ratio →55% recorded</p>	



### STEP#3 – BIPV layouts

We use virtual modules set-up from manufacturer's datasheets (see above) to generate BIPV systems. Production, shading losses, temperature losses are calculated in real time from module level to BIPV layout level. Every single module is computed as a system and the software displays individual KPIs.

Detailed results can be obtained at STEP#5 (BIMsolar reference process).




Figure 2.45 c-Si walkable floor=192 modules – Total 9.2kWp / 69.1sqm

<b>Power:</b>	9.2 kWp
<b>Module area:</b>	69.1 m <sup>2</sup>
<b>Estimated prod.:</b>	15141.7 kWh
<b>Array yield:</b>	1643.0 kWh/kWp
<b>Shadow losses:</b>	4.5 %
<b>Heat losses:</b>	4.3 %

Name	Modules
BAPV systems	
▼ BIPV systems	
ONYX Solar - ISFO...	192

Figure 2.46 Global results at array level – Year#1 - Walkable floor layout




Figure 2.47 Bifacial c-Si south balustrade= 108 modules; bifacial c-Si east + west balustrade= 24 modules – Total 12.8kWp / 125.6sqm




Figure 2.48 Global results at array level – Year#1 - Balustrades layouts

Handling a specific layout is possible as a ‘What If’ analysis: it was used for the walkable floor to size the shading effects due to the relating position towards the south balustrade. The ‘What if’ analysis is aimed at supporting design options so we can learn how to mitigate mismatching of irradiance between modules by optimization of the placement of the full array. Then the string strategy is influenced: zoning and selection of groups of modules by irradiance level / expected shading. The choice of the inverter(s) is also supported, as well as cost optimisation together with energy production (in this case 1 single inverter with 2 MPPTs / 4 strings)''

Detailed shading effects are visualized in real time:




Figure 2.49 Shading computation: walkable floor – Highest losses=13.5% (module 26-6)

#### STEP#4 – INVERTERS / WIRING

This step consists in building the best strategy for the implementation of inverters and connect to them the strings of modules to optimise the DC and AC productions.

BIMsolar enables considering the mismatching between modules (gaps in irradiance due to shading effects), then proposes the best wiring configuration for each MPPT to maximise the energy production.

Electrical layout specifications from ISFOC:




Figure 2.50 Electrical layout




Figure 2.51 INVERTERS and strings configuration in BIMsolar – Walkable floor





Figure 2.52 INVERTERS and strings configuration in BIMsolar – South balustrade




Figure 2.53 INVERTERS and strings configuration in BIMsolar – East & West balustrades

## STEP#5 – RESULTS

BIMsolar offers a comprehensive set of detailed results, from yearly to hourly timestep, covering irradiance, shading losses, heat losses, production, yield... from module level to layout level.

Examples:






Figure 2.54 PV generation + shading: walkable floor (module 26-6)




Figure 2.55 PV generation + shading: East balustrade (module 3-1)


**WALKABLE FLOOR - Table of results:**

<p>PV Generation – Shading losses GLOBAL – YEAR #1</p>	<table border="1"> <caption>Global PV Generation - Year #1</caption> <thead> <tr> <th>Category</th> <th>Value (kWh)</th> <th>Percentage</th> </tr> </thead> <tbody> <tr> <td>Production</td> <td>15141</td> <td>95.5%</td> </tr> <tr> <td>Shadow loss</td> <td>720</td> <td>4.5%</td> </tr> </tbody> </table>	Category	Value (kWh)	Percentage	Production	15141	95.5%	Shadow loss	720	4.5%																														
Category	Value (kWh)	Percentage																																						
Production	15141	95.5%																																						
Shadow loss	720	4.5%																																						
<p>PV Generation – Shading losses MONTHLY</p>	<table border="1"> <caption>Monthly PV Generation (kWh)</caption> <thead> <tr> <th>Month</th> <th>Production (kWh)</th> <th>Shadow loss (kWh)</th> </tr> </thead> <tbody> <tr><td>J</td><td>500</td><td>100</td></tr> <tr><td>F</td><td>700</td><td>100</td></tr> <tr><td>M</td><td>1200</td><td>100</td></tr> <tr><td>A</td><td>1300</td><td>100</td></tr> <tr><td>M</td><td>1600</td><td>100</td></tr> <tr><td>J</td><td>1900</td><td>100</td></tr> <tr><td>J</td><td>2100</td><td>100</td></tr> <tr><td>A</td><td>1800</td><td>100</td></tr> <tr><td>S</td><td>1200</td><td>100</td></tr> <tr><td>O</td><td>900</td><td>100</td></tr> <tr><td>N</td><td>600</td><td>100</td></tr> <tr><td>D</td><td>600</td><td>100</td></tr> </tbody> </table>	Month	Production (kWh)	Shadow loss (kWh)	J	500	100	F	700	100	M	1200	100	A	1300	100	M	1600	100	J	1900	100	J	2100	100	A	1800	100	S	1200	100	O	900	100	N	600	100	D	600	100
Month	Production (kWh)	Shadow loss (kWh)																																						
J	500	100																																						
F	700	100																																						
M	1200	100																																						
A	1300	100																																						
M	1600	100																																						
J	1900	100																																						
J	2100	100																																						
A	1800	100																																						
S	1200	100																																						
O	900	100																																						
N	600	100																																						
D	600	100																																						
<p>PV Generation – Shading losses AVERAGE DAY / MONTH</p>	<table border="1"> <caption>Average Daily PV Generation by Month</caption> <thead> <tr> <th>Month</th> <th>Production (kWh)</th> <th>Shadow loss (kWh)</th> </tr> </thead> <tbody> <tr><td>Janvier</td><td>~500</td><td>~100</td></tr> <tr><td>Février</td><td>~500</td><td>~100</td></tr> <tr><td>Mars</td><td>~500</td><td>~100</td></tr> <tr><td>Avril</td><td>~500</td><td>~100</td></tr> <tr><td>Mai</td><td>~500</td><td>~100</td></tr> <tr><td>Juin</td><td>~500</td><td>~100</td></tr> <tr><td>Juillet</td><td>~500</td><td>~100</td></tr> <tr><td>Août</td><td>~500</td><td>~100</td></tr> <tr><td>Septembre</td><td>~500</td><td>~100</td></tr> <tr><td>Octobre</td><td>~500</td><td>~100</td></tr> <tr><td>Novembre</td><td>~500</td><td>~100</td></tr> <tr><td>Décembre</td><td>~500</td><td>~100</td></tr> </tbody> </table>	Month	Production (kWh)	Shadow loss (kWh)	Janvier	~500	~100	Février	~500	~100	Mars	~500	~100	Avril	~500	~100	Mai	~500	~100	Juin	~500	~100	Juillet	~500	~100	Août	~500	~100	Septembre	~500	~100	Octobre	~500	~100	Novembre	~500	~100	Décembre	~500	~100
Month	Production (kWh)	Shadow loss (kWh)																																						
Janvier	~500	~100																																						
Février	~500	~100																																						
Mars	~500	~100																																						
Avril	~500	~100																																						
Mai	~500	~100																																						
Juin	~500	~100																																						
Juillet	~500	~100																																						
Août	~500	~100																																						
Septembre	~500	~100																																						
Octobre	~500	~100																																						
Novembre	~500	~100																																						
Décembre	~500	~100																																						

<p>PV Generation – Shading losses DAILY</p>													
<p>AC Production (Inverter Out) – AC/DC ratio GLOBAL Final yield = 1531kWh/kWp</p>	<table border="1"> <thead> <tr> <th>Category</th> <th>Value (kWh)</th> <th>Percentage</th> </tr> </thead> <tbody> <tr> <td>AC Production</td> <td>14109</td> <td>98.6%</td> </tr> <tr> <td>DC to AC loss</td> <td>200</td> <td>1.4%</td> </tr> </tbody> </table>	Category	Value (kWh)	Percentage	AC Production	14109	98.6%	DC to AC loss	200	1.4%			
Category	Value (kWh)	Percentage											
AC Production	14109	98.6%											
DC to AC loss	200	1.4%											
<p>Electrical Losses (Inverter OUT) GLOBAL</p>	<table border="1"> <thead> <tr> <th>Category</th> <th>Value (kWh)</th> <th>Percentage</th> </tr> </thead> <tbody> <tr> <td>DC Inverter In</td> <td>14310</td> <td>92.5%</td> </tr> <tr> <td>Mismatch losses</td> <td>831</td> <td>5.4%</td> </tr> <tr> <td>Ohmic losses</td> <td>333</td> <td>2.1%</td> </tr> </tbody> </table>	Category	Value (kWh)	Percentage	DC Inverter In	14310	92.5%	Mismatch losses	831	5.4%	Ohmic losses	333	2.1%
Category	Value (kWh)	Percentage											
DC Inverter In	14310	92.5%											
Mismatch losses	831	5.4%											
Ohmic losses	333	2.1%											

**SOUTH BALUSTRADO - Table of results:**

<p>PV generation – Shading losses GLOBAL – YEAR #1</p>	<p>Production (100 %) Shadow loss (0 %)</p> <p>12802 kWh 100 %</p>
<p>PV Generation MONTHLY</p>	<p>Production Shadow loss</p>
<p>PV Generation AVERAGE DAY / MONTH</p>	<p>Production Shadow loss</p>



**EAST BALUSTRADE - Table of results:**


<p>PV generation – Shading losses GLOBAL – YEAR #1</p>	<p>Echelle auto    Enregistrer image...    Enregistrer CSV...</p> <p>■ Production (99.8 %) ■ Shadow loss (0.2 %)</p> <p>102 kWh 100.3%</p>																																							
<p>PV Generation MONTHLY</p>	<p>■ Production ■ Shadow loss</p> <table border="1"> <thead> <tr> <th>Month</th> <th>Production (kWh)</th> <th>Shadow loss (kWh)</th> </tr> </thead> <tbody> <tr><td>Janvier</td><td>42</td><td>0</td></tr> <tr><td>Février</td><td>62</td><td>0</td></tr> <tr><td>Mars</td><td>100</td><td>0</td></tr> <tr><td>Avril</td><td>95</td><td>0</td></tr> <tr><td>Mai</td><td>135</td><td>0</td></tr> <tr><td>Juin</td><td>155</td><td>0</td></tr> <tr><td>Juillet</td><td>150</td><td>0</td></tr> <tr><td>Août</td><td>140</td><td>0</td></tr> <tr><td>Septembre</td><td>105</td><td>0</td></tr> <tr><td>Octobre</td><td>80</td><td>0</td></tr> <tr><td>Novembre</td><td>50</td><td>0</td></tr> <tr><td>Décembre</td><td>50</td><td>0</td></tr> </tbody> </table>	Month	Production (kWh)	Shadow loss (kWh)	Janvier	42	0	Février	62	0	Mars	100	0	Avril	95	0	Mai	135	0	Juin	155	0	Juillet	150	0	Août	140	0	Septembre	105	0	Octobre	80	0	Novembre	50	0	Décembre	50	0
Month	Production (kWh)	Shadow loss (kWh)																																						
Janvier	42	0																																						
Février	62	0																																						
Mars	100	0																																						
Avril	95	0																																						
Mai	135	0																																						
Juin	155	0																																						
Juillet	150	0																																						
Août	140	0																																						
Septembre	105	0																																						
Octobre	80	0																																						
Novembre	50	0																																						
Décembre	50	0																																						
<p>PV Generation AVERAGE DAY / MONTH</p>	<p>■ Production ■ Shadow loss</p>																																							



<p>AC/DC Production GLOBAL – YEAR #1</p> <p>FINAL YIELD (Inverters Out) 776 kWh/kWp</p>	<p>A pie chart illustrating the production split. The legend indicates AC Production at 98.4% and DC to AC loss at 1.6%. The chart shows a large blue segment (98.4%) and a very thin red segment (1.6%). Labels on the chart indicate 893 kWh (98%) for the blue segment and 14 kWh (2%) for the red segment.</p> <table border="1"> <thead> <tr> <th>Category</th> <th>Percentage</th> <th>Value (kWh)</th> </tr> </thead> <tbody> <tr> <td>AC Production</td> <td>98.4 %</td> <td>893 kWh (98 %)</td> </tr> <tr> <td>DC to AC loss</td> <td>1.6 %</td> <td>14 kWh (2 %)</td> </tr> </tbody> </table>	Category	Percentage	Value (kWh)	AC Production	98.4 %	893 kWh (98 %)	DC to AC loss	1.6 %	14 kWh (2 %)			
Category	Percentage	Value (kWh)											
AC Production	98.4 %	893 kWh (98 %)											
DC to AC loss	1.6 %	14 kWh (2 %)											
<p>Electrical Losses (Inverter OUT) GLOBAL</p>	<p>A pie chart illustrating the breakdown of electrical losses. The legend indicates DC Inverter In at 78%, Mismatch losses at 0.2%, and Ohmic losses at 21.8%. The chart shows a large blue segment (78%), a small red segment (21.8%), and a very thin green segment (0.2%). A label on the red segment indicates 353 kWh (22%).</p> <table border="1"> <thead> <tr> <th>Category</th> <th>Percentage</th> <th>Value (kWh)</th> </tr> </thead> <tbody> <tr> <td>DC Inverter In</td> <td>78 %</td> <td>-</td> </tr> <tr> <td>Mismatch losses</td> <td>0.2 %</td> <td>-</td> </tr> <tr> <td>Ohmic losses</td> <td>21.8 %</td> <td>353 kWh (22 %)</td> </tr> </tbody> </table>	Category	Percentage	Value (kWh)	DC Inverter In	78 %	-	Mismatch losses	0.2 %	-	Ohmic losses	21.8 %	353 kWh (22 %)
Category	Percentage	Value (kWh)											
DC Inverter In	78 %	-											
Mismatch losses	0.2 %	-											
Ohmic losses	21.8 %	353 kWh (22 %)											

**WEST BALUSTRADE - Table of results:**

<p>PV generation – Shading losses GLOBAL – YEAR #1</p>	<p>Production (100 %) Shadow loss (0 %)</p> <p>111.1 kWh</p>
<p>PV Generation MONTHLY</p>	<p>Production Shadow loss</p>
<p>PV Generation AVERAGE DAY / MONTH</p>	<p>Production Shadow loss</p>



### 2.7.4 Summary of the results

Unit	Array							Inverters								YIELD			
	kWh				Panel orientation			kWh		kWh		kWh		%		kWh		kWh/kWp	
	Floor	South Balustrade	East Balustrade	West Balustrade		Azimet*	Floor	Balustrades	Floor	Balustrades	Floor	Balustrades	Floor	Balustrades	Floor	Balustrades	Floor	Balustrades	
Direct	77 537	82 409	6 987	4 745	East	-105	15 141,7	1 182,8	14 310,0	907,0	201,0	17,0	1,4%	1,9%	14 109	893	1 531	776	
Diffuse	37 409	31 102	3 386	3 323	South	-15,0	12 801,7	941,0	12 389,0	728,0	201,0	173,0	12,0	1,4%	1,4%	12 216	716	1 163	
Indirect	3 731	17 883	1 772	1 816	West	75,0													
						**South = 0*	15 141,7	14 925,5	14 310,0	14 024,0	201,0	202,0	5%	5%	14 109,0	13 825,0	1 531,0	853,7	
<b>TOTAL:</b>		272 100,0	12 145,0	9 884,0			30 067,2		28 334,0		403,0				27 934,0				

### 2.7.5 Conclusions

At the current stage of the performance of the software and provided the fact that products and project are submitted to updates we consider that the first results are positive and converging towards expectations.

In particular:

- The impact of albedo is promising to consider the BIPV floor layout: gains for reflected irradiance from the tower enable to maintain a correct yield for the modules below this close obstacle,
- The balustrades have no shading losses and receive reflected irradiance from the ground,
- Spring, autumn months and December are profitable for the south balustrade.


We did not face critical difficulties in the process except difficulties in converting 2D plans into 3D model (geometrical issues to get a readable 3D mesh).

Considering bifacial gains, we could not proceed with proper simulation in this phase because of missing parameters. But we could assume that a gain in production outcomes between 15% and 25% is realistic.

Next steps will be:

1. Update of the building 3D model, related to final BIPV integration (demo site manager),
2. Implementation of BIFACIAL simulation (rear irradiance calculation on every single cell depending on elevation and orientation is crucial to perform reliable computation) with bifacial outcomes and settings from the testing phase of the modules,
3. BIM upgrade of the modules following ONYX Solar and ISFOC specifications, to enable technical design of the system,
4. Comparison between measurement and simulation as soon as the real modules will be integrated and monitoring available.

## 2.8 PLANNING TIMELINE



### 3 DEMO SITE 2: MASS

#### 3.1 DEMO-SITE BUILDING DESCRIPTION

MASS demo site, located in Aretxabaleta (Spain), corresponds to the headquarters and factory of Mondragón Assembly. The building is connected to the general electrical grid and PV panels are already installed on the roof with nominal power of 100kW.



Figure 3.1: Google maps top view of the factory.

##### 3.1.1 General topology

The building, an industrial pavilion, is divided into two different factories, the external dimensions of the MASS factory are 103,4 m long and between 51 and 66,6 m wide resulting in a ground floor area of about 5700 m<sup>2</sup>. From those 5700 m<sup>2</sup>, 790 m<sup>2</sup> are divided in three heights where the offices are located, the remaining 4.910 m<sup>2</sup> is a workshop with a height between 11 and 12 meters.




Figure 3.2: CAD rendering of the pavilion.



### 3.2 ARCHITECTURAL BIPV DESIGN

The BIPV installation will partially cover the South-East façade of the building. The solution will consist of glass-glass panels and c-Si technology, manufactured by Onyx, using the line developed by MASS within WP2. The BIPV modules will be installed using Tulipps' lock-&-go mounting system.



Figure 3.3: East façade of MASS building

For this demo, the final design has been selected between two different configurations, 1 with 114 panels of 2mx0.667 m and another composed of 228 panels of 1.02m x 0.667 m.

Demo 2	
MASS	
SCEN. 1 2m panels	SCEN. 2 1,02m panels
Glass-glass c-Si modules with different configurations (ONYX). Façade structure (TULIPPS)	
Ventilade façade	
SE	
152 m <sup>2</sup>	155 m <sup>2</sup>
21,6 kWp	22,2 kWp

Figure 1.4 Different configurations for Demo2

Since both designs, the 2 m panel and the 1.02 m panel, met the project specifications and met what MASS as the final owner required in aesthetic and production terms, the decision to select the design of 2m panels was taken, due to the fact that the economic valuation raised both by the local installer and by the project partners, was more economical than the option of 1.02 m panels.

Turn-key installation quotation for a demo-site				
		Scenario 1,02 m (4+4)	Scenario 2m (6+6)	Scenario 2m (4+4) ***
<b>1. Materials</b>			<b>Price [€]</b>	<b>Price [€]</b>
1.1	Fastening and mounting system	29.302,00 €	20.817,00 €	20.475,00 €
1.2	BIPV modules	50.651,20 €	53.378,30 €	42.309,12 €
1.3	Cabling	1.200,00 €	1.200,00 €	1.200,00 €
1.4	Inverters	4.750,00 €	4.750,00 €	4.750,00 €
1.5	Monitoring system			
1.6	Electrical installation materials	3.100,00 €	3.100,00 €	3.100,00 €
1.7	Battery System	6.200,00 €	6.200,00 €	6.200,00 €
<b>MATERIALS SUBTOTAL</b>		<b>95.203,20 €</b>	<b>89.445,30 €</b>	<b>78.034,12 €</b>
<b>2. Labor</b>			<b>Price [€]</b>	<b>Price [€]</b>
2.1	Permit obtaining	2.500,00 €	2.500,00 €	2.500,00 €
2.2	Detailed Executive Project	9.000,00 €	9.000,00 €	9.000,00 €
2.3	Structural and mechanical installation	66.500,00 €	66.500,00 €	66.500,00 €
2.4	Electrical installation	5.500,00 €	5.500,00 €	5.500,00 €
2.5	Certification of the installation	8.500,00 €	8.500,00 €	8.500,00 €
2.6	Operation and Maintenance (optional)	0,00 €	0,00 €	0,00 €
<b>LABOR SUBTOTAL</b>		<b>92.000,00 €</b>	<b>92.000,00 €</b>	<b>92.000,00 €</b>
<b>TOTAL TURN-KEY INSTALLATION:</b>		<b>187.203,20 €</b>	<b>181.445,30 €</b>	<b>170.034,12 €</b>

Figure 1.5 Economic table for different options of Demo2

With those data the selected option is the variant 38 designed by Viriden, from now on “demo 2 selected design”.

### 3.2.1 Demo 2 selected design




Figure 3.6: Demo 2 final design

<b>C2 011</b>	
Plan-Nr.	D003
Maassstab	1:20
Plan-Grösse	A3
erstellt/von	29.08.19/gas
geändert/von	25.09.19/gas





Figure 3.7: detail of the variable module design

### 3.3 BIPV STRUCTURE DESIGN

The façade structure design can be divided into in two parts, on the one hand, the necessary structure able to tie the modules to the existing building, whose designer has been AGM, as a local installer hired by MASS and a second structure, which is properly fixed to the BIPV module that has been designed by Tullips as part of the project.

#### 3.3.1 Building to module structure.


For the structure necessary to be able to place the panels for this demo the following documents of the Technical Building Code (CTE) have been taken into account:


- DB SE: Structural safety
- DB SE AE: Actions in the building
- DB SE C: Foundation
- DB SE A: Steel
- DB SE SI: Fire Safety

In addition, the following regulations in force have been taken into account:


- EHE-08: Structural Concrete Instruction.
- EAE: Structural Steel Instruction
- NSCE-02: Seismic resistant construction standard: general part and edification.
- RC-08: Instruction for the reception of cements

For the structural parts, Rolled steel in S-275-JR profiles built by welding in the workshop and on site by electrode E.43.3.B in two phases with surface treatment by blasting SA 2.5 and application in the workshop of a coat of anticorrosive primer of ZINC PHOSPHATE with a thickness of 40 microns are used. Anchor plates for support and fixings to existing structural elements (with studs, pins, tubular elements, plates, HIT-V 5.8 dowels of different metrics, HIT-RE 500 resin, all according to detail of structure drawings), losses, bushings, layout, auxiliary means and cleaning, according to CTE, DB-SE-AE and DB-SE-A.






Detalle placas T2. escala 1/10  
dimensiones placa = 300.350.15 mm (S275)



Espesor placa base: 15 mm


Detalle placas T1. escala 1/10  
dimensiones placa = 300.300.15 mm (S275)



Espesor placa base: 15 mm




ALZADO ESTE CON ANCLAJES A PILARES  
E 1:100




SUBESTRUCTURA DE SUJECCIÓN DE PANELES SUPERIORES  
E 1:50


M1\_MÓDULO (EXTREMOS)



M2\_MÓDULO (CENTRALES)



VISTA LATERAL




ALZADO DE UNIÓN ENTRE CERCHAS  
E 1:25




SUBESTRUCTURA DE SUJECCIÓN DE PANELES INFERIORES  
E 1:50



M3\_MÓDULO (EXTREMOS)




M4\_MÓDULO (CENTRALES)




VISTA LATERAL




ALZADO ESTE  
E 1:100



MÓDULO FOTOVOLTAICO  
E 1:20



ESTRUCTURA DE SUJECIÓN DE PANELES  
E 1:50






Figure 3.8: MASS substructure for Tulipps framing assembly

### 3.3.2 Module fixing structure

The frame for the demo design has been done by Tulipps, which has worked towards demonstrating a significant cost reduction through adjustments in the substructure design and components towards lower bill of materials, flexibility in sizing, ultra-easy installation processes.

This system consists of a distinctive click-&-go technology which is mounted in a rail system installed in the wall., with 1600 mm pitch distance. The system is presented in the public deliverable *D4.3. Functional samples of cost effective glass façade systems complying with specifications.*




Figure 3.9: Framing provided by Tulipps

### 3.4 BIPV MODULE DESIGN

For this demo2, the panels will be manufactured by Onyx. The initial design of the same will consist on the geometry shown in the following image where there will be a transparent front glass of 4 mm, 6 "and 5 BB cells, 2 foils of 0.9 mm EVA to make the seal and rear glass with colour RAL 3020, which will give the selected aesthetic to the whole of the façade. Regarding this design, it remains to be validated in the WP5 that the dimensions of 4 + 4 mm of glass is sufficient.




Figure 3.10: Composition of the panels

As an example, the first module manufactured in Onyx with the specifications of this demo2 is shown.




Figure 3.11: 2000m x 667 mm with 48 cells module manufactured by Onyx

### 3.4.1 BIPVBOOST module/s

The panels to be manufactured for this demo2 in terms of geometry and quantity, as can be seen in Section 3.2 where the design of the facade is exposed, would be the following:

- 90 modules of 2000mm x 667 mm and 48 cells
- 4 modules of 2000mm x 667 mm and 44 cells
- 4 modules of 2000mm x 667 mm and 40 cells
- 4 modules of 2000mm x 667 mm and 36 cells
- 4 modules of 2000mm x 667 mm and 32 cells
- 4 modules of 2000mm x 667 mm and 28 cells
- 4 modules of 2000mm x 667 mm and 24 cells

Each of the designs is detailed below. In all cases the module configuration is composed by the following materials:




Figure 3.12: Glass-glass laminate composition for demo prototypes






Figure 3.13: Façade glass-glass with 48 poly-crystalline cells and tempered rear glass RAL 3020

Table 3.1: Data sheet of glass-glass module with 48 poly-crystalline cells and tempered rear glass RAL 3020

<b>PHOTOVOLTAIC GLASS</b>		<b>2.000 x 667</b>	
48 cells		<b>6" Poly</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	202	P <sub>mpp</sub> (Wp)	
Open-circuit voltage	31	V <sub>oc</sub> (V)	
Short-circuit current	8,27	I <sub>sc</sub> (A)	
Voltage at nominal power	26	V <sub>mpp</sub> (V)	
Current at nominal power	7,81	I <sub>mpp</sub> (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	2000	mm	
Width	667	mm	
Thickness	9,8	mm	
Surface area	1,33	sqm	
Weight	27	Kgs	
Cell type	6" Poly	Crystalline	
No PV cells / Transparency degree	48	12%	
Front Glass	4 mm	Tempered Glass Low-Iron	
Rear Glass	4 mm	Tempered Glass RAL 3020	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	V <sub>sys</sub> (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of P <sub>mpp</sub>	-0,451	%/°C	
Temperature Coefficient of V <sub>oc</sub>	-0,361	%/°C	
Temperature Coefficient of I <sub>sc</sub>	+0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	12%
U-value [W/sqm.K]	5,4
Peak Power [Wp/sqm]	151,2




Figure 3.14: Façade glass-glass with 44 poly-crystalline cells and tempered rear glass RAL 3020

Table 3.2: Data sheet of glass-glass module with 44 poly-crystalline cells and tempered rear glass RAL 3020

<b>PHOTOVOLTAIC GLASS</b>		<b>2.000 x 667</b>	
44 cells		<b>6" Poly</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	185	$P_{mpp}$ (Wp)	
Open-circuit voltage	28	$V_{oc}$ (V)	
Short-circuit current	8,27	$I_{sc}$ (A)	
Voltage at nominal power	24	$V_{mpp}$ (V)	
Current at nominal power	7,81	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	2000	mm	
Width	667	mm	
Thickness	9,8	mm	
Surface area	1,33	sqm	
Weight	27	Kgs	
Cell type	6" Poly	Crystalline	
No PV cells / Transparency degree	44	20%	
Front Glass	4 mm	Tempered Glass Low-Iron	
Rear Glass	4 mm	Tempered Glass RAL 3020	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of $P_{mpp}$	-0,451	%/°C	
Temperature Coefficient of $V_{oc}$	-0,361	%/°C	
Temperature Coefficient of $I_{sc}$	+0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	20%
U-value [W/sqm.K]	5,4
Peak Power [Wp/sqm]	138,6




Figure 3.15: Façade glass-glass with 40 poly-crystalline cells and tempered rear glass RAL 3020

Table 3.3: Data sheet of glass-glass module with 40 poly-crystalline cells and tempered rear glass RAL 3020

<b>PHOTOVOLTAIC GLASS</b>		<b>2.000 x 667</b>	
40 cells		<b>6" Poly</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	168	$P_{mpp}$ (Wp)	
Open-circuit voltage	26	$V_{oc}$ (V)	
Short-circuit current	8,27	$I_{sc}$ (A)	
Voltage at nominal power	22	$V_{mpp}$ (V)	
Current at nominal power	7,81	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	2000	mm	
Width	667	mm	
Thickness	9,8	mm	
Surface area	1,33	sqm	
Weight	27	Kgs	
Cell type	6" Poly	Crystalline	
No PV cells / Transparency degree	40	27%	
Front Glass	4 mm	Tempered Glass Low-Iron	
Rear Glass	4 mm	Tempered Glass RAL 3020	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of $P_{mpp}$	▼ -0,451	%/°C	
Temperature Coefficient of $V_{oc}$	▼ -0,361	%/°C	
Temperature Coefficient of $I_{sc}$	▼ +0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	27%
U-value [W/sqm.K]	5,4
Peak Power [Wp/sqm]	126,0






Figure 3.16: Façade glass-glass with 36 poly-crystalline cells and tempered rear glass RAL 3020

Table 3.4: Data sheet of glass-glass module with 36 poly-crystalline cells and tempered rear glass RAL 3020

<b>PHOTOVOLTAIC GLASS</b>		<b>2.000 x 667</b>	
36 cells		<b>6" Poly</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	151	P <sub>mpp</sub> (Wp)	
Open-circuit voltage	23	V <sub>oc</sub> (V)	
Short-circuit current	8,27	I <sub>sc</sub> (A)	
Voltage at nominal power	19	V <sub>mpp</sub> (V)	
Current at nominal power	7,81	I <sub>mpp</sub> (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	2000	mm	
Width	667	mm	
Thickness	9,8	mm	
Surface area	1,33	sqm	
Weight	27	Kgs	
Cell type	6" Poly	Crystalline	
No PV cells / Transparency degree	36	34%	
Front Glass	4 mm	Tempered Glass Low-Iron	
Rear Glass	4 mm	Tempered Glass RAL 3020	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	V <sub>sys</sub> (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of P <sub>mpp</sub>	-0,451	%/°C	
Temperature Coefficient of V <sub>oc</sub>	-0,361	%/°C	
Temperature Coefficient of I <sub>sc</sub>	+0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	34%
U-value [W/sqm.K]	5,4
Peak Power [Wp/sqm]	113,4




Figure 3.17: Façade glass-glass with 32 poly-crystalline cells and tempered rear glass RAL 3020

Table 3.5: Data sheet of glass-glass module with 32 poly-crystalline cells and tempered rear glass RAL 3020

<b>PHOTOVOLTAIC GLASS</b>		<b>2.000 x 667</b>	
32 cells		<b>6" Poly</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	134	$P_{mpp}$ (Wp)	
Open-circuit voltage	20	$V_{oc}$ (V)	
Short-circuit current	8,27	$I_{sc}$ (A)	
Voltage at nominal power	17	$V_{mpp}$ (V)	
Current at nominal power	7,81	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	2000	mm	
Width	667	mm	
Thickness	9,8	mm	
Surface area	1,33	sqm	
Weight	27	Kgs	
Cell type	6" Poly	Crystalline	
No PV cells / Transparency degree	32	42%	
Front Glass	4 mm	Tempered Glass Low-Iron	
Rear Glass	4 mm	Tempered Glass RAL 3020	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of $P_{mpp}$	-0,451	%/°C	
Temperature Coefficient of $V_{oc}$	-0,361	%/°C	
Temperature Coefficient of $I_{sc}$	+0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	34%
U-value [W/sqm.K]	5,4
Peak Power [Wp/sqm]	113,4




Figure 3.18: Façade glass-glass with 28 poly-crystalline cells and tempered rear glass RAL 3020

Table 3.6: Data sheet of glass-glass module with 28 poly-crystalline cells and tempered rear glass RAL 3020

<b>PHOTOVOLTAIC GLASS</b>		<b>2.000 x 667</b>	
28 cells		<b>6" Poly</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	118	$P_{mpp}$ (Wp)	
Open-circuit voltage	18	$V_{oc}$ (V)	
Short-circuit current	8,27	$I_{sc}$ (A)	
Voltage at nominal power	15	$V_{mpp}$ (V)	
Current at nominal power	7,81	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	2000	mm	
Width	667	mm	
Thickness	9,8	mm	
Surface area	1,33	sqm	
Weight	27	Kgs	
Cell type	6" Poly	Crystalline	
No PV cells / Transparency degree	28	49%	
Front Glass	4 mm	Tempered Glass Low-Iron	
Rear Glass	4 mm	Tempered Glass RAL 3020	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of $P_{mpp}$	-0,451	%/°C	
Temperature Coefficient of $V_{oc}$	-0,361	%/°C	
Temperature Coefficient of $I_{sc}$	+0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	49%
U-value [W/sqm.K]	5,4
Peak Power [Wp/sqm]	88,2






Figure 3.19: Data sheet of glass-glass module with 24 poly-crystalline cells and tempered rear glass RAL 3020

Table 3.7: Data sheet of glass-glass module with 24 poly-crystalline cells and tempered rear glass RAL 3020

<b>PHOTOVOLTAIC GLASS</b>		<b>2.000 x 667</b>	
24 cells		<b>6" Poly</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	101	$P_{mpp}$ (Wp)	
Open-circuit voltage	15	$V_{oc}$ (V)	
Short-circuit current	8,27	$I_{sc}$ (A)	
Voltage at nominal power	13	$V_{mpp}$ (V)	
Current at nominal power	7,81	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	2000	mm	
Width	667	mm	
Thickness	9,8	mm	
Surface area	1,33	sqm	
Weight	27	Kgs	
Cell type	6" Poly	Crystalline	
No PV cells / Transparency degree	24	56%	
Front Glass	4 mm	Tempered Glass Low-Iron	
Rear Glass	4 mm	Tempered Glass RAL 3020	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of $P_{mpp}$	-0,451	%/°C	
Temperature Coefficient of $V_{oc}$	-0,361	%/°C	
Temperature Coefficient of $I_{sc}$	+0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	56%
U-value [W/sqm.K]	5,4
Peak Power [Wp/sqm]	75,6

To connect the solar panels as well as to offer all the advantages that a J-box offers, such as avoiding the entry of water, the following option was selected.




Figure 1.16 JB approximate location (equal to all the variants)

### DETAIL : Junction Box




Figure 1.17 PV-JB/WL-V MC (4 spring clamps) junction box

All the junction boxes of these variants use MC4 connectors

### 3.5 BIPV ELECTRICAL SYSTEM DESIGN

#### 3.5.1 BIPVBOOST electrical diagram

Electrical diagram for demo 2 selected design is defined by Ekilor, MASS local installer, which has proven experience in the installation of solar panels, including those that are currently on the roof of MASS




Figure 3.20: Electrical diagram provided by Ekilor

### 3.6 BIPV MONITORING DESIGN

#### 3.6.1 Definition of monitoring objectives: BIPV performance validation, economic viability and progress towards NZEB requirements

As described previously in this document the Mondragon assembly demo site will be equipped with a BIPV ventilated facade and new BEMS system. The objective of the monitoring system is to measure and verify the energy performance of the BIPVBOOST project developments and implementation in Mondragon assembly demo site. In this context the energy performance is understood as the non-used energy (energy savings), the self-consumption ratio, the reduction in the energy bill and the performance ratio. Next the implementation of monitoring system is presented.

#### 3.6.2 Definition of variables to be monitored

In order to achieve the monitoring system objectives, the monitored variables have been selected following the monitoring guidelines defined in deliverable 8.3. The following figure 3.9 shows in a graphical way the main variables that will be measured, and the table 3.1 summarised the measured variables, the monitoring instruments and the required accuracies. These variables will be acquired in two-time steps, the pre-intervention (In red font in figure 3.9) period and the post intervention period (inside the red box in figure 3.9)




Figure 3.21: Main measuring variables of Aretxabaleta demo site

**Table 3.8: Aretxabaleta demo site variables measurement information: required instruments, range, units, Time resolution and accuracy**

Variable	Description	instrument	Range	Units	Time Resolution	Accuracy
<b>BIPV components</b>						
<b>Ventilated facade</b>						
<b>Meteo</b>						
$G_{i_{vf}}$	Irradiance in the ventilated facade plane	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the Reading
$T_{m_{vf}}$	Temperature of the reference cell	Thermocouple type T	0-100	°C	<1min	1K
<b>DC</b>						
$I_{vf}$	Intensity DC	Amperimeter		A	<1min	1% of the Reading
$V_{vf}$	Voltage DC	Voltimeter		V	<1min	1% of the Reading
$P_{vf}$	Power DC	Power meter	24	kW	<1min	2% of the Reading
$ET_{vf}$	Energy DC	Energy meter		kW/h	<1min	
<b>AC</b>						
$P_{vf\_l}$	Power AC	Power meter	24	kW	<1min	2% of the Reading
$ET_{vf\_l}$	Energy AC	Energy meter		kW/h	<1min	
<b>Storage</b>						
<b>Imput</b>						
$I_{st}$	Intensity	Amperimeter		A	<1min	1% of the Reading
$V_{st}$	Voltage	Voltimeter		V	<1min	1% of the Reading
$P_{st}$	Power	Power meter	24	kW	<1min	2% of the Reading
$ET_{st}$	Energy	Energy meter		kW/h	<1min	
<b>Building</b>						
$G_i$	Global irradiance	Pyranometer	0-1200	w/m <sup>2</sup>	<1min	5% of the Reading
$T_{amb}$	Ambient temperature	Thermocouple type T	0-50	°C	<1min	1K
$S_w$	Wind Speed	Ultrasonic anemometer	0-100	m/s	<1min	Sw<5m/s--->0,5m/s;Sw>5m/s--->10% of the reading
<b>HVAC</b>						
<b>Office</b>						
$I_{hvac\_office}$	Intensity	Amperimeter		A	<1min	1% of the Reading
$V_{hvac\_office}$	Voltage	Voltimeter		V	<1min	1% of the Reading
$P_{hvac\_office}$	Power	Power meter		kW	<1min	2% of the Reading
$ET_{hvac\_office}$	Energy	Energy meter		kW/h	<1min	
<b>WorkShop 1</b>						



$I_{hvacc\_WS1}$	Intensity	Amperimeter		A	<1min	1% of the Reading
$V_{hvacc\_WS1}$	Voltage	Voltimeter		V	<1min	1% of the Reading
$P_{hvacc\_WS1}$	Power	Power meter		kW	<1min	2% of the Reading
$ET_{hvacc\_WS1}$	Energy	Energy meter		kW/h	<1min	
<b>WorkShop 2</b>						
$I_{hvacc\_c\_WS2}$	Intensity	Amperimeter		A	<1min	1% of the Reading
$V_{hvacc\_WS2}$	Voltage	Voltimeter		V	<1min	1% of the Reading
$P_{hvacc\_WS2}$	Power	Power meter		kW	<1min	2% of the Reading
$ET_{hvacc\_WS2}$	Energy	Energy meter		kW/h	<1min	
<b>Existing PV field</b>						
<b>AC</b>						
$P_{pv\_I}$	Power AC	Power meter	89	kW	<1min	2% of the Reading
$ET_{pv\_I}$	Energy AC	Energy meter		kW/h	<1min	
<b>Grid</b>						
$P_{gr}$	Power from the grid	Power meter		kW	<1min	2% of the Reading
$ET_{gr}$	Energy from the grid	Energy meter		kW/h	<1min	

### 3.6.3 Existing monitoring system

Mondragon assembly has already a PV plant installed on the building's roof. This PV plant is not part of the BIPVBOOST project, but it has an impact in the self-consumption ratio of the building during the project period. Therefore, the monitoring of the production of this plant is important to evaluate the project KPIs. Fortunately, the energy produced by this existing PV plant is being monitoring by the existing a monitoring system and the data are shared with TECNALIA.

### 3.6.4 BIPVBOOST monitoring system

The monitoring system is composed by all the instruments required to measure the variables listed in Table 3.8 connected to a data logger (via Modbus). Figure 3.22 shows the preintervention period connection diagram between all the instruments and the main board where the data logger is installed. The installation of all these instruments was carried out before August 2020. The installation lay out can be divided in two main groups: The roof installation and the indoor installation.

The instruments installed on the roof (near to the pre-existing PV plant) are devoted to measure the meteorological data (See Figure 3.23).

- Reference cell to measure the irradiance in the ventilated facade plane
- Pyranometer to measure the global irradiance
- PT100 to measure the ambient temperature, protected from sun radiation and wind.
- Anemometer to measure the wind speed.

Moreover, the instrument devoted to measure de building climatization consumption (HVAC) were installed indoor in the workshop 1, workshop 2 and the offices.




Figure 3.22: Pre-intervention monitoring system connection schema




Figure 3.23: Roof installation of the instruments devoted to meteorological data.

Regarding the data collection, the gathered data are sent to TECNALIA via internet connection (provided by Mondragon Assembly) and the data of the pre-existing PV plant will be sent to TECNALIA. The data can be checked online in the website prepared for this purpose (see next figure).




Figure 3.24: Screenshot of the web datalogger.

### 3.7 BIPV MODELLING AND PERFORMANCE SIMULATION

EnerBIM, as WP6 leader and BIMsolar tool developer, has completed BIPV systems digital modelling and simulation works as a pre-study.

#### 3.7.1 Element level to building level methodology using 3D modelling and simulation tools

##### 3.7.1.1 Overall methodology

The same methodology presented in Section 2.7.1.1 has been used.

#### 3.7.2 Modelling strategy retained for transparent and opaque BIPV

The software is being developed to fit with ONYX Solar and TULIPPS combined strategies regarding BIPV glass modules to integrate cladding systems. The BIPV module configurator is based on 4 editors:

- Cell editor
- Pattern editor
- Transparent Glass editor
- Glazing editor

To design a transparent BIPV system, we have fixed the following steps:

### BIPV Layout



### Balance of System (downstream studies)



As a pre-study approach - conceptual design - for cladding systems without advanced BIPV considerations at this stage, the module builder is based on 2 editors working as a BAPV configurator:

- Cell editor
- Module editor

We have fixed the following steps:

### BAPV Layout



## **3.7.3 DEMO#2 – MASS building, 3D design from 2D plans, simulation with BIMsolar**

### **3.7.3.1 Hypothesis**

BIPV modules have been set up from ONYX Solar datasets.

COLOURED modules: the development of these specific innovations for BIPV is not completed for BIMsolar software at this stage (WP6 T6.3 – M48). We use a first level of optical properties related to BIPV glass quality and modules resultant efficiency (from lab tests by ONYX Solar).

To run first simulations, we have selected mono crystalline cells and glass modules from ONYX Solar standard modules datasheets in accordance with Viridén+Partner's variant ref.38 (25.09.2019) amended during the 5<sup>th</sup> General Assembly (05.05.2021).




Figure 3.25: Viriden+Partner – Project East Façade – Variant 38 design (vertical configuration)

ONYX Solar has set up single sized modules as defined below, where only the cell density is changed in certain modules:




Figure 3.26: Onyx Solar – Detailing modules – Double sized (final choice)



### 3.7.3.2 CLADDING MODULES VARIANT 38 – BAPV features

<p>BIPV equivalent MODULES (source ONYX Solar) 48 cells / 202Wp 667mm x 2000mm</p>		
<p>BIPV equivalent MODULES (source ONYX Solar) 44 cells / 185Wp 667mm x 2000mm</p>		
<p>BIPV equivalent MODULES (source ONYX Solar) 40 cells / 168Wp 667mm x 2000mm</p>		
<p>BIPV equivalent MODULES (source ONYX Solar) 36 cells / 151Wp 667mm x 2000mm</p>		
<p>BIPV equivalent MODULES (source ONYX Solar) 32 cells / 134Wp 667mm x 2000mm</p>		






**ALBEDO**

- ➔ 20% for surroundings (grass)
- ➔ 50% for building (metal)


**ORIENTATION**

- ➔ +30° from picture interpretation




**HORIZON IN PLANE IRRADIATION** for typical 35° PV angle


- ➔ Masking at winter for PV production




**IRRADIANCE**

TMY data to generate weather file as input for BIMsolar (epw)  
 TMY Period: 2007-2016  
 Time step: hourly





### 3.7.3.4 3D MODELING - SETUP- EXISTING BUILDING



**Figure 3.28: Modelling has been made as much realistic as it could be from the existing 2D plans to address BIPV issues (Trimble SketchUp model from Viridén+Partner)**

### STEP#1-BIMsolar IMPORTATION – Building settings






Figure 3.29: Close and far shadowing calculation are made through 3D modelling of realistic buildings - Sun course for full year is displayed at hourly step time





**Figure 3.30: Albedo effects (reflected irradiance) are generated selecting groups and types of surfaces 20% for surroundings; 50% for the building envelop; 80% for cladding as a general approach**



### 3.7.3.5 Simulation – Results


#### STEP#2-IRRADIATION

We use markers to record and visualize values. We compared 2 versions of the building 3D model: with cladding detail (corrugated surface) and without

Sets of data can be exported in CSV

Corrugated cladding version – Mapping at maximum potential


<p>Global survey on East facade</p> <p>Yearly kWh/sqm</p> <p>Some discrepancies may be due to complex surfaces (corrugated cladding)</p> <p>→1200 kWh/sqm minimum recorded on top row</p>	
<p>Global survey on East facade</p> <p>Direct reception ratio</p> <p>→60% recorded</p>	
<p>Global survey on East facade</p> <p>Average daily irradiance</p> <p>→270 kWh/sqm minimum recorded on top row</p>	



### STEP#3 – BIPV layouts

We use virtual modules set-up from manufacturer’s datasheets (see above) to generate BAPV systems. PV generation, electrical production, shading losses, temperature losses and other performance indicators are calculated in real time from module level to BIPV layout level. Every single module is computed as a system and the software displays individual KPIs.

Detailed results can be obtained at STEP#5 (BIMsolar reference process).





Power:	21.6 kWp
Module area:	152.1 m <sup>2</sup>
Estimated prod.:	19833.5 kWh
Array yield:	917.9 kWh/kWp
Shadow losses:	0.0 %
Heat losses:	9.2 %

Name	Modules
▼ BAPV systems	
ONyx Solar - B...	63
ONyx Solar - B...	27
ONyx Solar - B...	1
ONyx Solar - B...	1
ONyx Solar - B...	1
ONyx Solar - B...	1
ONyx Solar - B...	1
ONyx Solar - B...	1
ONyx Solar - B...	1
ONyx Solar - B...	1

Figure 3.31: Global results – All layouts – V38 version – non tilted BAPV modules




Figure 3.32: Mapping of shading losses – No issue – No significant shading

#### STEP#4 – INVERTERS / WIRING

This step consists in building the best strategy for the implementation of inverters and connect to them the strings of modules to optimise the DC and AC productions.

BIMsolar enables considering the mismatching between modules (gaps in irradiance due to shading effects), then proposes the best wiring configuration for each MPPT to maximise the energy production.

We used this functionality to deliver representative KPIs at pre-study stage before the selection of the final inverter.

For this study, we selected a typical SMA Solar string inverter: Sunny Tripower 15000TL-30




Figure 3.33: Inverter selection and optimized wiring – 1 string inverter / 2 MPPTs

### STEP#5 – RESULTS

BIMsolar offers a comprehensive set of detailed results, from yearly to hourly timestep, covering irradiance, shading losses, heat losses, production, yield... from module level to layout level.

Example:





Figure 3.34: Monthly AC generation + ohmic losses: inverter output

**EAST FAÇADE – Variant 38 - non tilted modules - Table of results:**

<p>IRRADIATION share - Annual GLOBAL BAPV ARRAY</p>	<p>A pie chart illustrating the distribution of irradiation types for the Global BAPV Array. The chart is divided into three segments: a large yellow segment for Direct Irradiation (56.6%), a medium light blue segment for Diffuse Irradiation (30.8%), and a smaller grey segment for Indirect Irradiation (12.6%).</p> <table border="1"> <thead> <tr> <th>Irradiation Type</th> <th>Value (kWh)</th> <th>Percentage (%)</th> </tr> </thead> <tbody> <tr> <td>Direct Irradiation</td> <td>87022 kWh</td> <td>57 %</td> </tr> <tr> <td>Diffuse Irradiation</td> <td>47335 kWh</td> <td>31 %</td> </tr> <tr> <td>Indirect Irradiation</td> <td>19400 kWh</td> <td>13 %</td> </tr> </tbody> </table>	Irradiation Type	Value (kWh)	Percentage (%)	Direct Irradiation	87022 kWh	57 %	Diffuse Irradiation	47335 kWh	31 %	Indirect Irradiation	19400 kWh	13 %
Irradiation Type	Value (kWh)	Percentage (%)											
Direct Irradiation	87022 kWh	57 %											
Diffuse Irradiation	47335 kWh	31 %											
Indirect Irradiation	19400 kWh	13 %											
<p>PV Generation – Shading losses GLOBAL – Year #1 → 19 833 kWh No shading issue Array Yield = 918 kWh/kWp</p>	<p>A pie chart showing the PV Generation results for Year #1. The chart consists of a single blue segment representing Production at 100%, with no shadow loss. The total generation is 19,833 kWh.</p> <table border="1"> <thead> <tr> <th>Category</th> <th>Value (kWh)</th> <th>Percentage (%)</th> </tr> </thead> <tbody> <tr> <td>Production</td> <td>19833 kWh</td> <td>100 %</td> </tr> <tr> <td>Shadow loss</td> <td>0 kWh</td> <td>0 %</td> </tr> </tbody> </table>	Category	Value (kWh)	Percentage (%)	Production	19833 kWh	100 %	Shadow loss	0 kWh	0 %			
Category	Value (kWh)	Percentage (%)											
Production	19833 kWh	100 %											
Shadow loss	0 kWh	0 %											





DC Production (Inverter IN)

Year #1 = 17 061 kWh

Losses (strings)

Significant mismatch losses  
(from wiring)





### 3.7.4 Summary of the results

	Array				Inverter				Yield			
Unit	kWh	degree		kWh	kWh	kWh	%	kWh	kWh/kWp			
	Irradiation		Panel orientation		PV generation		DC inverter IN		Losses		AC inverter OUT	AC inverter OUT
	East facade		Azimet*	Tilt	East facade	East facade	East facade	East facade	East facade	East facade	East facade	East facade
Direct	87 022	East	-60,0	90,0	19 833,0	17 061,0	273	1,6%	16 788,0	776,0		
Diffuse	47 335											
Indirect	19 400											
	153 757,0		*South = 0°		19 833,0	17 061,0	273,0	0,0	16 788,0	776,0		
<b>TOTAL:</b>	<b>153 757,0</b>				<b>19 833,0</b>	<b>17 061,0</b>			<b>16 788,0</b>		<b>MEAN VALUES</b>	

### 3.7.5 Conclusions

At the current stage of the validated performance of the software and provided the fact that products and project are submitted to updates we consider that the first results are exploitable and converging towards performance expectations. Even if we did not face critical difficulties in the process, discussions must be engaged to fix the electrical strategy so to work in detail on the string/inverter calculation. Some key points about this pre-study:

- East façade (before modules integration) is homogeneous regarding irradiance mapping. Simulation seems to perform correctly, with 10 years based Typical Meteorological Year file from PVGIS,
- No shading issues, no irradiation mismatching,



- Direct reception ratio seems correct (60%),
- Array yield: 918 kWh/kWp,
- PV generation seems to be quite well balanced within a full year period (January production is 43.5% of August),
- The AC production could be optimized with a stronger strategy mitigating the mismatching for strings and more technical studies on the inverter side. Final yield is 776 kWh/kWp.

Next steps will be:

1. Update of the building 3D model, related to final and detailed BIPV studies (demo site manager + partners),
2. Implementation of COLOURED BIPV modules expert configurator and simulation models (T6.3) into BIMsolar,
3. Final set up of the modules and the mounting structure following ONYX Solar and TULIPPS manufacturing specifications,

**Comparison between measurement and simulation as soon as the real modules will be integrated**

### 3.8 PLANNING TIMELINE

Below is the planning timeline for the MASS demonstration site at the time of writing. The Gantt chart is a living document and available via the BIPVBOOST shared platform.




Figure 3.35: MASS Demo-site Gantt Chart

## 4 DEMO SITE 3: OPTIMAL

### 4.1 DEMO-SITE BUILDING DESCRIPTION

#### 4.1.1 Building description

The house is in Belgium, Saint-Denis (close to the town of Mons), which is located close to the French border (Lat. 50°28'). The building is a residential family house for a family of 5 persons constructed in 1997 (Figure 4.2). Next to this building there is a small office and a kitchen room added in 2011 (Figure 4.313). The main house is constructed in blocs and bricks while the office is constructed in wood with a beam structure and a very good insulation level with triple glazing.



Figure 4.1: Google and CAD view of the whole building

The building is connected to the electrical public grid network with a single-phase connection and a 40 A meter. The building is also connected to the gas network in order to feed the gas boiler.

#### 4.1.2 General topology

The external dimensions of the main house are 13.4 m long and 8.8 m wide resulting in a ground floor area of 118 m<sup>2</sup>. At the first floor the area is a little bit smaller and equal to a value of 92.4 m<sup>2</sup>. The dimensions of the added rectangular office are 10 m long and 4.3 m wide providing a ground floor area of 43 m<sup>2</sup>. The kitchen room area is 17 m<sup>2</sup>. Therefore, the total floor area of the building including the external walls is 270 m<sup>2</sup>.

The house contains a cellar and ventilated room of smaller height under its total surface making it an ideal place to install the batteries. There is a good technical connection between the roof and the cellar in order to place the wiring between the roof and the batteries including any monitoring devices.



Figure 4.2: Picture of the house with the front view (left) and the back view (right)



Figure 4.3: Picture of the office next to the house (left) and top view of the whole building (right)

### 4.1.3 Grid connection & Equipment

The building is connected to the electrical public grid network with a 2 phases connection and a 40 A meter. The building is also connected to the gas network in order to feed the gas boiler. In order to support the increased power brought by the BIPVBOOST panels, the general meter will require to be upgraded to 3 phases connection of a power of 13,9 kVA.

The **main building** is equipped with 2 heating systems: a gas boiler of a power of 21 kW to heat the water radiator and to produce the Domestic Hot Water (DHW). The building is also equipped with a HVAC air/air HP of a power of 8 kW and capable to heat or cool the main house building. This HVAC in the main building is controllable. This will require to buy a device making the interface between BEMS system and the HVAC equipment. The internal HVAC unit is a Toshiba RAV-SM806BTP-E and an interface IntesisBox TO-RC-KNX-1i or similar (IntesisBox TO-RC-MBS-1 or IntesisBox TO-RC-BAC-1).

The **office** attached to the main building is equipped with a small HVAC Heat Pump (HP) capable to produce heat in winter and to cool the office in summer. The power of this HP is 2.5 kW. This HP cannot be controlled.

This setup offers various possibilities to control the building temperature mainly by using either the HVAC of 8 kW or the gas boiler to heat the main house.

In the scope of the BIPVBOOST project, this demonstration site will be equipped also with electric batteries.

There are already PV panels: 3.5 kWp on the west roof slope and 1.4 kWp on the flat roof next to the main building. The plan is to replace the one on the roof slope (3.5 kWp) with the one coming from BIPVBOOST.

#### 4.1.4 Energy consumption

The electricity contract is a dual Day and Night meter. The night schedule is from 10pm until 7 am and also includes the weekend. The electricity tariff increased a lot in the last year. In 2016, the 'Night' tariff was around 4 c€ / kWh and the 'Day' tariff was around 7 c€ / kWh. In 2017, the 'Night' tariff was around 5 c€ / kWh and the 'Day' tariff was around 6.5 c€ / kWh. Additionally, there are also other costs to be added: the network cost (including the distribution and transportation costs), the fixed cost and the green energy cost.

For the gas, the price was between 2.2 c€ and 2.4 c€ / kWh (2017), while it was 1.8 c€ in 2020. As for the electricity there is also several other cost such as the network cost (including the distribution and transport costs) and a fixed cost in addition

The history of electrical consumptions of the house is available for many years. An extract of these available data is provided in **Figure 4.4**. A second table is provided containing the daily measure of the current building during the month of December 2017 (Figure 4.5).

DUAL RATE METER			
Year	Yearly Total Consumption (kwh)	Yearly 'Day' Consumption (kwh)	Yearly 'Night' Consumption (kwh)
2020	8198	4186	4012
2019	8144	4433	3711
2018	8164	4440	3724
2017	8941	4934	4007
2016	6442	3259	3184
2015	6049	3078	2970
2014	5839	3255	2583
2013	6143	3368	2774
2012	6589	3760	2829
2011	5166	3059	2107
2010	3869	2167	1702
2009	4126	1911	2215
2008	3542	1490	2052
2007	3687	1702	1985

Figure 4.4: Yearly electrical consumption of the house

Date	Day	Total Building			House		Office				Weather
		Electricity 'Day' [kwh]	Electricity 'Night' [kwh]	Electricity Total [kwh]	Gas [m <sup>3</sup> ]	Electricity All Consumption [kwh]	Electricity All ([kwh]	Electricity Light [kwh]	Electricity Plugs [kwh]	Electricity HVAC [kwh]	External temperature [°C]
3/12/17 15:30	Sunday	0,7	11,5	12,2	4,2	8,2	4	0	4	0	0
4/12/17 8:00	Monday	21,6	5,3	26,9	4,1	13,9	13	1	8	4	1
5/12/17 9:30	Tuesday	16,3	5,1	21,4	5,2	11,4	10	0	8	2	4
6/12/17 7:30	Wednesday	18,3	6,9	25,2	5,8	13,2	12	1	8	3	6
7/12/17 8:30	Thursday	16,3	6,0	22,3	3,8	11,3	11	1	8	2	4
8/12/17 8:00	Friday	15,7	6,0	21,7	6,6	13,7	8	0	6	2	3
9/12/17 8:30	Saturday	0,0	17,2	17,2	10,3	11,2	6	0	5	1	-1

Figure 4.5: Measure of daily electrical and gas consumption of the current building

#### 4.1.5 BIPV system to be installed

BIPV panels will be installed on the roof of the main building (residential house). This will consist of metal-based roofing shingles. The product will be the FLISOM CIGS module with Schweizer roof structure. The implementation will consist of a retrofitting of the current roof.

There are 2 slopes to the roof one with an orientation East and one with an orientation West. The dimension of each slope of the roof are 5.84 m large by 13.8 m long resulting in an area of  $2 * 80.5 \text{ m}^2 = 161 \text{ m}^2$  for the 2 roof slopes. From this surface, the useful area must be reduced by the ridge, the 5 roof windows, and the chimney. This provides a useful area between 140 and 150  $\text{m}^2$  to setup the PV panels. The new panels will be installed on both roof slopes.




Figure 4.6: Cross section of the house showing the roof slope and dimensions

#### 4.1.6 Monitoring system

As of 2019, before the project starts, there is no monitoring system installed in the house. Setting up the monitoring system will be part of the BIPVBOOST project.

The house is equipped with a normal residential internet connection. So, it will be possible to access or push data outside.

Regarding the weather data, there is a weather station on the residential house in Belgium used during the BFIRST project. The distance between the houses is about 4 km.



## 4.2 ARCHITECTURAL BIPV DESIGN

### 4.2.1 Existing demo-site building



Figure 4.7: Demo-site 3 building, east and west side

Table 4.1: Available roof area

	Roof east	Roof west	Total roof
Roof area (m <sup>2</sup> )	81.48	79.23	160.71
Obstacles (m <sup>2</sup> )(roof windows, chimney, canopy)	6.46	5.91	12.38

### 4.2.2 Architectural BIPVBOOST Design Options

Two initial possible design options have been elaborated with different objectives. The first one foresees to maximize the power of the installation (10.2 kWp) while the second one tries to have the best possible architectural integration, while slightly scarifying PV performance (9.3 kWp).

Moreover, for the maximum power option, three different scenarios have been established and studied in detail.

In these scenario, 3 types of panel format have been used. They are called 1V, 2V and 3V. They are approximatively 1 unit large, 2 unit large and 3 unit large.

#### 4.2.2.1 Design option 1.1 (“Max Power”)

This option is represented in Figure 4.8. In this scenario 2V modules are mainly used because they offer the best compromise between maximizing the cell area per roof surface area. These 2V modules are completed by 1V modules in order to fill in as much as possible the usable roof surface. The number of each type of module is summarized in Table 4.2. The total power of this configuration is 10.2 kW.

#### 4.2.2.2 Design option 1.11 (“Max Power”)

With the option (Figure 4.9: Scenario 1.11 (Max power).: East (top), West (bottom), one row of 1V panel is added inside the east roof and 2 rows of 1V panel on the west roof in order to gain a little more power. The total power is 10.38 kW.

#### 4.2.2.3 Design option 1.12 (“Max Power”)

This option (Figure 4.10) is identical to the previous one except that no active panels are placed on the east roof in the small triangular part in the centre. The total power is 10.26 kW.

#### 4.2.2.4 Design option 1.2 (“Max Power”)

With the option (Figure 4.11), 3V panels are used in order to check if the panels offering the highest power density but smaller geometrical flexibility could bring more power. However, the total power is smaller than the previous options mainly because spaces is lost on the left and right part of the roof slopes. The total power is 9,81 kW.

#### 4.2.2.5 Design option 2 (“Best architectural integration”)

The two inclined roofs are completely implemented in the roof area with frameless modules (Figure 4.12). With the color-coordinated sheet steel, profiles and modules, the roof can be perceived as a total area. With dummy modules, the remaining areas can be connected to the existing skylights and the chimney as well as the porch.

Option 2, unlike option 1, is based on two types of modules. The main part of the roof area is provided with the narrow, vertical module types (1V). Only on the edge do the broad module types occur. By this division, a uniform image is generated, despite the different location of the existing skylights, which cut through the roof surface. The total power is 9.42 kW.

**Table 4.2: Summary of panel placement options and their power**

	East				West				Total
	1V modules	2V modules	3V modules	kWp	1V modules	2V modules	3V modules	kWp	
Option 1.1	15	80	0	5,25	11	77	0	4,95	10,2
Option 1.11	12	83	0	5,34	22	73	0	5,04	10,38
Option 1.12	12	81	0	5,22	22	73	0	5,04	10,26
Option 1.2	6	23	41	5,25	9	16	37	4,56	9,81
Option 2	162	0	0	4,86	144	4	0	4,56	9,42
Option1.11 (refined)	24	75	0	5,22	19	70	0	4,77	9,99





Figure 4.8: Scenario 1.1 (Max power). East (top), West (bottom)






Figure 4.10: Scenario 1.12 (Max power). Alternative option for the East roof





Figure 4.11: Scenario 1.2 (Max power). East (top), West (bottom)






Figure 4.12: Scenario 2 (Architectural Design). East (top), West (bottom)

### **4.2.3 Detailed selected architectural design**

#### **4.2.3.1 Final Design**

All these scenarios present preliminary designs of different options. However, the final setup requires to consider placing flashing material at the top, the edge, the bottom and in the small triangular part of the east roof.

The evaluation of buying and installing the panels together with the flashing material all around the panel perimeters was then performed (Figure 4.13). The cost of buying the flashing material is evaluated to 10000 € while the labour cost is 4800 €. This was evaluated based on a cost per square meter rule of the flashing material provided by the local architect.

This makes the cost of the flashing material quite expensive and therefore it was decided to minimize this cost as much as possible. The solution was to use dummy panels as much as possible and to use 2V panels equipped with only one active cell in order to be able to 'cut' these specific dummy panels at the exact dimension. These panels will be produced on specific dimension in order to provide a proper overlap with the sheeting of the roof windows. Only the special shapes around the chimney and the bay will be cut on site. Also, dummy panels or onsite flashing will be used at the junction between the panels surface and the bottom gutter. This will reduce a lot the extra cost of the flashing material required initially.

This leads to the final design presented in Figure 4.14. This setup has a power of 9.99 kWp. The power is a little smaller than the initial option 1.11 (10.38 kWp) but it will reduce the cost of the flashing material required around the panel surface.

Turn-key installation quotation for a demo-site							
	Common	Scenario 1.1	Scenario 1.11	Scenario 1.12	Scenario 1.2	Scenario 2	
1. Materials		Price [€]	Price [€]	Price [€]	Price [€]	Price [€]	Remarks
<b>1.0 Removing / preparing</b>							
Setup + security	1000						
Removing existing tiles + removing underlayer + removing underlating (*)	2000						
New wood sub-structure (*)	2000						Is the underlating different for one Scenario to another?
New sublayer (*)	1500						
Gutter placed back (*)	500						
1.1 Fastening and mounting system (FCA Switzerland)		1.563,96	1.581,29	1.581,29	1.356,36	1.622,95	Structure not included: Structure provided by TULIPPS/SCHWEIZER. Battery limits of provided material to be defined.
1.2 BIPV modules (FCA Switzerland)		46.469,44	47.257,16	47.257,16	45.107,13	49.921,32	Modules not included: Modules provided by ONYX/FLISOM/PIZ. Battery
1.3 Cabling							This is an <b>actual cost for CC Cable only</b> . Total cost can only be calculated after finalization of the electrical design for demosite. This Based on Fronius Galvo solution (inverter with transformer): 2 * 3 kWp inverters
1.4 Inverters	2000						Cabling included. Monitoring equipment not included: Monitoring equipment to be provided by TECNALIA. Battery limits of provided
1.5 Monitoring system							We can provide this information only after the choice of right scenario Budget of 6000 € for the batteries and 3000 € for the inverter
1.6 Electrical installation materials	500						
1.7 Battery System	9000						
<b>1.8 Flashing + Velux windows (*)</b>		<b>10.000,00</b>	<b>7.500,00</b>	<b>10.000,00</b>	<b>10.000,00</b>	<b>10.000,00</b>	<b>There will be some difference in material surface and therefore on material cost but cannot be determined at this stage. Estimated to</b>
<b>MATERIALS SUBTOTAL</b>	<b>18500</b>	<b>58.033,39</b>	<b>56.338,45</b>	<b>58.838,45</b>	<b>56.463,50</b>	<b>61.544,27</b>	
<b>Lab</b>							
2. or		Price [€]	Price [€]	Price [€]	Price [€]	Price [€]	Remarks
2.1 Permit obtaining	250						This is an Estimated Cost.
2.2 Detailed Executive Project							We can provide this information only after the choice of right scenario.
2.3 Structural and mechanical installation		3.200,00	3.200,00	3.200,00	3.200,00	4.000,00	We can provide this information only after the choice of right scenario. Estimated to 4 days / 2 persons + 25% for the option 2
2.4 Electrical installation	1600						Estimated to 1 day, 1 person + Upgrade of the GRD connection
2.5 Certification of the installation	250						
2.6 Operation and Maintenance (optional)							
<b>2.7 Flasing + Velux windows</b>		<b>4.800,00</b>	<b>4800</b>	<b>4800</b>	<b>4800</b>	<b>4800</b>	<b>Estimated to 6 days / 2 persons</b>
<b>LABOR SUBTOTAL</b>	<b>2100</b>	<b>8.000,00</b>	<b>8.000,00</b>	<b>8.000,00</b>	<b>8.000,00</b>	<b>8.800,00</b>	
<b>TOTAL TURN-KEY INSTALLATION:</b>		<b>20.600,00 €</b>	<b>66.033,39 €</b>	<b>64.338,45 €</b>	<b>66.838,45 €</b>	<b>64.463,50 €</b>	<b>70.344,27 €</b>

Figure 4.13: Cost evaluation




Figure 4.14: Final design

This final design also considers the following details (which might still get slightly modified until the final production):

- The details in order to place the Velux flashing material and how the panels are connected at the top, the bottom (Figure 4.15, Figure 4.16) and the side of the Velux (Figure 4.17)
- the placement of the roof top (Figure 4.18)
- The junction of the panels with the bottom gutters (Figure 4.19)
- The design of the triangular part of the east slope
- The design of the roof edge (Figure 4.20)




Figure 4.15: Junction details at the top of the Velux




Figure 4.16: Junction details at the bottom of the Velux






Figure 4.17: Junction details on the side of the Velux




Figure 4.18: Ridge details






Figure 4.19: Details at the bottom junction with the gutter




Figure 4.20: Details at the side edge of the roof

Finally, a summary of all the type of features and type of panels are summarized in




Figure 4.21: East roof details




Figure 4.22: West roof details

The building permit was obtained in August 2020 (Figure 4.23).






Figure 4.23: Building permit

### 4.3 BIPV STRUCTURE DESIGN

#### 4.3.1 Existing building structure (roof)

The basic roof structure consists of a wooden beam structure overarching the walls of the building. The roof structure seems to be around 200 mm thick. The insulation sits within the vertical beams and is covered and protected by a plastic sheet (see Figure 4.24 and Figure 4.25)



Figure 4.24: Existing roof structure of Demo-site 3

The lath for the tiles is 30 mm in height and with the same width (see Figure 4.25). At the eaves lead the tiles lead directly into the gutter.



Figure 4.25: Details at the eaves of Demo-site 3 roof.

### 4.3.2 BIPVBOOST roof/tile structure

It has been decided by the Demo-site owner, that the basic structure of the roof should not be changed (e.g. additional insulation). However, the roof structure for mounting Solrif® based BIPV roof modules will require some changes to the original roof structure:

- Width of the tile lath: Must be 100 mm in order to mount the clamps for the modules.
- The protective plastic sheet must withstand 80°C, otherwise it must be changed.
- The detail at the eaves to the gutter must be adapted (detail see proposal Viridén + Partner).




Figure 4.26: Vertical section detail eaves and gutter.

## 4.4 BIPV MODULE DESIGN

For cost reasons, the largest possible PV module size should be used for BIPV complete roofs. For small roofs and roofs with obstacles, this is often a challenge in terms of layout. Large modules often lead to too much unused roof area.

It has been shown that by using a "module family" with two to three compatibles, but differently sized modules, the flexibility for the complete roof covering is significantly greater and thus the roof surfaces can be optimally used for solar power.

### 4.4.1 BIPVBOOST module/s

In the framework of BIPVBOOST WP4 (T4.2) two module families have been developed. They differ in the orientation of the CIGS subcells (vertical/portrait and horizontal/landscape).




Figure 4.27: Structural design of the CIGS on metal roof module families (vertical and horizontal oriented CIGS subcells)

#### 4.4.2 BIPVBOOST module/s electrical Design

<b>Solrif® CIGS on metal BIPV roof modules</b>			Version			5.1 (7.9.2020)		
Module Type			1x1H	2x1H	1x1V	2x1V	3x1V	
<b>Dimensions</b>								
Width total	LhorTotal [mm]		870	1700	487	888	1270	
Height total	LverTotal [mm]		462	462	853	853	853	
Width grid	RhorTotal [mm]		852	1682	469	870	1252	
Height grid	RverTotal [mm]		430	430	821	821	821	
Thickness at module frame	[mm]				17			
Thickness at J-Box	[mm]				23 ± 1			
Weight (preliminary estimation)	[kg]		4.0	7.0	4.0	7.0	10.0	
area (based on layout grid)			0.4	0.7	0.4	0.7	1.0	
<b>Electrical characteristics at STC<sup>1</sup></b>								
Nominal Power	P <sub>MPP</sub> [W]		30	60	30	60	90	
Short Circuit Current	I <sub>SC</sub> [A]		0.97	1.91	0.97	1.94	2.91	
Open Circuit Voltage	V <sub>OC</sub> [V]		46	48	46	46	46	
MPP Current	I <sub>MPP</sub> [A]		0.88	1.66	0.88	2x0.88	3x0.88	
MPP Voltage	V <sub>MPP</sub> [V]		34	36	34	34	34	
Solar Cell Efficiency (subcell)	η <sub>c</sub> [%]				12			
Module Efficiency	η <sub>m</sub> [%]		9.1	9.2	8.7	9.4	9.8	
Power Output Tolerance					-0%/+5%			
Maximum Reverse Current					10 A			
Maximum System Voltage					1000 V			

Figure 4.28: Preliminary datasheet of the CIGS on metal modules, part 1

<b>Thermal characteristics</b>								
Temperature coefficient	Voc [%/°C]				-0.3			
Temperature coefficient	Isc [%/°C]				0.01			
Temperature coefficient	PPmpp [%/°C]				-0.35			
<b>Operating conditions</b>								
Temperature range	[°C]				-40 to 85			
Max. mechanical load [Pa]					open			
<b>Additional data</b>								
Cell type			CIGS					
Junction Box			Back side including bypass diode, IP 67, MC4 type / MC4 connectors STC1					
No. of junction boxes			1	1	1	2	tbd	
Cable length (4mm <sup>2</sup> )	[mm]		tbd	tbd	900	900	tbd	
Encapsulation			Fluoropolymer front sheet / back plate: aluminium 3 mm black anodized					
<b>Warranty &amp; certification</b>								
Performance guarantee			10 years on 90% of Pmpp under STC1 and 20 years on 80% of Pmpp under					
Warranty			5 years' workmanship after delivery date					
Certification			EN IEC 61646; EN IEC 51730-1 & 2					
Fire safety class			according to hard roofing (B root T1, Euroclass) (attempted)					

Figure 4.29: Preliminary datasheet of the CIGS on metal modules, part 2

Note: The fire safety tests need to be performed prior to the final design and production of the Demo-site 3 installation.



## 4.5 BIPV ELECTRICAL SYSTEM DESIGN

In this section the choice of the inverter, the panels connection wiring, and the electric board will be described.

However, first it is important to review the current existing legislation in Belgium which will drive some of our choices hereafter.

As now (2021), the electricity can be injected back on the public network and the main general meter counts in the reverse side when the electricity is injected into the public network. However this is changing and it is becoming mandatory to install a general meter that will count both the energy used from the network and the energy feed in into the network. Based on this new meter and new regulation, there will be 2 options to pay the energy bill:

(1) The first option will be to pay a flat tax depending on the installed power together with the net consumption (energy taken from the network minus energy feed in into the network). This flat tax is based on the minimum of the following 2 powers: panels installed power and inverter total power. So a good solution to minimize the cost of this scenario is to minimize the power of installed inverters.

(2) The second option will be to pay only the energy taken from the network. In that case the electricity feed in to the network is not at all taken into account for the bill. This energy is sent completely free to the energy provider.

Based on the power that is scheduled to be installed using the BIPVBOOST panel (10.8 kWp) and the installation of batteries, it is very strongly desired to base the future scenario on the option (2) and to minimize the energy taken from the public network.

This will put a large pressure on self-consumption for the Belgian demonstration site.

### 4.5.1 PV Inverter

The design of the electrical system is not an easy task for the Optimal demonstration site. This is because this design must meet several constraints. The 3 major ones are summarized here after:


1. In order to be considered as a prosumer in Belgium the size of the installed inverters must not exceed 10 kWp. If the power of inverters (sum of all inverter installed) exceeds this limit, the installation is considered as a producer. Being a producer imposes to face additional administrative tasks. As stated in section 4.1.6 there are already 2 inverters installed (1.4 kWp and 3.5 kWp). This leaves 'only' the possibility to install an additional inverter of 5.1 kWp (if the building must remain prosumer).
2. The second point is the new TAX imposed since the end of 2020 as summarized in 4.5. Going for the flat TAX based on the installed PV power would lead to an annual TAX of around 1200 € which is probably as much as the energy saving price. This is not an option. As stated in that section, the goal is to minimize the cost of exploitation of the PV installation and therefore to limit the TAX imposed on the PV inverter power. To achieve that a new meter will be set up that is capable to measure the electricity consumed from the network and the electricity fed into the network. Having that will allow to pay 'only' for the electricity that is consumed from the public network.
3. Installing inverter for a total peak power between 5 and 10 kWp imposes to use a tri-phase electricity supply although the building is currently equipped with a single-phase supply.
4. Having CIGS modules has some consequences on current leaks imposing to make sure that the inverter has a good galvanic insulation.

For the first constraint here above, there are several possible scenarios:

1. Being a producer and therefore do not consider the limit of 10 kWp for the total power of all inverters.
2. Install an inverter < 5.1 kWp
3. Replace the existing inverter with slightly lower power in order to be able to use an inverter of or around 6.0 kWp for the BIPVBOOST panels.

However, the specificity of this demonstration site is that the panels are almost equally distributed on 2 roof slopes having 2 orientations at 180 deg. (East and West). This means that the panels production on each slope will not be maximum at the same time. The East roof will have its maximum peak power around 10-11 am while the west side around 14-16 pm. Moreover, none of the slope are oriented towards the South meaning that the peak power will never reach the theoretical maximum power of the panels.

This means that the total daily production of the field will be smaller than for an equivalent south oriented field of PV panels. However, this also means that the electricity production will start earlier in the morning and will produce more in the evening than for a south oriented field (Figure 4.30). Therefore, this offers the possibility to install an inverter of lower peak power than the 9.9 kWp of the PV systems.



**Figure 4.30: Comparison PV Field South and East-West oriented (from Fronius: "Efficient East-West Oriented PC Systems with one MPP tracker")**

The East-West orientation could suggest installing one inverter per roof slope. However, that would mean to install 2 inverters of around 3 to 4kWp each leading to 6 - 8 kWp. That would not allow to reach the limit of 10 kWp of installed capacity.

However, installing only one inverter (with one or 2 MPPT entry) will allow to use a lower max power inverter. Some simulations have been performed while design the roof set up. These simulations were performed during the first year project in order to validate the concept and to forecast the electricity meter adaptation. These simulations were performed with PVSyst free edition. The first simulation uses 2 inverters of 3kWp, one for each roof slope. The second configuration study the use of a single inverter of 5 kWp for both roof slopes. For these simulations we have considered 170 1V panels on the west roof and 160 1V panel on the West roof. The main results are:

- For the 2 inverters case (2\*3 kWp):
  - Electricity produced in one year = 3'282 + 4'259 = 7'541 kWh
  - Losses due to overpower inverter east: 4.36 %
  - Losses due to overpower inverter west: 4.75 %
- For the 1 inverter case (5 kWp):
  - Electricity produced in one year: 7'270 kWh
  - Losses due to overpower : 7,49%

This simulation shows that there are only 3.5 % of different in the annual electricity amount produced. However, in the simulation, it can be noted that on the single inverter case, there are 8.65% losses called "Global incident on the plane of the PV cells". This is not clear in this output and we could not figure out the meaning for that.

On the page 3 bottom, of the 3 simulations, it can be noted that there are some productions which are lost due to the overpower of the PV production compared to the power of the inverter. This is particularly visible for the 2 inverters case.

These simulations allow to validate the possibility to use a single inverter of a lower total power without losing annual production.

The search for inverters was not an easy task for the reasons exposed above and because it was required to have first the final count of the number of PV panels installed on each slope of the roof.

Based on the precise definition of the panels presented in section 4.2.3.1 a first price request was performed to a reseller of SMA inverters. This was also important for us to have a third-party validation of our design and conclusions. This reseller proposes us to use SMA STP4.0 or STP5.0 inverters (Figure 4.33). The Figure 4.31 shows that with 170 1V equivalent panels on the east roof slope and 154 1V equivalent panels on the west roof slope, the total annual production is 7 772 kWh so even better than with our simulation above.





Figure 4.31: SMA simulation provided by a third-party SMA reseller.

Another aspect that must also be taken into account is the string connection. In the simulation above, each string was composed of 9 x 1V equivalent panels. So the East roof is composed of 17 strings and the West roof of 14 strings. This leads to 170 / 174 panels used on the East roof and 154/159 panels on the West roof.

The options to connect the panels together, to create string are calculated on the Figure 4.32: Options to connect the panels and design the strings

Number of cells per string	Options to design the Strings											
	9	10	11	12	13	14	15	16	17	18	19	20
	<b>East Face</b>											
Total number of 1V modules	<b>174</b>											
Number Strings	19	17	15	14	13	12	11	10	10	9	9	8
Total number of connect 1V panels	171	170	165	168	169	168	165	160	170	162	171	160
Unconnected panels	-3	-4	-9	-6	-5	-6	-9	-14	-4	-12	-3	-14
Nominal Power (W)	5130	5100	4950	5040	5070	5040	4950	4800	5100	4860	5130	4800
Short Circuit Curren (A)	18,4	16,5	14,6	13,6	12,6	11,6	10,7	9,7	9,7	8,7	8,7	7,8
Open Circuit Voltage (V)	414	460	506	552	598	644	690	736	782	828	874	920
MPP Current (A)	16,7	15,0	13,2	12,3	11,4	10,6	9,7	8,8	8,8	7,9	7,9	7,0
MPP Voltage (V)	306	340	374	408	442	476	510	544	578	612	646	680
	<b>West Face</b>											
Total number of 1V modules	<b>159</b>											
Number Strings	17	15	14	13	12	11	10	9	9	8	8	7
Total number of connect 1V panels	153	150	154	156	156	154	150	144	153	144	152	140
Unconnected panels	-6	-9	-5	-3	-3	-5	-9	-15	-6	-15	-7	-19
Nominal Power (W)	4590	4500	4620	4680	4680	4620	4500	4320	4590	4320	4560	4200
Short Circuit Curren (A)t	16,5	14,6	13,6	12,6	11,6	10,7	9,7	8,7	8,7	7,8	7,8	6,8
Open Circuit Voltage (V)	414	460	506	552	598	644	690	736	782	828	874	920
MPP Current (A)	15,0	13,2	12,3	11,4	10,6	9,7	8,8	7,9	7,9	7,0	7,0	6,2
MPP Voltage (V)	306	340	374	408	442	476	510	544	578	612	646	680

Figure 4.32: Options to connect the panels and design the strings



Caractéristiques techniques	Sunny Tripower 3.0	Sunny Tripower 4.0	Sunny Tripower 5.0	Sunny Tripower 6.0
<b>Entrée (DC)</b>				
Puissance max. du générateur photovoltaïque	6000 Wc	8000 Wc	9000 Wc	9000 Wc
Tension d'entrée max.	850 V	850 V	850 V	850 V
Plage de tension MPP	140 V à 800 V	175 V à 800 V	215 V à 800 V	260 V à 800 V
Tension d'entrée assignée		580 V		
Tension d'entrée min. / tension d'entrée de démarrage		125 V / 175 V		
Courant d'entrée max. entrée A / entrée B		12 A / 12 A		
Courant de court-circuit max. entrée A / entrée B		18 A / 18 A		
Nombre d'entrées MPP indépendantes / strings par entrée MPP		2 / A:1; B:1		
<b>Sortie (AC)</b>				
Puissance assignée (pour 230 V, 50 Hz)	3000 W	4000 W	5000 W	6000 W
Puissance apparente AC max.	3000 VA	4000 VA	5000 VA	6000 VA
Tension nominale AC		3/N/PE; 220 V / 380 V 3/N/PE; 230 V / 400 V 3/N/PE; 240 V / 415 V		
Plage de tension AC		180 V à 280 V		
Fréquence du réseau AC / Plage		50 Hz / 45 Hz à 55 Hz 60 Hz / 55 Hz à 65 Hz		
Fréquence de réseau assignée / tension de réseau assignée		50 Hz / 230 V		
Courant de sortie max.	3 x 4,5 A	3 x 5,8 A	3 x 7,6 A	3 x 9,1 A
Facteur de puissance à la puissance assignée / facteur de déphasage réglable		1 / 0,8 inductif à 0,8 capacitif		
Phases d'injection / Phases de raccordement		3 / 3		
<b>Rendement</b>				
Rendement max. / Rendement européen	98,2 % / 96,5 %	98,2 % / 97,1 %	98,2 % / 97,4 %	98,2 % / 97,6 %
<b>Dispositifs de protection</b>				
Dispositif de déconnexion côté entrée		•		
Surveillance du défaut à la terre / surveillance du réseau		• / •		
Protection inversion de polarité DC / résistance aux courts-circuits AC / séparation galvanique		• / • / -		
Unité de surveillance du courant de défaut, sensible à tous les courants		•		
Classe de protection (selon IEC 61140) / catégorie de surtension (selon IEC 60664-1)		I / III		
<b>Caractéristiques générales</b>				
Dimensions (L/H/P)	435 mm / 470 mm / 176 mm (17,1 pouces / 18,5 pouces / 6,9 pouces)			
Poids	17 kg (37,4 lb)			
Plage de température de fonctionnement	-25 °C à +60 °C [-13 °F à +140 °F]			
Émissions sonores, typiques	30 dB(A)			
Autoconsommation (nuit)	5,0 W			
Topologie / Système de refroidissement	Sans transformateur / Convection			
Indice de protection (selon IEC 60529)	IP65			
Classe climatique (selon IEC 60721-3-4)	4K4H			
Valeur maximale admise pour l'humidité relative de l'air (sans condensation)	100 %			
<b>Équipement</b>				
Raccordement DC / raccordement AC	SUNCLIX / fiche AC			
Affichage via smartphone, tablette, ordinateur portable	•			
Interfaces : WLAN / Ethernet / RS485	• / • / •			
Protocoles de communication	Modbus (SMA, Sunspec), Webconnect, SMA Data, TS4-R			
Gestion de l'ombrage : SMA ShadeFix (intégrée) / TS4-R	• / ○			
Garantie : 5 / 10 / 15 ans	• / ○ / ○			
Certifications et homologations (autres sur demande)	AS 4777, C10/11, CE, CEI 0-21, DIN EN 62109-1/IEC 62109-1, DIN EN 62109-2/IEC 62109-2, EN 50438, G59/3, GB3/2, NEN-EN 50438, ÖVE / ÖNORM E 8001-4-712, FPD5, PPC, RD 1699, SI 4777, TR 3.2.1, UTE C15-712, VDE-ARN 4105, VDE0126-1-1, VFR 2014, RIG compliant, DEWA 2016, EN 62116, IEC 61727, IECEN 50438, NBR 16149, NRS 097-2-1			
Certifications et homologations (en projet)				
Pays de disponibilité de SMA Smart Connected	AU, AT, BE, CH, DE, ES, FR, IT, LU, NI, UK			
Désignation du type	STP3.0-3AV-40	STP4.0-3AV-40	STP5.0-3AV-40	STP6.0-3AV-40

Figure 4.33: SMA Sunny Tri-power



## **4.6 BIPV MONITORING DESIGN**

### **4.6.1 Definition of monitoring objectives: BIPV performance validation, economic viability and progress towards NZEB requirements**

As mentioned earlier in this document, Optimal demo site will be equipped with a BIPV roof retrofitting and new BEMS system that will optimise the thermal inertia use of the building, the optimal use of produced energy by shifting some loads and optimal use of batteries. The objective of the monitoring system is to measure and verify the effect of this implantation in the overall building performance. In this context the energy performance is understood as the non-used energy (energy savings), the self-consumption ratio, the reduction in the energy bill and the performance ratio. Next, the implementation of the monitoring system is presented.

### **4.6.2 Definition of variables to be monitored**

In order to demonstrate the project objectives, the monitored variables have been selected following the monitoring guidelines defined in Deliverable 8.3. The following Figure 4.34 shows the variables to be monitored, and the Table 4.3 summarises the measured variables, instruments and required accuracies. These variables have been divided in two-time steps, the pre-intervention (Inside the Blue box in Figure 4.34) period and the post intervention period (inside the red box in Figure 4.34). As can be seen the selected variables are related with the energy balance of the demo; energy production (by the existing PV field and the one to be installed), the energy consumption from the grid, energy consumed by HVAC system, gas boiler and movable charges and meteorological data.

The variables of the pre-intervention period are being measured since August 2020 and the post-intervention variable will be monitored after the new BIPV roof and BEMS interventions have been carried out.




Figure 4.34. Measured variables on optimal demo site. In Blue the variables measured during the preintervention period and in red the variables that will be also measured during the postintervention period.

Table 4. 3. Optimal demo site variables measurement information: required instruments, range, units, Time resolution and accuracy

Variable		instrument	Range	Units	Time Resolution	Accuracy
<b>BIPV components</b>						
<b>Roof retrofiting</b>						
<b>Meteo</b>						
$G_{irr}$	Irradiance in the roof retrofiting	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
$T_{mrr}$	Temperature of the reference cell	Thermocouple type T	0-100	°C	<1min	1K
<b>DC</b>						
$I_{rr}$	BIPV generated Intensity DC	Amperimeter		A	<1min	1% of the reading
$V_{rr}$	BIPV generated Voltage DC	Voltimeter		V	<1min	1% of the reading
$P_{rr}$	BIPV generated Power DC	Power meter	15	kW	<1min	2% of the reading
$ET_{rr}$	BIPV generated Energy DC	Energy meter		kW/h	<1min	
<b>AC</b>						

$P_{rr\_l}$	BIPV generated Power AC	Power meter	15	kW	<1min	2% of the reading
$ET_{rr\_l}$	BIPV generated Energy AC	Energy meter		kW/h	<1min	
<b>Storage</b>						
<b>Input</b>						
$I_{rr\_st}$	Intensity flux of storage system	Amperimeter		A	<1min	1% of the reading
$V_{rr\_st}$	voltage of storage system	Voltimeter		V	<1min	1% of the reading
$P_{rr\_st}$	Power flux of storage system	Power meter		kW	<1min	2% of the reading
$ET_{rr\_st}$	Energy flux of storage system	Energy meter		kW/h	<1min	
<b>Building</b>						
$G_i$	<i>Global irradiance</i>	Pyranometer	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
$T_{amb}$	<i>ambient temperature</i>	Thermocouple type T	0-50	°C	<1min	1K
$S_w$	<i>Wind speed</i>	Ultrasonic anemometer	0-100	m/s	<1min	Sw<5m/s--->0,5m/s;Sw>5m/s--->10% of the reading
HVAC controlled by de BEMS						
$I_{hvac\_c}$	Intensity	Amperimeter		A	<1min	1% of the reading
$V_{hvac\_c}$	Voltage	Voltimeter		V	<1min	1% of the reading
$P_{hvac\_c}$	Power	Power meter		kW	<1min	2% of the reading
$ET_{hvac\_c}$	Energy	Energy meter		kW/h	<1min	
HVAC Not controlled by de BEMS						
$I_{hvac\_nc}$	Intensity	Amperimeter		A	<1min	1% of the reading
$V_{hvac\_nc}$	Voltage	Voltimeter		V	<1min	1% of the reading
$P_{hvac\_nc}$	Power	Power meter		kW	<1min	2% of the reading
$ET_{hvac\_nc}$	Energy	Energy meter		kW/h	<1min	
<b>Existing gas Boiler</b>						
$P_{gas}$	Thermal Power	Gas flow meter		kg/s	<1min	
$E_{gas}$	Thermal energy	water calorimeter		kW	<1min	
<b>Existing PV field 2009</b>						
<b>AC</b>						
$P_{pv09\_l}$	Power	Power meter	3,4	kW	<1min	2% of the reading
$ET_{pv09\_l}$	Energy	Energy meter		kW/h	<1min	
<b>Existing PV field 2012</b>						
<b>AC</b>						
$P_{pv12\_l}$	Power	Power meter	1,35	kW	<1min	2% of the reading

ET <sub>pv12_I</sub>	Energy	Energy meter		kW/h	<1min	
<b>Grid</b>						
P <sub>gr</sub>	Power	Power meter		kW	<1min	2% of the reading
ET <sub>grid</sub>	Energy	Energy meter		kW/h	<1min	
<b>Movable charges</b>						
E <sub>whashing machine</sub>	Whashing machine energy consumption	Energy meter		kW/h	<1min	
E <sub>swining poll heat pump and pump</sub>	Ssining pool energy consumption	Energy meter		kW/h	<1min	
E <sub>dishwasher</sub>	Dish washer energy consumption	Energy meter		kW/h	<1min	

### 4.6.3 BIPVBOOST monitoring system

The pre-intervention period instruments have been installed in the building as detailed in the following figures: Figure 4.35, Figure 4.36, Figure 4.37..




Figure 4.35. Monitoring system elements located in the Cellar.




Figure 4.36 Monitoring system elements located in the ground level.

South facade

North Facade




Figure 4.37. Monitoring system elements located in the south and north facades.

Starting from the cellar, it has been installed just one instrument, the calorimeter that it is measuring the thermal energy produced by the existing gas boiler for heating the house (not the domestic hot water). See the installation schema in the Figure 4.38.








Figure 4.40. Secondary board components, lay-out and connections.

Finally, the meteorological instruments (pyranometer, temperature sensor, reference cell and anemometer) have been installed in the North and South façades, as shown in the next figure.

### Meteorological instruments



### Main Board




Figure 4.41. Monitoring system installed components; meteorological instruments and main board.

## 4.7 BIPV MODELLING AND PERFORMANCE SIMULATION

EnerBIM, as WP6 leader and BIMsolar tool developer, has completed BIPV systems digital modelling and simulation works as a pre-study.

### 4.7.1 Element level to building level methodology using 3D modelling and simulation tools

#### 4.7.1.1 Overall methodology

The same methodology presented in Section 2.7.1.1 has been used.

### 4.7.2 Modelling strategy retained for CIGS films mounted on roof tiles (integrated system by SCHWEIZER) – Opaque BIPV

The software is being developed to fit with SCHWEIZER/FLISOM<sup>®</sup> strategies regarding CIGS PV technologies mounted on metal substrate (steel, aluminum) to generate cladding modules and roof tiles. As a pre-study approach, the module builder is based on 2 editors working as a BAPV configurator:

- Cell editor
- Module editor

To design a CIGS roof tile system, we have fixed the following steps:

#### BIPV Layout



#### Balance of System



### 4.7.3 DEMO#3 – OPTIMAL building, 3D design from 2D plans, simulation with BIMsolar

#### 4.7.3.1 Hypothesis

BIPV modules have been set up from SCHWEIZER datasets (final revision). Layouts options decided by VIRIDEN & FD2 (as architects) and OPTIMAL (as the demo site owner).

To run first simulations, we have set-up selected CIGS cells and CIGS modules from FLISOM<sup>®</sup> standards (known from PVSITES sister project) and set up features from SCHWEIZER datasheets and recommendations.

### 4.7.3.2 CIGS ROOF TILES

#### Specifications from SCHWEIZER

<b>Solrif® CIGS on metal BIPV roof modules</b>		Version		5.0 (21.7.2020)		
Module Type		1x1H	2x1H	1x1V	2x1V	3x1V
<b>Dimensions</b>						
Width total	LhorTotal [mm]	870	1700	487	888	1270
Height total	LverTotal [mm]	462	462	853	853	853
Width grid	RhorTotal [mm]	852	1682	469	870	1252
Height grid	RverTotal [mm]	430	430	821	821	821
Thickness at module frame				17		
Thickness at J-Box				23 ± 1		
Weight (preliminary estimation)	[kg]	4.0	7.0	4.0	7.0	10.0
area (based on layout grid)		0.4	0.7	0.4	0.7	1.0
<b>Electrical characteristics at STC<sup>1</sup></b>						
Nominal Power	P <sub>MPP</sub> [W]	30	60	30	60	90
Short Circuit Current	I <sub>sc</sub> [A]	0.97	1.91	0.97	1.94	2.91
Open Circuit Voltage	V <sub>oc</sub> [V]	46	46	46	46	46
MPP Current	I <sub>MPP</sub> [A]	0.88	1.68	0.88	2x0.88	3x0.88
MPP Voltage	V <sub>MPP</sub> [V]	34	36	34	34	34
Solar Cell Efficiency (subcell)	η <sub>c</sub> [%]			12		
Module Efficiency	η <sub>m</sub> [%]	9.1	9.2	8.7	9.4	9.8
Power Output Tolerance				-0.5/+5%		
Maximum Reverse Current				10 A		
Maximum System Voltage				1000 V		
<b>Thermal characteristics</b>						
Temperature coefficient	Voc [%/°C]			-0.3		
Temperature coefficient	Isc [%/°C]			0.01		
Temperature coefficient	PPmpp [%/°C]			-0.35		
<b>Operating conditions</b>						
Temperature range	[°C]			-40 to 85		
Max. mechanical load [Pa]				open		
<b>Additional data</b>						
Cell type				CIGS		
Junction Box				Back side including bypass diode, IP 67, MC4 type / MC4 connectors STC1		
No. of junction boxes		1	1	1	2	tbd
Cable length (4mm <sup>2</sup> )	[mm]	tbd	tbd	900	tbd	tbd
Encapsulation				Fluoropolymer front sheet / back plate (open)		
<b>Warranty &amp; certification</b>						
Performance guarantee		10 years on 90% of Pmpp under STC1 and 20 years on 80% of Pmpp under				
Warranty		5 years' workmanship after delivery date				
Certification		EN IEC 61646; EN IEC 51730-1 & 2				
Fire safety class		according to hard roofing (B root T1, Euroclass) (attempted)				

#### Configuration of virtual modules into BIMsolar

**1X1V MODULE**


Technical specifications

	<p><b>BIPV Module editor</b></p> <p>Supplier: SCHWEIZER          Model: Solif_1x1V</p> <p>Configuration   Technical   Glazing</p> <p><b>Physical:</b>          Peak power: 30.000 Wp          Power coef.: -0.350 %/°C          NOCT: 45,0 °C</p> <p><b>Electrical:</b>          Strings: 1          Voc: 46.000 V          Vmpp: 34.000 V          Isc: 0.970 A</p>
<p>1X2V MODULE          Technical specifications</p>	<p><b>BIPV Module editor</b></p> <p>Supplier: SCHWEIZER          Model: Solif_2X1V</p> <p>Configuration   Technical   Glazing</p> <p><b>Physical:</b>          Peak power: 60.000 Wp          Power coef.: -0.350 %/°C          NOCT: 45,0 °C</p> <p><b>Electrical:</b>          Strings: 1          Voc: 46.000 V          Vmpp: 34.000 V          Isc: 1.940 A</p> <hr/> <p><b>BIPV Module editor</b></p> <p>Supplier: SCHWEIZER          Model: Solif_2X1V</p> <p>Configuration   Technical   Glazing</p> <p><b>Size</b>          Width: 870 mm          Length: 821 mm</p> <p><b>Cells</b>          SCHWEIZER - SubModule Vertical_Solif_2          H spacing: 1 mm          V spacing: 1 mm</p> <p><b>Information</b>          Area: 0.714 m<sup>2</sup>          Cells: 1          Rows: 1          Columns: 1          Occupancy: 94.6 %</p>

### 4.7.3.3 WEATHER DATA and IRRADIATION MODELING

We chose to use the European open access reference tool PVGIS to generate meteorological + site data at the exact location of the demo site. Visualization from satellite enable considering terrain modelling, albedo evaluation and masking effects

<p><b>GEO LOCATION</b></p>	
<ul style="list-style-type: none"> <li>➔ Google Maps</li> <li>➔ PVGIS</li> </ul>	
<p><b>ALBEDO</b></p>	
<ul style="list-style-type: none"> <li>➔ 20% for vegetation</li> <li>➔ 50% for buildings</li> </ul>	<p><b>ORIENTATION</b></p> <ul style="list-style-type: none"> <li>➔ Set-up from architectural design and urban integration</li> </ul>





### 4.7.3.4 3D MODELING - SETUP- EXISTING BUILDING




Figure 4.42: Modelling has been made as much realistic as it could be from the existing 2D plans to address BIPV issues (Trimble SketchUp model from FD2 Architecture)

### STEP#1-BIMsolar IMPORTATION




Figure 4.43: Close and far shadowing calculation are made possible through 3D modelling of realistic buildings - Sun course for full year is displayed at hourly step time





Figure 4.44: Albedo effects (reflected irradiance) are generated selecting groups and types of surfaces 20% as a setup for surroundings and 50% for the building itself and other buildings

#### 4.7.3.5 Simulation – Results

##### STEP#2-IRRADIATION

We use markers to record and visualize values.

Sets of data can be exported in CSV.




<p>Average day for January Wh/sqm Max=80 Min=48 (shading from chimney)</p>	
<p>Direct ratio for January % Max=75 Min=12 (shading from chimney)</p>	
<p>Roof Shading survey January (worst case) No shading issue except on chimney area</p>	
<p>July Best case kWh/sqm Max=154 Min=122 (shading from chimney)</p>	

<p>Average day for July Wh/sqm Max=316 Min=250 (shading from chimney)</p>	
<p>Direct ratio for July % Max=76 Min=40 (shading from chimney)</p>	
<p>Roof Shading survey July (best case) No shading issue except on chimney area</p>	

### STEP#3 – BIPV layouts


We use virtual modules set-up from manufacturer's datasheets (see above) to generate BIPV systems:



**Figure 4.45: Layout generation within 3D interface using BIPV BIM objects (from BIMsolar®)**

Production, shading losses, temperature losses are calculated in real time from module level to BIPV layout level. Every single module is computed as a system and the software displays individual KPIs.

Detailed results are obtained at STEP#5 (BIMsolar reference process)



**Figure 4.46: East roof for Solrif® modules combination following architect + demo owner requirements. Total 5.2kWp / 62.8 sqm**






Figure 4.47: East roof – Shading losses at module level

Note: skylights are not perfectly positioned in the original 3D model. For that reason, the BIPV modules layouts may enter in collision with the geometry which generates local shading.

Dummy modules are not created for simulation. 2x1V modules equipped with one cell are set-up as 1X1V modules.




Figure 4.48: East roof – Global results – Array level






Figure 4.49: West roof for Solrif<sup>®</sup> modules combination following architect + demo owner requirements. *Total 4.8kWp / 62.8 sqm*



Figure 4.50: West roof – Shading losses at module level

Note: skylights are not perfectly positioned in the original 3D model. For that reason, the BIPV modules layouts may enter in collision with the geometry which generates local shading.

Dummy modules are not created for simulation. 2x1V modules equipped with one cell are set-up as 1X1V modules.




Figure 4.51: East roof – Global results – Array level

#### STEP#4 – INVERTERS / WIRING

This step consists in building the best strategy for the implementation of inverters and connect to them the strings of modules to optimise the DC and AC productions.

BIMsolar enables considering the mismatching between modules (gaps in irradiance due to shading effects), then proposes the best wiring configuration for each MPPT to maximise the energy production.

##### Methodology for simulations:

Because the 1X1V and 2x1V modules are different in size to fit with the architectural grid configuration, we need to address only individual cells to set-up connections of modules to build strings and to meet inverters input requirements (same  $I_{sc}$  values to connect in series).

For these reasons we rebuilt the 3D models with one cell equivalent modules.

This allows to count the exact number of cells and to connect the appropriate ones to meet the electrical engineering strategy.

##### Electrical layout specifications from OPTIMAL:

As presented above (section 4.5.1 “PV inverter”), OPTIMAL chose to limit the total power input for the inverter. This means disconnect 3 cells on each roof.

BIMsolar allows mismatching of modules analysis to support wiring strategies. This is useful to build well balanced strings to be connected on the inverter’s MPPTs.

In this way we let the software build the strings of 9 modules for the two roofs and we disconnected the most shaded modules (nb=6 around the chimney).


We obtain a total of 327 cells connected to the SMA INVERTER.




**EAST roof - Table of results:**

<p>IRRADIATION share - Annual GLOBAL BIPV ARRAY</p>	<table border="1"> <thead> <tr> <th>Irradiation Type</th> <th>Percentage</th> <th>Value (kWh)</th> </tr> </thead> <tbody> <tr> <td>Direct Irradiation</td> <td>43.5 %</td> <td>26329 kWh</td> </tr> <tr> <td>Diffuse Irradiation</td> <td>54 %</td> <td>32689 kWh</td> </tr> <tr> <td>Indirect Irradiation</td> <td>2.5 %</td> <td>-</td> </tr> </tbody> </table>	Irradiation Type	Percentage	Value (kWh)	Direct Irradiation	43.5 %	26329 kWh	Diffuse Irradiation	54 %	32689 kWh	Indirect Irradiation	2.5 %	-
Irradiation Type	Percentage	Value (kWh)											
Direct Irradiation	43.5 %	26329 kWh											
Diffuse Irradiation	54 %	32689 kWh											
Indirect Irradiation	2.5 %	-											
<p>Production – Shading losses Year #1 GLOBAL BIPV ARRAY</p>	<table border="1"> <thead> <tr> <th>Category</th> <th>Percentage</th> <th>Value (kWh)</th> </tr> </thead> <tbody> <tr> <td>Production</td> <td>99.6 %</td> <td>4660 kWh</td> </tr> <tr> <td>Shadow loss</td> <td>0.4 %</td> <td>-</td> </tr> </tbody> </table>	Category	Percentage	Value (kWh)	Production	99.6 %	4660 kWh	Shadow loss	0.4 %	-			
Category	Percentage	Value (kWh)											
Production	99.6 %	4660 kWh											
Shadow loss	0.4 %	-											

PV Generation – Shading losses  
MONTHLY



PV Generation – Shading losses  
AVERAGE DAY / MONTH




<p>DC Production (Inverter IN)          Year #1 = 4 452 kWh          Losses (strings)</p>	<p>A pie chart illustrating the breakdown of DC production. The largest segment is blue, representing 'DC Inverter In' at 96.6% (4452 kWh, 97%). A smaller green segment represents 'Mismatch losses' at 2.9% (131 kWh, 3%). A very thin red segment represents 'Ohmic losses' at 0.5%.</p> <table border="1"> <thead> <tr> <th>Category</th> <th>Value (kWh)</th> <th>Percentage</th> </tr> </thead> <tbody> <tr> <td>DC Inverter In</td> <td>4452</td> <td>96.6 %</td> </tr> <tr> <td>Mismatch losses</td> <td>131</td> <td>2.9 %</td> </tr> <tr> <td>Ohmic losses</td> <td>-</td> <td>0.5 %</td> </tr> </tbody> </table>	Category	Value (kWh)	Percentage	DC Inverter In	4452	96.6 %	Mismatch losses	131	2.9 %	Ohmic losses	-	0.5 %
Category	Value (kWh)	Percentage											
DC Inverter In	4452	96.6 %											
Mismatch losses	131	2.9 %											
Ohmic losses	-	0.5 %											
<p>AC Production (Inverter OUT)          Year #1 = 4 372 kWh          Final Yield = 881 kWh/kWp</p>	<p>A pie chart illustrating the breakdown of AC production. The large blue segment represents 'AC Production' at 98.2% (4372 kWh, 98%). The small red segment represents 'DC to AC loss' at 1.8%.</p> <table border="1"> <thead> <tr> <th>Category</th> <th>Value (kWh)</th> <th>Percentage</th> </tr> </thead> <tbody> <tr> <td>AC Production</td> <td>4372</td> <td>98.2 %</td> </tr> <tr> <td>DC to AC loss</td> <td>-</td> <td>1.8 %</td> </tr> </tbody> </table>	Category	Value (kWh)	Percentage	AC Production	4372	98.2 %	DC to AC loss	-	1.8 %			
Category	Value (kWh)	Percentage											
AC Production	4372	98.2 %											
DC to AC loss	-	1.8 %											




**WEST roof - Table of results:**


<p>IRRADIATION share - Annual GLOBAL BIPV ARRAY</p>	<table border="1"> <thead> <tr> <th>Irradiation Type</th> <th>Percentage</th> <th>Value (kWh)</th> </tr> </thead> <tbody> <tr> <td>Direct Irradiation</td> <td>44.1 %</td> <td>24870 kWh</td> </tr> <tr> <td>Diffuse Irradiation</td> <td>52.9 %</td> <td>29847 kWh</td> </tr> <tr> <td>Indirect Irradiation</td> <td>3 %</td> <td>1688 kWh</td> </tr> </tbody> </table>	Irradiation Type	Percentage	Value (kWh)	Direct Irradiation	44.1 %	24870 kWh	Diffuse Irradiation	52.9 %	29847 kWh	Indirect Irradiation	3 %	1688 kWh
Irradiation Type	Percentage	Value (kWh)											
Direct Irradiation	44.1 %	24870 kWh											
Diffuse Irradiation	52.9 %	29847 kWh											
Indirect Irradiation	3 %	1688 kWh											
<p>Production – Shading losses Year #1 GLOBAL BIPV ARRAY</p>	<table border="1"> <thead> <tr> <th>Category</th> <th>Percentage</th> <th>Value (kWh)</th> </tr> </thead> <tbody> <tr> <td>Production</td> <td>99.6 %</td> <td>4336 kWh</td> </tr> <tr> <td>Shadow loss</td> <td>0.4 %</td> <td>-</td> </tr> </tbody> </table>	Category	Percentage	Value (kWh)	Production	99.6 %	4336 kWh	Shadow loss	0.4 %	-			
Category	Percentage	Value (kWh)											
Production	99.6 %	4336 kWh											
Shadow loss	0.4 %	-											

PV Generation – Shading losses  
MONTHLY



PV Generation – Shading losses  
AVERAGE DAY / MONTH





#### 4.7.4 Summary of the results

	Array										Yield
Unit	kWh		degree			kWh	kWh	kWh	%	kWh	kWh/kWp
	Irradiation		Panel orientation			PV generation	DC inverter IN	Losses		AC inverter OUT	AC inverter OUT
	East Roof	West Roof		Azimuth*	Tilt	House	House	House	House	House	House
Direct	26 329	24 870	East	-112,9	39,4	4 660,0	4 452,0	80	1,8%	4 372,0	852,0
Diffuse	32 689	29 847									
Indirect	1 565	1 688	West	69,1	39,4	4 336,1	4 201,0	75,0	1,8%	4 126,0	881,0
				*South = 0°							
	60 583,0	56 405,0				8 996,1	8 653,0	155,0	0,0	8 498,0	866,5
<b>TOTAL:</b>	<b>116 988,0</b>					<b>8 996,1</b>	<b>8 653,0</b>			<b>8 498,0</b>	<b>MEAN VALUES</b>

#### 4.7.5 Conclusions

At the current stage of the validated performance of the software and provided the fact that products and project are submitted to updates we consider that the first results are positive and converging towards expectations. We did not face critical difficulties in the process except difficulties in positioning the virtual objects with the highest accuracy into layouts to fit with 2D drawings and 3D original model provided by the BIPV designers.

The two roofs seem to be well balanced in final yield. Connected to the same inverter, the strings do not show unacceptable mismatching.

5 months (OCT-FEB) reveal low expected production due to meteorological conditions and the important share of diffuse irradiation.

Next steps will be:

1. Update of the building 3D model, related to final BIPV integration (demo site manager),
2. Implementation of enhanced features to generate BIPV BIM objects related to virtualization of SOLRIF<sup>®</sup> systems and enabling accurate positioning on the 3D model,
3. Comparison between measurement and simulation as soon as the real modules will be integrated and monitoring available.

#### 4.8 PLANNING TIMELINE

Below is the planning timeline for the Optimal demonstration site at the time of writing. The Gantt chart is a living document and available via the BIPVBOOST shared platform.




Figure 4.18: Optimal Demo-site Gantt Chart

The next big steps for the demonstration site setup are:

- August 2021: ordering of the PV inverter.
- September 2021: delivery of the PV inverter.
- October 2021: Delivery of the panels and equipments
- November 2021: Panel placement

## 5 DEMO SITE 4: PIZ

### 5.1 DEMO-SITE BUILDING DESCRIPTION

The demosite at which BIPV modules will be installed is located in the town of Morbegno situated in the North of Italy. It is a residential complex consisting of twin buildings separated from each other. The buildings were built in 2007 and are multi-family residential complex consisting of 17 residential units and 4 commercial spaces. Commercial spaces are located on the ground floor and are intended for office use. Both buildings have been constructed of bricks with the mainframe structure of reinforced concrete beams and pillars. Building facades have been realized with PIZ H89 panel which provides a good level of insulation. Images of the building are shown in Figure 5.2 and Figure 5.3.




Figure 5.1: Satellite view of demosite 4, Latitude 46°7'54'' Longitude 9°33'64'' (Source: google earth)



Figure 5.2: Demo-site 4, Images of the building





**Figure 5.3: Demo-site 4, Building's image from 1<sup>st</sup> underground level**

The electricity produced by the BIPV installation will be consumed primarily to power common light points and elevators. If there is any excess electricity produced during the day, it will be used to control common heat pump for the hot/cold water of the building.

## **5.2 ARCHITECTURAL BIPV DESIGN**

### **5.2.1 Existing demo-site building**

The Demo-site consists of two adjacent buildings, both buildings have an identical cube-like shape. Each building consists of 5 floors above ground and 2 underground levels. The area of each floor is about 200 m<sup>2</sup>. The underground level comprises car garages and common areas (metering room, heat pump room). The components of the building electrical system are present in the metering room on the 2nd underground level. All building facades have been realized with the PIZ H89 panel. 3D drawing of the demo site can be seen in Figure 5.5 and Figure 5.5.




Figure 5.4: Demo-site 4, 3d drawing of the existing building




Figure 5.5: Demo-site 4, 3d drawing of the existing building

## 5.2.2 Architectural BIPVBOOST Design

In the initial design stages, two architectural designs were prepared with different purposes, first one focused on maximizing the power installation (10,9 KWp) whereas the second one aimed at the best architectural integration while slightly compromising the energy production (10,2 KWp).

### 5.2.2.1 Design option A1 and A2 (best architectural integration)

The design is shown in Figure 5.6. In this design top two rows of PIZ cladding panels are replaced by two rows of ePIZ glass-glass BIPV modules in all four facades of each building. The new installation runs in a wreath shape thereby covering all four facades of each building. This design option integrates well with the existing building design. In total 120 m<sup>2</sup> of ePIZ BIPV cladding would be installed which would generate 10,2 KWp of energy. The design option A is further divided into category A1 (three number of three-phase inverters for each building) and A2 (4 number of monophase inverters for each building) based upon the type of inverter used.

### 5.2.2.2 Design option B (maximum power)

The design is shown in Figure 5.7. In this design top three rows of PIZ cladding panel are replaced by three rows of ePIZ glass-glass BIPV modules in all facades except the North-West façade. This design has four dummy modules for each building at the position of emergency overflows. In total 140 m<sup>2</sup> of ePIZ BIPV cladding would be installed which would generate 10,9 kWp of energy. This option generates more power output compared to option A but the design doesn't blend in well with the existing building design.

<b>Viridén Partner</b> Viridén + Partner AG Zwinglistrasse 35, 8004 Zürich Telefon: 043 456 80 80 Fax: 043 456 80 00 www.viriden-partner.ch	BIPVBoost - Horizon 2020 Projekt PIZ S.r.l., Cizeta 2 - Pal.A - Cosio Valtellino - Italy	<b>C2 011</b> Plan-Nr. A512 Massstab 1:200 Plan-Grösse A3 erstellt/von 13.11.19/erd geändert/von
	Pre-design - Demosite 4 <b>Scenario A</b> 2 module rows	
	<b>total for house A and B incl. north facade:</b> number of modules = 158 standard pieces + 2 special pieces = 160 pieces surface = 121 m <sup>2</sup> number of cells = 2544 cells approx. power totaly = 10.17 kWp	
	The color of the new PIZ panels is the same as the current color of the panels (white). The definitive decision of the color of the panels is possible only with sampling.	



picture house A, south-west facade



picture house A, north-east facade



picture house A and B, north-west facade



picture house A and B, south-east facade



Figure 5.6: Design option A (best architectural integration)

<b>Viridén + Partner</b> Viridén + Partner AG Zwielerstrasse 35, 8004 Zürich Telefon: 043 456 80 80 Fax: 043 456 90 90 www.viriden-partner.ch	<b>BIPVBoost - Horizon 2020 Projekt</b> PIZ Str.1., Cieta 2 - Pal.A - Gossio Valtellino - Italy	<b>C2 011</b> Plan-Nr.: AS014 Massstab: 1:200 Plan-Grösse: A3 erstellt/rev: 13.11.19/erd geändert/rev:
	Pre-design - Demosite 4 <b>Scenario B - Rev.</b> 3 module rows	

**total for house A and B:**  
 number of modules = 174 standard pieces + 8 modules not connected  
 standard modul total = 182 pieces  
 special modules = 4 pieces  
 total = 186 pieces  
 surface = 140 m<sup>2</sup>  
 number of cells = 2'816 cells  
 approx. power = 11.26 kWp

The color of the new PIZ panels is the same as the current color of the panels (white).  
 The definitive decision of the color of the panels is possible only with sampling.



picture house A, south-west facade



picture house A, north-east facade



picture house A and B, north-west facade



picture house A and B, south-east facade



**Figure 5.7: Design option B (maximum power)**

### 5.2.2.3 Choice of final design

For the final choice of architectural design, both design options A and B were presented and discussed in the local municipality office. The office was requested to choose one of the two presented design options. Municipality accepted design option A because this design blends in well with the current cladding design of the building and the difference in power output is not much when compared to design option B.

A cost estimation analysis as seen in Figure 5.8 was carried out for all design options in order to support the final design choice based upon best value for money rule. It can be seen that architectural design A has been further divided into two categories A1 (three number of three-phase inverters for each building) and A2 (4 number of monophase inverters for each building) based upon the type of inverter used.

Design A2 turned out to be the best option because the architectural layout is accepted by the municipality, has the least cost among the three options and uses monophase inverter for every façade of each building. Therefore, it was decided to study this design option A2 in detail and make further improvements in the design.



Turn-key installation quotation for a demo-site				
	Scenario A2	Scenario A1	Scenario B	
<b>1. Materials</b>	<b>Price [€]</b>	<b>Price [€]</b>	<b>Price [€]</b>	<b>Remarks</b>
1.1 Fastening and mounting system	1.500,00 €	1.500,00 €	1.600,00 €	For demosite-4 structure is not provided by TULUPPS/SCHWEIZER. Partial cost of fastening system is already included in price of BIPV module. This is the estimated cost of additional components to be purchased.
1.2 BIPV modules	79.779,14 €	79.779,14 €	87.001,74 €	This cost is sum of the cost of modules provided by ONYX and PIZ. This cost is estimated considering current production process for both ONYX and PIZ.
1.3 Cabling	740,00 €	1.290,00 €	1.290,00 €	Cable distances are calculated from pre-design. Cost is estimated from quotation received on 04/12/2019. Price may change over time.
1.4 Inverters	2.392,00 €	2.092,00 €	3.138,00 €	The cost of the invertors taken from the quotation received on 04/12/2019. Price may change over time.
1.5 Monitoring system	200,00 €	200,00 €	200,00 €	Cabling included. Monitoring equipment not included: Monitoring equipment to be provided by TECNALIA.
1.6 Electrical installation materials	500,00 €	3.000,00 €	3.248,00 €	This is an estimated cost of all required material. A Part of this cost is taken from quotation received on 4/12/2019 and a part is estimated based on previous experience.
1.7 Battery System				Not Applicable for Demosite4
<b>MATERIALS SUBTOTAL</b>	<b>85.111,14 €</b>	<b>87.861,14 €</b>	<b>96.477,74 €</b>	
<b>2. Labor</b>	<b>Price [€]</b>	<b>Price [€]</b>	<b>Price [€]</b>	<b>Remarks</b>
2.1 Permit obtaining	4.000,00 €	4.000,00 €	4.000,00 €	This is an estimated cost.
2.2 Detailed Executive Project	2.000,00 €	2.000,00 €	2.000,00 €	This is an estimated cost.
2.3 Structural and mechanical installation	8.000,00 €	8.000,00 €	8.660,00 €	Cost estimated based on previous experience. It includes disinstallation cost of PIZ, installation cost of new BIPV system and platform rental cost.
2.4 Electrical installation	4.800,00 €	6.400,00 €	6.928,00 €	Cost estimated after consulting electrical installer.
2.5 Certification of the installation	1.000,00 €	1.000,00 €	1.000,00 €	Cost estimated for certification of only electrical installation of the system (not for the complete BIPV system).
2.6 Operation and Maintenance (optional)				
<b>LABOR SUBTOTAL</b>	<b>19.800,00 €</b>	<b>21.400,00 €</b>	<b>22.588,00 €</b>	
<b>TOTAL TURN-KEY INSTALLATION:</b>	<b>104.911,14 €</b>	<b>109.261,14 €</b>	<b>119.065,74 €</b>	

Figure 5.8: Cost estimation analysis of Design option A1, A2 and B

#### 5.2.2.4 Design option E, final design (Improved version of design option A2)

The design is shown in Figure 5.9 and Figure 5.10, it is an improved version of design option A2 and is the final design. In this architectural design, the top three rows of the PIZ cladding panel are replaced with the two rows of ePIZ glass-glass BIPV modules and two small rows of conventional PIZ H89 modules. ePIZ glass-glass BIPV modules are placed in between the two small rows of conventional PIZ H89 modules in order to avoid production losses due to the shadow of flashing elements in the top row.

In this design, 178m<sup>2</sup> of façade cladding is replaced with 110m<sup>2</sup> of ePIZ BIPV cladding and 68m<sup>2</sup> of PIZ H89 cladding. 204 standard ePIZ BIPV modules and 8 special ePIZ BIPV modules are required for this installation. All ePIZ BIPV modules have the same width and solar cells will be evenly distributed in the individual BIPV module which gives a raster image look overall. The approximate power of this PV installation is 9,8 kWp.


An emergency water overflow in the BIPV installation area exists, located on the North-East façade of each building which will be redirected to the lower row of conventional PIZ H89 modules during the installation process. The new ePIZ panels will be of white color same as the existing PIZ cladding panels of the building. The solar cells are of sparkling-gold color, contrast in colors with sparkling gold PV cells is more balanced compared to black or blue solar cells. Overall, the design of the demo site integrates well with the building surrounding. Figure 5.11 shows rendered images of the demo-site building before and after BIPV installation.

The cost comparison analysis of all the design options can be seen in Figure 5.12. The increase in cost of design option E compared to design option A2 is due to addition of 68m<sup>2</sup> of PIZ H89 cladding in the design which is required in order to avoid power losses due to shadowing effect.

<b>Viridén + Partner</b> Viridén + Partner - 20 Via... Tel: +39 02 455 9000 Fax: +39 02 455 9000 www.viridenpartner.it	<b>BIPVBoost - Horizon 2020 Projekt</b> FIE S.r.l., Clava 2 - Pav. A - Corso Valtellina - Italy	<b>C2 011</b> Plan No: AS33 Max Area: 1.100 Max Inflow: A3	
	Design - Demo-site 4 <b>Scenario E.1 / Facade NW - Facade NE</b> Two rows of cells per module	Installation: 23.09.20/gas grid-inflow: 02.12.20/gas	

The definitive module sizes and construction are in the responsibility of the client. Viridén + Partner AG is acting as a consultant and takes no responsibility for planning.

The final color has yet to be defined. Representation of the new position of the modules with the sparkling grid cell.



north-west facade - house A



north-east facade - house A

Figure 5.9: Demo-site 4, North-west and north-east facade


<b>Viridén + Partner</b> Viridén + Partner - 20 Via... Tel: +39 02 455 9000 Fax: +39 02 455 9000 www.viridenpartner.it	<b>BIPVBoost - Horizon 2020 Projekt</b> FIE S.r.l., Clava 2 - Pav. A - Corso Valtellina - Italy	<b>C2 011</b> Plan No: AS34 Max Area: 1.100 Max Inflow: A3	
	Design - Demo-site 4 <b>Scenario E.1 / Facade SW - Facade SE</b> Two rows of cells per module	Installation: 23.09.20/gas grid-inflow: 02.12.20/gas	

The definitive module sizes and construction are in the responsibility of the client. Viridén + Partner AG is acting as a consultant and takes no responsibility for planning.

The final color has yet to be defined. Representation of the new position of the modules with the sparkling grid cell.



south-west facade - house A



south-east facade - house A

Figure 5.10: Demo-site 4, south-west and south-east facade design





Figure 5.11: Demo-site 4, 3D design of demo-site building design with and without ePIZ BIPV modules

Turn-key installation quotation for a demo-site					
	Scenario A2	Scenario A1	Scenario B	Scenario E	
1. Materials	Price [€]	Price [€]	Price [€]	Price [€]	Remarks
1.1 Fastening and mounting system	1.500,00 €	1.500,00 €	1.600,00 €	1.500,00 €	For demosite-4 structure is not provided by TULIPPS/SCHWEIZER. Partial cost of fastening system is already included in price of BIPV module. This is the estimated cost of additional components to be purchased.
1.2 BIPV modules	79.779,14 €	79.779,14 €	87.001,74 €	79.779,14 €	This cost is sum of the cost of modules provided by ONYX and PIZ. This cost is estimated considering current production process for both ONYX and PIZ.
1.3 Cabling	740,00 €	1.290,00 €	1.290,00 €	740,00 €	Cable distances are calculated from pre-design. Cost is estimated from quotation received on 04/12/2019. Price may change over time.
1.4 Inverters	2.392,00 €	2.092,00 €	3.138,00 €	2.392,00 €	The cost of the inverters taken from the quotation received on 04/12/2019. Price may change over time.
1.5 Monitoring system	200,00 €	200,00 €	200,00 €	200,00 €	Cabling included. Monitoring equipment not included. Monitoring equipment to be provided by TECNALIA.
1.6 Electrical installation materials	500,00 €	3.000,00 €	3.248,00 €	500,00 €	This is an estimated cost of all required material. A Part of this cost is taken from quotation received on 4/12/2019 and a part is estimated based on previous experience.
1.7 Battery System					Not Applicable for Demosite4
1.8 PIZ H89 cladding modules				5.916,00 €	
<b>MATERIALS SUBTOTAL</b>	<b>85.111,14 €</b>	<b>87.861,14 €</b>	<b>96.477,74 €</b>	<b>91.027,14 €</b>	
2. Labor	Price [€]	Price [€]	Price [€]	Price [€]	Remarks
2.1 Permit obtaining	4.000,00 €	4.000,00 €	4.000,00 €	4.000,00 €	This is an estimated cost.
2.2 Detailed Executive Project	2.000,00 €	2.000,00 €	2.000,00 €	2.000,00 €	This is an estimated cost.
2.3 Structural and mechanical installation	8.000,00 €	8.000,00 €	8.660,00 €	8.000,00 €	Cost estimated based on previous experience. It includes disinstallation cost of PIZ, installation cost of new BIPV system and platform rental cost.
2.4 Electrical installation	4.800,00 €	6.400,00 €	6.928,00 €	4.800,00 €	Cost estimated after consulting electrical installer.
2.5 Certification of the installation	1.000,00 €	1.000,00 €	1.000,00 €	1.000,00 €	Cost estimated for certification of only electrical installation of the system (not for the complete BIPV system).
2.6 Operation and Maintenance (optional)					
<b>LABOR SUBTOTAL</b>	<b>19.800,00 €</b>	<b>21.400,00 €</b>	<b>22.588,00 €</b>	<b>19.800,00 €</b>	
<b>TOTAL TURN-KEY INSTALLATION:</b>	<b>104.911,14 €</b>	<b>109.261,14 €</b>	<b>119.065,74 €</b>	<b>110.827,14 €</b>	

Figure 5.12: Cost estimation analysis of Design option A1, A2, B and final design E

## 5.3 BIPV STRUCTURE DESIGN

### 5.3.1 Existing building structure

The building walls have been constructed in bricks and the facades have been realized with PIZ H89 cladding system. The existing PIZ H89 cladding panels are in white colour with photocatalytic behaviour, rough surface finish, 0 mm vertical and 0 mm horizontal joint. The PIZ H89 cladding panel as shown in Figure 5.13 consists of mortar combined with an insulating layer. The panel has a total thickness of 89 mm and is made up of 9 mm external mortar skin and 80 mm insulation. The mortar is reinforced with alkaline resistant fiberglass and contains modified cement with metal oxide coloured pigments which are resistant to atmospheric agents. This mortar is joined with a layer of NEOPOR which is synthesized polystyrene with retarded expansion. Overall, the thickness of the installed system with mounting rails is 92 mm.

The PIZ cladding product is CE certified and follows ETAG 017. It has a lower specific thermal conductivity and very low water absorption capacity. It shows good resistance under wind suction test, a good resistance under impact test and a great resistance under fire test. PIZ system is a breathable system with open joints, so it has good water vapor permeability.




Figure 5.13: Demo site 4, PIZ H 89 cladding system

PIZ panels can be mounted using a special profile mounting system specific to PIZ product. This mounting system makes installation of panels easier and less time consuming. It consists of horizontal profiles in aluminum (start profiles, H-profile and top profile), vertical T spacer profile in PVC and corner profiles in aluminum. Aluminium profiles are secured to the substructure using expansion plug distanced at 90 cm. These profiles are fixed in the grooves prepared on the horizontal and vertical edges of the panels. Over Horizontal edges, mortar is thickened and grooved to allow insertion of continuous extruded aluminium profile and on vertical edge rockwool is grooved to allow insertion of PVC T spacer profile.

### 5.3.2 BIPVBOOST structure

ePIZ can be mounted on substructure using the same fastening and mounting system as traditional PIZ panels. The mounting system will comprise the same profile system as explained in the previous section. Horizontal profiles will be fixed to the walls using metal expansion plugs. The pitch between the expansion plugs will be 45 cm. The modules will be installed with 0 mm vertical joint and 15 mm horizontal joint. Additional aluminium safety clamps will be used to provide extra protection to the glass. Safety clamps are recommended considering the behavior of polymeric materials under high temperatures. In ePIZ modules, EVA encapsulant and silicone are the polymeric materials. These materials could melt in case of fire and result in glass detachment therefore safety clamps can enhance protection in such a scenario.




Figure 5.14: Demo-site 4, typical wall section before BIPV installation

Figure 5.15: Demo-site 4, typical wall section after BIPV installation

Typical wall sections before and after BIPV installation is shown in Figure 5.14 and Figure 5.15 respectively. Three rows of PIZ H89 cladding panels will be replaced by two rows ePIZ BIPV panels and two small rows of conventional PIZ H89 cladding panel.

## 5.4 BIPV MODULE DESIGN

### 5.4.1 ePIZ glass-glass module description

ePIZ consists of a composite element, obtained by integrating PIZ cladding product with different photovoltaic (PV) technologies. The main concept of combining PIZ product with a PV element was to have a BIPV cladding system that can offer energy production, a high level of thermal insulation and a good level of acoustic insulation within one product along with an easy installation process. In the BIPVBOOST project, two

different ePIZ products were prepared by integrating the PIZ rock metabio H89 panel with ONYX glass-glass PV module and FLISOM CIGS modules.

For the demo-site installation, it was decided to use ePIZ prepared with ONYX glass-glass PV module, functional prototype is shown in Figure 5.16. PIZ rock metabio H89 consists of 8-9 mm thick mortar external skin joined with 80 mm thick wool rock insulation that has a density of 135 kg/m<sup>3</sup>. The mortar is reinforced with alkaline resistant fiberglass and contains modified cement with metal oxide coloured pigments which are resistant to atmospheric agents. The glass-glass PV laminate consists of two layers of 3.2 mm thick glass with PV cells packed in between the two layers through EVA encapsulant sheets. A Junction Box (JB) is attached at the back of the module containing all necessary electrical components. Silicone adhesive was used to join the surface of the mortar with the rear glass surface of the glass-glass PV module. Silicone was applied only behind the solar cells and along the edges.



**Figure 5.16: Demo-site 4, ePIZ prototype with glass-glass PV module (color of the cells is different from the one that will be installed)**



**Figure 5.17: Demo-site 4, Aluminum H-profile placed inside the upper horizontal grooves**

The vertical edges of the wool rock are grooved to allow the insertion of a PVC "T" profile for the "0" mm gap joint. Top horizontal edge of the wool rock is grooved as shown in Figure 5.18 to create a passage for the electrical wiring thus providing a defined path for wiring inside the module. A hollow cavity of 102 mm diameter is created inside the PIZ module to accommodate JB. Horizontal edges of mortar are thickened and grooved to allow insertion of aluminium H-profile as depicted in Figure 5.17.





**Figure 5.18: Demo-site 4, Groove created on the top horizontal edge to provide cable passage**



**Figure 5.19: Demo-site 4, Middle safety clamp**




**Figure 5.20: Demo-site 4, ePIZ prototypes with glass-glass PV laminate mounted on wall**


Prototypes in golden-brown and sparkling-gold color solar cells were prepared for the Architect VIRIDEN Partner in order to make the right design choice for the demo-site building. Architect chose sparkling gold color cell and white color PIZ mortar surface with rough finish for demo-site building.

#### **5.4.2 Demo-site module/s design**


Architectural design of demo-site is shown in Figure 5.9 and Figure 5.10, we have six different module designs in total; two standard modules and four special modules which will be used to adjust spaces at building corners. Design of all demo-site modules is shown In Figure 5.21, Figure 5.24, Figure 5.23, Figure 5.24, Figure 4.21 and Figure 4.22.




**Figure 5.23: Demo-site 4, front view of standard ePIZ module A1**




**Figure 5.24: Demo-site 4, front view of standard ePIZ module A2**




**Figure 5.25: Demo-site 4, front view of special ePIZ module B1**



**Figure 5.26: Demo-site 4, front view of standard ePIZ module B2**



**Figure 5.27: Demo-site 4, front view of special ePIZ module C1**




**Figure 5.28: Demo-site 4, front view of special ePIZ module C2**



**Table 5.1 Total number of BIPV modules required for demo-site 4 installation**

Type	Required Numbers
Standard module - A1	102
Standard module - A2	102
Special Module - B1	2
Special Module - B2	2
Special Module - C1	2
Special Module – C2	2



**Figure 5.29: Demo-site 4, Lateral view of standard ePIZ module**

Table 5.1 shows total number of modules required to complete the demo-site BIPV installation.

### 5.4.3 BIPVBOOST module/s electrical Design

This section provides data sheet and design of glass-glass PV modules provided by ONYX. Data sheets can be seen in Table 5.2, Table 5.3 and Table 5.4, it contains all necessary details of the PV modules that will be integrated with PIZ panel to manufacture BIPV modules. The design of the PV modules can be seen if Figure 5.31, Figure 5.32, Figure 5.33, Figure 5.34 and Figure 5.35

Table 5.2 Demo-site 4, technical data sheet of ONYX PV module type A1 and A2

<b>PHOTOVOLTAIC GLASS</b>		<b>1.110 x 451</b>	
<b>Sparkling gold 16.3-16.1%</b>		<b>6" Poly Color</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	47	$P_{mpp}$ (Wp)	
Open-circuit voltage	7	$V_{oc}$ (V)	
Short-circuit current	8,22	$I_{sc}$ (A)	
Voltage at nominal power	6	$V_{mpp}$ (V)	
Current at nominal power	7,68	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	1110	mm	
Width	451	mm	
Thickness	7,8	mm	
Surface area	0,50	sqm	
Weight	7,5	Kgs	
Cell type	6" Poly Color	Crystalline sparkling gold	
No PV cells / Transparency degree	12	42%	
Front Glass	3 mm	Tempered Glass Low-Iron	
Rear Glass	3 mm	Tempered Glass	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of $P_{mpp}$	-0,451	%/°C	
Temperature Coefficient of $V_{oc}$	-0,361	%/°C	
Temperature Coefficient of $I_{sc}$	+0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	42%
U-value [W/sqm.K]	-
Peak Power [Wp/sqm]	93,7




Figure 5.30: Demo-site 4, design of ONYX PV module, type A1




Figure 5.31: Demo-site 4, design of ONYX PV module, type A2

Table 5.3 Demo-site 4, technical data sheet of ONYX PV module type B1 and B2

<b>PHOTOVOLTAIC GLASS</b>		<b>1.064 x 451</b>	
<b>Sparkling gold 16.3-16.1%</b>		<b>6" Poly Color</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	39	$P_{mpp}$ (Wp)	
Open-circuit voltage	6	$V_{oc}$ (V)	
Short-circuit current	8,22	$I_{sc}$ (A)	
Voltage at nominal power	5	$V_{mpp}$ (V)	
Current at nominal power	7,68	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 15 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	1064	mm	
Width	451	mm	
Thickness	7,8	mm	
Surface area	0,48	sqm	
Weight	7,2	Kgs	
Cell type	6" Poly Color	Crystalline sparkling gold	
No PV cells / Transparency degree	10	49%	
Front Glass	3 mm	Tempered Glass Low-Iron	
Rear Glass	3 mm	Tempered Glass	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of $P_{mpp}$	-0,451	%/°C	
Temperature Coefficient of $V_{oc}$	-0,361	%/°C	
Temperature Coefficient of $I_{sc}$	+0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	49%
U-value [W/sqm.K]	-
Peak Power [Wp/sqm]	81,5




Figure 5.32 Demo-site 4, design of ONYX PV module, type B1




Figure 5.33 Demo-site 4, design of ONYX PV module, type B2



Table 5.4 Demo-site 4, technical data sheet of ONYX PV module type C1 and C2

<b>PHOTOVOLTAIC GLASS</b>		<b>668 x 451</b>	
<b>Sparkling gold 16.3-16.1%</b>		<b>6" Poly Color</b>	<b>Crystalline</b>
<b>Electrical data test conditions (STC)</b>			
Nominal peak power	23	$P_{mpp}$ (Wp)	
Open-circuit voltage	4	$V_{oc}$ (V)	
Short-circuit current	8,22	$I_{sc}$ (A)	
Voltage at nominal power	3	$V_{mpp}$ (V)	
Current at nominal power	7,68	$I_{mpp}$ (A)	
Power tolerance not to exceed	±10	%	
STC: 1000 w/m <sup>2</sup> , AM 1.5 and a cell temperature of 25°C, stabilized module state.			
<b>Mechanical description</b>			
Length	668	mm	
Width	451	mm	
Thickness	7,8	mm	
Surface area	0,30	sqm	
Weight	4,5	Kgs	
Cell type	6" Poly Color	Crystalline sparkling gold	
No PV cells / Transparency degree	6	52%	
Front Glass	3 mm	Tempered Glass Low-Iron	
Rear Glass	3 mm	Tempered Glass	
Thickness encapsulation	1,80 mm	EVA Foils	
Category / Color code			
<b>Junction Box</b>			
Protection	IP65		
Wiring Section	2,5 mm <sup>2</sup> or 4,0 mm <sup>2</sup>		
<b>Limits</b>			
Maximum system voltage	1000	$V_{sys}$ (V)	
Operating module temperature	-40...+85	°C	
<b>Temperature Coefficients</b>			
Temperature Coefficient of $P_{mpp}$	-0,451	%/°C	
Temperature Coefficient of $V_{oc}$	-0,361	%/°C	
Temperature Coefficient of $I_{sc}$	+0,08	%/°C	

\* All technical specifications are subject to change without notice by Onyx Solar

<b>GLASS PROPERTIES</b>	<b>Onyx Equivalent Glass</b>
Light Transmission	52%
U-value [W/sqm.K]	-
Peak Power [Wp/sqm]	77,9






Figure 5.34 Demo-site 4, design of ONYX PV module, type C1




Figure 5.35: Demo-site 4, design of ONYX PV module, type C2

## 5.5 BIPV ELECTRICAL SYSTEM DESIGN

### 5.5.1 BIPVBOOST system components

The electrical design of the system was studied in detail and all electrical components were selected accordingly. It was decided to realize the PV installation using a mono phase inverter for every façade as each façade is oriented in different direction and generates different power. Electrical components required for demo-site installation are listed in Table 5.5. Figure 5.36 provides technical data sheet of the inverter.

**Table 5.5 Demo-site 4, list of electrical components**

SR. NO.	ITEM	QTY.
1	"QE-A" / "QE-B" ELECTRICAL PANEL	2 units
2	"QE-PAR" ELECTRICAL PANEL	1 unit
3	GENERAL CIRCUIT BREAKER TO BE INSTALLED ON AN EXISTING FRONT ELECTRICAL PANEL	1 unit
4	PARALLEL CIRCUIT BREAKER TO BE INSTALLED ON "QE-A" AND "QE-B"	2 units
5	CABLE TYPE H1 Z222-K RED 1 X6MMQ	220 m
6	CABLE TYPE H1 Z222-K BLACK 1 X6MMQ	220 m
7	FG1 6OR1 6 5G6 TYPE CABLE	45 m
8	CATEGORY 6 U / FTP DATA CABLE	90 m
9	INVERTER ZCS AZZURRO 1 1 00TL-WS	8 units
10	EMERGENCY CIRCUIT BREAKER FOR EACH INVERTER	8 units
11	WATERPROOF SWITCHBOARD GEWISS TYPE EMERGENCY SYSTEMS - GW42201	1 unit

TECHNICAL DATA	1100TL	1600TL	2200TL	2700TL	3000TL
<b>DC Input data</b>					
Typical DC power	1200W	1800W	2400W	2900W	3300W
No. of independent MPPTs/No. of strings per MPPT	1/1				
Maximum DC input voltage	450V		500V		
Activation voltage	100V		120V		
Nominal DC input voltage	360V				
MPPT range of DC voltage	80-450V		100-500V		
DC voltage range at full load	110-450V	165-450V	170-500V	200-500V	
Maximum input current for each MPPT	10A	7A	13A	13.5A	15A
<b>AC output data</b>					
Nominal AC power	1000W	1550W	2100W	2600W	3100W
Maximum AC power	1000VA	1550VA	2100VA	2600VA	3100VA
Maximum AC Current	4.5A	7A	9.5A	11.5A	13A
Type of connection/nominal grid voltage	Single-phase L/N/PE / 220V,230V,240V				
Grid Voltage range	180-270V (according to the local grid standards)				
Grid nominal frequency	50/60Hz				
Grid frequency range	45-53 / 57-63 Hz (according to the local grid standards)				
Total current harmonic distortion	<3%				
Power factor	1 (programmable +/-0.8)				
Active Power adjustable range	0-100%				
Grid feed-in limitation	Feed in adjustable from zero to the nominal power value*				
<b>Efficiency</b>					
Maximum efficiency	97%		97.1%		97.2%
Weighted efficiency (EURO)	95.2%	95.9%	96.1%	96.4%	96.5%
MPPT efficiency	>99.9%				
Night-time consumption	<1W				
<b>Protections</b>					
Safety protections	Anti islanding, RCMU, Ground Fault Monitoring				
DC reverse polarity protection	Yes				
DC switch	Optional (only WS models)				
Surge protection	Yes				
Protection class/Surge category	I/III				
Integrated dischargers	AC/DC MOV: Type III standard				
<b>Standard</b>					
EMC	EN 61000-6-1/2/3/4,				
Safety standard	IEC 62116, IEC 61727, IEC 61683, IEC 60068-1/2/14/30, IEC 62109-1/2				
Grid connection standard	AS 4777, VDE V 0124 100, VDE V 0126 1-1, VDE AR-N 4105, EN50438, G83/2, C10/II, RD1699, CEI 0-21				
<b>Communication</b>					
Communication interfaces	Wi-Fi (only WS models), RS485 (proprietary protocol), SD card				
Additional inputs or connections	Input for current sensor connection				
Data storage on SD	25 years				
<b>General information</b>					
Permissible ambient temperature range	-25°C...+60°C (power limitation above 45°C)				
Topology	Transformerless				
Environmental protection rating	IP65				
Permissible relative humidity range	0%...95% senza condensazione				
Maximum operating altitude	2000m				
Noise	< 25dB @ 1mt				
Weight	11kg		12kg		
Cooling	Natural ventilation				
Dimensions (H*L*D)	405mm*314mm*135mm				
Display	LCD				
Warranty	10 years				

\*Possible by connecting a current sensor (ZSI-ACC-TA)

Figure 5.36: Technical data sheet of inverter Azzurro 1100TL

## 5.5.2 BIPVBOOST electrical diagram

The electrical scheme of the demo-site BIPV installation is shown in Figure 5.37:




Figure 5.37: Electrical diagram for the demo-site installation

## **5.6 BIPV MONITORING DESIGN**

### **5.6.1 Definition of monitoring objectives: BIPV performance validation, economic viability and progress towards NZEB requirements**

The main objective of the monitoring system is to verify and validate the Energy performance of the BIPV installation at the demo-site through the measurement of key variables. The measurement methodology and key variables to be measured were defined in Deliverable 8.3. The monitoring methodology described in Deliverable 8.3 is based in the inter-comparison of two monitoring periods, defined as the pre-intervention period (base line) and the post intervention period.

The implementation of pre-intervention period monitoring system has been finished in July 2020 and measurements are being gathered since August 2020. The post-intervention monitoring system will be implemented after the intervention described in this document in September 2021.

Next, the pre-intervention period monitoring system is presented and later this document will be updated with the implementation of a post-intervention monitoring system.

### **5.6.2 Definition of variables to be monitored**

The monitoring objectives will be reached through the measurement of the energy variables shown in Figure 5.38. Table 5.6 enlists short definition of the variables depicted in Figure 5.38 and additional information about instruments used for the measurements. In Table 5.6, variables that are being monitored during preintervention period are in blue and the variables that will be monitored during the post intervention period variables written in red.

It can be seen that during the pre-intervention period variables are related to the meteorology, building energy consumption from the grid and energy consumption by the heat pump. Moreover, during the post intervention period, energy production of BIPV modules will also be measured.

## Demo PIZ




Figure 5.38: Main measuring variables of PIZ demo site. Blue variables are being monitored since the start of preintervention year and the red variables will be monitored afterwards postintervention period.

Table 5.6. Description of the variables shown in Figure 5.38 and the instruments used for the measurements.

Variable	Description	Instrument	Range	Units	Time Resolution	Accuracy
<b>BIPV components</b>						
<b>Opaque cladding</b>						
<b>East</b>						
<b>Meteo</b>						
G <sub>oc_east</sub>	Irradiance East plane	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
T <sub>m_oc_east</sub>	Module temperature	Thermocouple type T	0-100	°C	<1min	1K
<b>DC</b>						
I <sub>oc_east_DC</sub>	DC Intensity	Amperimeter		A	<1min	1% of the reading
V <sub>oc_east_DC</sub>	DC Voltage	Voltimeter		V	<1min	1% of the reading
P <sub>oc_east_DC</sub>	DC Power	medidor de potencia	10	kW	<1min	2% of the reading
ET <sub>oc_east_DC</sub>	DC Energy	Energy meter		kW/h	<1min	
<b>AC</b>						
P <sub>oc_east_AC</sub>	AC Power	Power meter	10	kW	<1min	2% of the reading
ET <sub>oc_east_AC</sub>	AC Energy	Energy meter		kW/h	<1min	
<b>South</b>						
<b>Meteo</b>						
G <sub>oc_South</sub>	Irradiance south plane	Reference cell	0-1200	w/m <sup>2</sup>	<1min	5% of the reading
T <sub>m_oc_South</sub>	Module temperature	Thermocouple type T	0-100	°C	<1min	1K
<b>DC</b>						
I <sub>oc_South_DC</sub>	DC Intensity	Amperimeter		A	<1min	1% of the reading



V <sub>oc_South_DC</sub>	DC Voltage	Voltimeter		V	<1min	1% of the reading
P <sub>oc_South_DC</sub>	DC Power	medidor de potencia	10	kW	<1min	2% of the reading
ET <sub>oc_South_DC</sub>	DC Energy	Energy meter		kW/h	<1min	
<b>AC</b>						
P <sub>oc_South_AC</sub>	AC Power	Power meter	10	kW	<1min	2% of the reading
ET <sub>oc_South_AC</sub>	AC Energy	Energy meter		kW/h	<1min	
<b>West</b>						
<b>Meteo</b>						
G <sub>oc_West</sub>	Irradiance west plane	Reference cell	0-1200	w/m2	<1min	5% of the reading
T <sub>m_oc_West</sub>	Module temperature	Thermocouple type T	0-100	°C	<1min	1K
<b>DC</b>						
I <sub>oc_West_DC</sub>	DC Intensity	Amperimeter		A	<1min	1% of the reading
V <sub>oc_West_DC</sub>	DC Voltage	Voltimeter		V	<1min	1% of the reading
P <sub>oc_West_DC</sub>	DC Power	medidor de potencia	10	kW	<1min	2% of the reading
ET <sub>oc_West_DC</sub>	DC Energy	Energy meter		kW/h	<1min	
<b>AC</b>						
P <sub>oc_West_AC</sub>	AC Power	Power meter	10	kW	<1min	2% of the reading
ET <sub>oc_West_AC</sub>	AC Energy	Energy meter		kW/h	<1min	
<b>Building</b>						
<b>Meteo</b>						
G <sub>iHorizontal</sub>	Horizontal Irradiance	Pyranometer	0-1200	w/m2	<1min	5% of the reading
T <sub>amb</sub>	ambient temperature	Thermocouple type T	0-50	°C	<1min	1K
Sw	Wind speed	Ultrasonic anemometer	0-100	m/s	<1min	Sw<5m/s--->0,5m/s;Sw>5m/s-->10% of the reading
<b>Grid</b>						
P <sub>gr</sub>	AC Power	Power meter		kW	<1min	2% of the reading
E <sub>gr</sub>	AC Energy	Energy meter		kW/h	<1min	
<b>Heat Pump</b>						
P <sub>hp</sub>	AC Power	Power meter		kW	<1min	2% of the reading
E <sub>hp</sub>	AC Energy	Energy meter		kW/h	<1min	

### 5.6.3 BIPVBOOST monitoring system

The installation of the pre-intervention monitoring system was carried out in two main group of components; Meteorological station and the main board.

The meteorological station was installed on the roof and consist of the following components (see Figure 5.39 and Figure 5.40);

- 1 anemometer for measuring wind speed (Sw)
- 3 references cells in the equivalent plane that will be installed the opaque cladding BIPV modules for measuring the irradiance ( $G_{i_{oc\_east}}$ ,  $G_{i_{oc\_south}}$ ,  $G_{i_{oc\_west}}$ )
- 1 pyranometer for measuring the horizontal global irradiance (Gi)
- 1 temperature sensor (PT-100) for measuring the ambient temperature.


**Roof installation**

Figure 5.39: pre-intervention monitoring system meteorological station installed on the roof.





Figure 5.40: Pre-intervention monitoring system meteorological station connections diagram.


On the other hand, the main board was installed in the metering room as seen in Figure 5.41 and Figure 5.42. It contains following components.

- The data logger
- The heat pump energy meter to measure heat pump consumption ( $P_{hp}, E_{hp}$ ).
- The grid connection energy meter for measuring the building energy consumption. ( $P_{gr}, E_{gr}$ )

**Monitoring system main board**



**Figure 5.41: Monitoring system main board installed in the counter room.**



**Figure 5.42: Monitoring system main board connections diagrams.**

## Data collection

The measurements of the sensors are collected by the data logger via Modbus and sent to Tecnalia headquarters through internet connection using a modem integrated in the monitoring system. Data gathered by the monitoring system can be checked online on the web datalogger prepared for this purpose, screenshot of online web datalogger is shown in Figure 5.43




Figure 5.43: Screen shot of the web datalogger.

## 5.7 BIPV MODELLING AND PERFORMANCE SIMULATION

EnerBIM, as WP6 leader and BIMsolar tool developer, has completed BIPV systems digital modeling and simulation work as a pre-study.

### 5.7.1 Element level to building level methodology using 3D modeling and simulation tools

#### 5.7.1.1 Overall methodology

The same methodology presented in Section 2.7.1.1 has been used.

#### 5.7.2 Modeling strategy retained for transparent and opaque BIPV

The software is being developed to fit with ONYX Solar strategies regarding glazing systems and transparent BIPV products. The BIPV module configurator is based on 4 editors:


- Cell editor
- Pattern editor
- Transparent Glass editor
- Glazing editor

To design a transparent BIPV system, we have fixed the following steps:

BIPV Layout



Balance of System (downstream studies)



### 5.7.3 DEMO#4 – PIZ building, 3D design from 2D plans, simulation with BIMsolar

#### 5.7.3.1 Hypothesis

BIPV modules have been set up from ONYX Solar and PIZ datasets (up to date version).

COLOURED cells: the development of these specific cells and patterns databases for BIPV with adequate models is not completed for BIMsolar software at this stage (WP6 T6.3 – M48)

To run first simulations, we have selected mono crystalline cells and glass modules from ONYX standards and set up features from ONYX Solar modules datasheets.

#### 5.7.3.2 FACADE CLADDING MODULES – ONYX Solar BIPV glass for simulation

Table 5.7 Configuration of ONYX Solar Cladding modules

<p><b>A1 &amp; A2 BIPV MODULES</b></p> <p>1110mm x 451mm</p> <p>Cell color : Sparkling gold</p> <p>102 panels distributed over all the contours</p> <p>Total : 204 panels</p>	
---	--



<p><b>B1 &amp; B2 BIPV equivalent MODULES</b></p> <p>1064mm x 451mm</p> <p>Cell color : Sparkling gold</p> <p>2 panels on North-East façade of each building.</p> <p>Total : 4 panels</p>	
<p><b>C1 &amp; C2 BIPV equivalent MODULES</b></p> <p>668mm x 451mm</p> <p>Cell color : Sparkling gold</p> <p>2 panels on South-West façade of each building.</p> <p>Total : 4 panels</p>	



### 5.7.3.3 WEATHER DATA and IRRADIATION MODELING

We chose to use the European open access reference tool PVGIS to generate meteorological + site data at the exact location of the demo site. Visualization from satellite enable considering terrain modelling, albedo evaluation and masking effects.


<p><b>GEO LOCATION</b></p> <p>➔ Google Maps</p>	
---	--

<p>➔ PVGIS</p> <p>ORIENTATION</p> <p>➔ +30° from Google Maps interpretation</p> <p>ALBEDO</p> <p>➔ 20% ground</p> <p>➔ 50% buildings</p>	<p>The top row shows two maps from PVGIS. The left map is a regional view of the area around Talamona, showing terrain and various locations. The right map is a more detailed street-level view of the same area, highlighting specific buildings and streets. Below these maps is a satellite-style aerial view of the same location, showing the layout of buildings and green spaces.</p>
<p>HORIZON</p> <p>IN PLANE IRRADIATION for typical 35° PV angle</p> <p>➔ Severe masking for PV production during winter</p>	<p>This section contains two charts. On the left is a bar chart titled 'Monthly in-plane irradiation for fixed angle'. The y-axis is 'In-plane irradiation [kWh/m<sup>2</sup>]' ranging from 0 to 200. The x-axis is 'Month' from Jan to Dec. The bars show a seasonal peak in July (~180 kWh/m<sup>2</sup>) and a significant dip in winter months (Jan, Feb, Nov, Dec). On the right is a circular diagram titled 'Outline of horizon' showing the horizon height and sun heights for June and December. The sun height for June is significantly higher than for December, illustrating the seasonal variation in solar elevation.</p>
<p>IRRADIANCE</p> <p>TMY data to generate weather file as input for BIMsolar (epw)</p> <p>TMY Period: 2007-2016</p> <p>Time step: hourly</p> <p>➔ Horizontal mask effects at winter</p>	<p>This section contains two charts. On the left is a line chart titled 'Typical Meteorological Year: Global horizontal irradiation'. The y-axis is 'Global horizontal irradiation [W/m<sup>2</sup>]' ranging from 0 to 1000. The x-axis shows months from January to January. The chart shows a highly variable, hourly irradiation profile with a clear seasonal peak in summer and a significant dip in winter. On the right is another circular diagram titled 'Outline of horizon' showing the horizon height and sun heights for June and December. A callout box indicates 'Sun height, June Height 47° at azimuth -74°', highlighting the high sun position in June.</p>

→ no direct irradiance at winter



BIMsolar epw importation  
Sun course / heliodon





### 5.7.3.4 3D MODELING - SETUP- EXISTING BUILDING








Figure 5.44: Modelling has been made as much realistic as it could be from the existing 2D plans to address BIPV issues (Trimble SketchUp model from PIZ)

### STEP#1- BIMsolar IMPORTATION – Building settings





**Figure 5.45: Close and far shadowing calculation are made through 3D modelling of realistic buildings - Sun course for full year is displayed at hourly step time – 4 seasons illustration**



**Figure 5.46: Close and far shadowing calculation – Specific illustration – DEC 21<sup>st</sup> – 12:00**






Figure 5.47: Albedo effects (reflected irradiance) are generated selecting groups and types of surfaces

20% as a setup for surroundings and 50% for the buildings envelopes as a general approach

### 5.7.3.5 Simulation – Results

#### STEP#2-IRRADIATION

We use markers to record and visualize values

Sets of data can be exported in CSV

#### SOUTH FACADES mapping & survey

<p>Yearly kWh/sqm          →620kWh/sqm recorded for facade A          →570kWh/sqm recorded for facade B          (exclusion of shading issue due to beam)</p>	
<p>Average day          140kWh/sqm recorded for facade A          →128kWh/sqm recorded for facade B          (exclusion of shading issue due to beam)</p>	

<p>Direct ratio          →70% recorded for façade A          →68% recorded for façade B          (exclusion of shading issue due to beam)</p>	
<p>Shading          →only external beam generates shading issues</p>	

***EAST FACADES mapping & survey***


<p>Yearly kWh/sqm          →800kWh/sqm recorded as average value</p>	
--	--

<p>Average day 180kWh/sqm recorded as average value</p>	
<p>Direct ratio →61% recorded</p>	
<p>Shading →no issue</p>	







**NORTH FACADES mapping & survey**

<p>Yearly kWh/sqm</p> <p>→530kWh/sqm recorded for facade A East side</p> <p>→430kWh/sqm minimum for facade A West side</p> <p>→550kWh/sqm recorded for facade B as a minimum</p>	
<p>Average day</p> <p>→119kWh/sqm recorded for facade A East side</p> <p>→102kWh/sqm minimum for facade A West side</p> <p>→123kWh/sqm recorded for facade B</p>	
<p>Direct ratio</p> <p>→22% recorded for facade A East side</p> <p>→16% recorded for facade A East side</p> <p>→22% recorded for facade B</p>	



**WEST FACADES mapping & survey**



<p>Direct ratio →36% recorded</p>	
<p>Shading →no issue</p>	

### STEP#3 – BIPV layouts

We use virtual modules set-up from manufacturer's datasheets (see above) to generate BIPV systems. Production, shading losses, temperature losses are calculated in real time from module level to BIPV layout level. Every single module is computed as a system and the software displays individual KPIs.

Detailed results can be obtained at STEP#5 (BIMsolar reference process).



**Building A**


**Figure 5.48: Building A – 2 rows of 1110x451mm (=102 modules) on South, East, West and North facades + 2 rows 668x451mm (=2 modules) on South-West + 2 rows of 1064x451mm (=2 modules) on North-East facades – Total 4.9kWp / 52.6sqm**

### Building A

<b>Power:</b>	4.9 kWp
<b>Module area:</b>	52.6 m <sup>2</sup>
<b>Estimated prod.:</b>	2695.8 kWh
<b>Array yield:</b>	548.1 kWh/kWp
<b>Shadow losses:</b>	5.9 %
<b>Heat losses:</b>	9.1 %

Name	Modules
BAPV systems	
BIPV systems	
ONYXsolar - ePIZ_A1&...	24
ONYXsolar - ePIZ_A1&...	28
ONYXsolar - ePIZ_A1&...	24
ONYXsolar - ePIZ_A1&...	12
ONYXsolar - ePIZ_A1&...	14
ONYXsolar - ePIZ_C1&...	2
ONYXsolar - ePIZ_B1&...	2

**Figure 5.49: Global results building A – All layouts**




Figure 5.50: Shading mapping at module level – Main issue is shading from external beam (south, 70% on 2 modules)



**Building B**



**Figure 5.51: Building B – 2 rows of 1110x451mm (=102 modules) on South, East, West and North facades + 2 rows of 668x451mm (=2 modules) on South-West + 2 rows of 1064x451mm (=2 modules) on North East facades – Total 4.9kWp / 52.6sqm**

**Building B**

<b>Power:</b>	4.9 kWp
<b>Module area:</b>	52.6 m <sup>2</sup>
<b>Estimated prod.:</b>	2740.1 kWh
<b>Array yield:</b>	557.1 kWh/kWp
<b>Shadow losses:</b>	4.5 %
<b>Heat losses:</b>	9.0 %

Name	Modules
BAPV systems	
> BIPV systems	

**Figure 5.52: Global results building B – All layouts**




Figure 5.53: Shading mapping at module level



### STEP#4 – INVERTERS / WIRING

We have implemented the inverters as listed on the single line diagram:


- Azzuro-1100-TL: 30 panels
- Azzuro-1100-TL: 24 panels
- Azzuro-1100-TL: 24 panels
- Azzuro-1100-TL: 28 panels

### Building A



Figure 5.54: Building A - 1 inverter on each façade for all the panels (=4 inverters Azzuro-1100-TL), there is 102 module types A1&A2, 2 module types B1&B2 and then 2 C1&C2

### Building B



**Figure 5.55: Building B – 1 inverter on each façade for all the panels (=4 inverters Azzuro-1100-TL), there is 102 module types A1&A2, 2 module types B1&B2 and then 2 C1&C2**



**STEP#5 – RESULTS**

BIMsolar offers a comprehensive set of detailed results, from yearly to hourly timestep, covering irradiance, shading losses, heat losses, production, yield... from module level to layout level.

Example on building A:






Figure 5.56: Production + shading losses: building A – Monthly analysis

**Building A - Table of results:**






**Building B - Table of results:**

<p>Production – Shading losses</p> <p>GLOBAL</p> <p>→ Production= 2 740kWh (96%)</p> <p>→ Shading losses= 128kWh (4%)</p>	
<p>Production – Shading losses</p> <p>MONTHLY</p> <p>→ strong discrepancy due to horizontal masking, low season</p> <p>→ 7 months are well balanced and July is the most productive</p>	
<p>Production – Shading losses</p> <p>AVERAGE DAY / MONTH</p>	

Production – Shading losses  
DAILY



**Building A - Layouts YIELD survey & mapping**

Array yield and KPIs displayed at module level

SOUTH-WEST FACADES



SOUTH-WEST FACADES



SOUTH-WEST FACADES



SOUTH-WEST FACADES





SOUTH-EAST FACADES



SOUTH-EAST FACADES




SOUTH-EAST FACADES







NORTH-WEST FACADES



NORTH-WEST FACADES



NORTH-WEST FACADES



NORTH-EAST FACADES



NORTH-EAST FACADES



NORTH-EAST FACADES



**Building B - Layouts YIELD survey & mapping**

SOUTH-WEST FACADES



SOUTH-WEST FACADES



SOUTH-WEST FACADES



SOUTH-WEST FACADES






SOUTH-EAST FACADES



SOUTH-EAST FACADES




SOUTH-EAST FACADES











### 5.7.4 –Summary of the results

Unit	Array				Inverter								Yield				
	kWh		Panel orientation	kWh	kWh		kWh		kWh		%		kWh		kWh/kWp		
	Building A	Building B			Building A	Building B	Building A	Building B	Building A	Building B	Building A	Building B	Building A	Building B	Building A	Building B	
			Azimet*	Building A	Building B	Building A	Building B	Building A	Building B	Building A	Building B	Building A	Building B	Building A	Building B	Building A	Building B
Direct	10 289	10 460	East	-60	824,9	834,5	784,0	795,0	37	38	4,8%	4,8%	747,0	757,0	661,0	671,0	
Diffuse	15 016	15 349	South	30	765,1	729,0	427,0	453,0	20	21	4,8%	4,8%	407,0	432,0	298,0	317,0	
Indirect	6 406	6 406	West	120	536,3	549,4	497,0	515,0	23	24	4,8%	4,8%	474,0	491,0	419,0	435,0	
			North	150	569,4	627,5	462,0	550,0	22	26	4,8%	4,8%	440,0	524,0	338,0	403,0	
	31 711,0	32 215,0	*South = 0°		2 695,7	2 740,4	2 170,0	2 313,0	102,0	109,0	4,8%	4,8%	2 068,0	2 204,0	429,0	456,5	
<b>TOTAL:</b>	<b>63 926,0</b>				<b>5 436,1</b>		<b>4 483,0</b>		<b>211,0</b>				<b>4 272,0</b>		<b>MEAN VALUES</b>		

### 5.7.5 Conclusions

At the current stage of the validated performance of the software and provided the fact that products and project are submitted to updates we consider that the first results are positive and converging towards expectations. We did not face critical difficulties in the process.

- Shading issues: potential discrepancies with electrical production on south layouts due to shading effects from the external beams / poles. Up to 40% of shading for two modules, 20% for four

modules, may create mismatching effects and lowering of the MPP for the entire string (modules are connected in series, 1 string per facade),

- Direct reception ratio discrepancy to be considered (max 70% south, min 16% maximum North); the fact that each façade is independent with its own inverter avoids the mismatching between strings,
- Production seems to be quite well balanced within a 7-month period. Winter should be very low (less than 20% of the summer production) because of the lack of irradiation due to the horizontal masking (valley effect)
- July is the most productive period for both buildings,
- Building B is more productive than building A. For both buildings, the East facades are the most productive, the South facades the less.




Figure 5.57: Highlight of mismatching of irradiation between extreme modules

Next steps will be:

1. Update of the building 3D model, related to the final BIPV integration (demo site manager),
2. BIM upgrade of the modules following ONYX Solar and PIZ specifications, to enable technical design of the system,
3. Comparison between measurement and simulation as soon as the real modules will be integrated and monitoring available.



## 6 NEXT STEPS

The following steps are focused to the validation of the design of the prototypes for each demo-site according to the test results performed in WP5. Once the design is completely validated and accepted by the demo-owners, the partners of the consortium will start with the manufacturing of the BIPV modules and structure.

In the following months it has been planned to install all the equipment and prototypes for the BIPVBOOST installation in the four demo-sites according to the design and Gantt chart detailed in the present deliverable.

The monitoring installation will continue with the data acquisition before and after the BIPVBOOST installation. This task will be performed until the end of the project.

The baseline of each demonstration site will be evaluated according to monitoring data gathered from each demo-site. This will allow to define the energy demand baseline to be compared with the demand after the BIPVBOOST installation.

Each demo-site is being developed aligned to project objectives, and a post-intervention performance assessment and quantification of cost reduction and energy efficiency related impacts will be performed for each demo.